

Preliminary prospects of a Pumped Thermal Energy Storage (PTES) based on a supercritical CO₂ Brayton cycle

Karin EDEL^{a,*}, František HRDLIČKA^a, Václav NOVOTNÝ^a

^a*Czech Technical University in Prague, Faculty of Mechanical Engineering, Department of Energy Engineering, Technická 4, Prague 6, 166 07 – Prague, Czech Republic*

[*karin.edel@fs.cvut.cz](mailto:karin.edel@fs.cvut.cz)

Abstract:

As part of the change towards a higher deployment of renewable energy sources, which naturally deliver energy intermittently, the need for energy storage systems is increasing. For compensation of disturbance in power production due to inter-day to seasonal weather changes, long-term energy storage is required. In the spectrum of storage systems, one out of a few geographically independent possibilities is the storage of electricity in heat, so-called Carnot-Batteries. This paper presents a Pumped Thermal Energy Storage (PTES) system based on a recuperated supercritical CO₂ Brayton cycle. The modelled system provides a round-trip efficiency of 38.9%.

Keywords: pumped thermal energy storage (PTES), Carnot-batteries, power-to-heat-to-power (P2H2P), supercritical CO₂ cycle, Brayton cycle, heat exchange, pinch-point analysis

1 Carnot-Batteries as a future energy storage solution

In this Introduction, the reason why the demand for energy storage is rising will be briefly addressed. It follows a classification of energy storage, an explanation of the Carnot-Batteries concept, the currently operating pilot plants and a brief review of CO₂ as working fluid for PTES.

1.1 The reason for the rising demand for energy storage

As the demand for renewable energies is increasing, so is the importance of its reliability. Unfortunately, the availability of energy from renewable sources and the electricity demand are usually not corresponding. Most renewable energy is obtained from so-called variable renewable energy sources (VRES) like sun and wind, which the electric grid could handle, up to maximum integration of 10% without any further changes [1]. The variation of hourly wind speed, as well as the solar radiation, compared to the feed-in, at the example of Nuremberg in Germany, can be visually compared in Figure 1 and Figure 2. This shall give an idea of the fluctuation of “available weather” and energy demand throughout a day. For this purpose, Figure 1 also shows the variation of the wind by highlighting its minimum and maximum values (at the different hours of the day throughout the year). The wind speed and sun radiation data is obtained from the MERRA database [2]¹, and the feed-in values from a local energy supplier called N-ERGIE [3].

¹ The data from the MERRA data base was, with kind permission, retrieved and processed with an Excel-Tool (version 18.03.2016) from Prof. Dr.-Ing. Matthias Popp, Burgstraße 19, D-95632 Wunsiedel, Germany.




Figure 1: Intraday load curve network supply and wind speed in Nuremberg, Germany, 2015 [2,3]




Figure 2: Intraday load curve network supply and sun radiation in Nuremberg, Germany, 2015 [2,3]

These kinds of inequalities of offer and demand can be observed worldwide and the whole year round, also requiring shifting energy between different seasons of the year. To encounter this problem, besides focusing on making the energy production as flexible as possible, energy storages are about to become of great importance in the change to a decarbonised future, as also stated by the International Energy Agency (IEA) [4].

Energy storage can also be an enabler for making VAES power plants like a Concentrated Solar Power (CSP) more competitive to traditional, fossil fuel burning power plants [5]. Thermal storage, directly integrated into the power cycle, can replace the sun as a source of heat during shady times and allow the CSP plant to deliver energy more continuously and reliable. With a competitive solution like this, places with high availability of sun radiation, like for example Western China, could effectively use the sun instead of a fossil fuel power plant, even if the interest would be from more economic nature, rather than solely for the protection of the environment.

1.2 Classification of PTES as energy storage

In the spectrum of storage systems, thermal energy storage (TES) is one out of a few possibilities how to store energy environmentally friendly and geographically independent. The potential of different storage principles is visualised in Figure 3. Electro-Thermal Energy Storage (ETES) is rated as a technology, feasible for longer storage time and higher power. However, it is also still in its concept phase [6], with the first demonstrators being tested.




Figure 3: Comparison between different storage technologies (modified from [6,7])

1.3 PTES – principle and pilot plants

The principle of PTES (also called Carnot-Battery, Electro-Thermal Energy storage ETES or Pumped Heat Energy Storage PHES²) is pretty straightforward. The storage process consists out of three phases: charging the storage with a heat pump cycle or an electric heater (though it is not pumped then), storing the heat in hot and cold reservoirs, and discharging the storage with a power cycle (Fig. 4). A PTES can employ latent heat storage with, for example, Phase Change Materials (PCM) or sensible heat storage with materials like oil, rocks, or salts.




Figure 4: Principle of Pumped Thermal Energy Systems (modified from [8])

By 2020, several Carnot-Battery pilot plants have been operated successfully. The Argon-based Brayton Cycle with 150 kW (600 kWh electric) of the *Newcastle University*, built with the help of the company *Isentropic Ltd.* in the United Kingdom, is deploying reciprocating devices. The system has a round-trip efficiency of 60% to 65% [9] and is based on the theoretical concept by Howes [10]. *SIEMENS Gamesa* built a PTES pilot in Hamburg, Germany which went into operation in summer 2019 [11–13]. They use an electric heater to heat air which is blown through a packed bed storage for charging it. For retrieving power from the system, the heat can be used to generate steam for a conventional Rankine cycle. The maximum electrical output power is then 1.5 MW, while the storage has a capacity of 30 MWh electric, with a round-trip efficiency of about 45% [8–10]. Further, two thermally integrated PTES (TI-PTES) with heat pump/organic Rankine cycle in lab-scale were built in Liege, Belgium [14]. Utilising waste heat at 75 °C as the cold source for the heat pump a round-trip efficiency of 100% is reached [14,15]. A liquid-air energy storage (LAES) with 8% round-trip efficiency from the company *Highview*

² Not to be confused with PHS (Pumped Hydro Storage).

Power delivering 350kW (2.5MWh) was tested from 2011 to 2014 in Greater London [16,17]. However, there are already several other projects of Carnot-Battery pilot plants under development, construction or in testing.

1.4 CO₂ as working fluid for PTES cycles

CO₂ is an interesting candidate as a working fluid for PTES systems, because of its critical point at nearly ambient temperature and high densities. The low temperature is good for heat rejection in a Brayton cycle [18]. The high density results in a comparably low compression work and high power density, which results in small turbomachinery [19]. Additionally, it is widely available, inexpensive and nontoxic [19]. Problems with CO₂ are, that it is highly diffusive, enhancing corrosion of surrounding materials or leads to rapid depressurisation and that it is very sensitive to small changes in pressure or temperature near the critical point [19]. Additionally, the specific heat capacity of carbon dioxide is strongly variable, leading to high changes in the temperature difference between the hot and cold fluid in heat exchangers, which can cause the minimal temperature difference to be not at inlet or exit but inside the heat exchanger, which is called pinch-point-problem [18]. Compared to cycles running with other working fluids, CO₂ cycles are not so widely tested and used yet, which can lead to possible problems, but also offers great potential.

Most proposed PTES systems which employ CO₂ as the working fluid are based on transcritical Rankine cycles, reaching between 40.9% and 68.6% round-trip efficiency [20–24]. Only McTigue et al. propose a supercritical CO₂ Brayton cycle, reaching 60.4% round-trip efficiency with a low-temperature cycle and 78.4% in a high-temperature cycle [25]. A very different approach is the transcritical isothermal Rankine cycle by Kim et al., using a double-acting liquid piston system with direct heat transfer to the storage media water, reaching 68.6% round-trip efficiency [26].

For the proposed transcritical CO₂ Rankine cycles the pinch-point problem is usually encountered by using multiple hot storage tanks, using indirect heat transfer to (mostly pressurised) water tanks [20,21,27]. For Ayachi et al. [23], who are using ground storage, the heat transfer is directly between the CO₂ and the solid storage material through which it is flowing (direct, passive multi-tube packed bed storage). Their pinch-point considerations are directly connected with the overall storage design. Steinmann et al. [24] point out that it is generally impossible to achieve a mean temperature difference of 5 K to 10 K between a single pressurised water storage and the CO₂, while still having a constant mass flow and significant heat transfer (temperature difference) in the heat exchanger. Unlike the before mentioned research, they choose to assume an ideal storage system, neglecting the pinch-point problem, rather than specifying a possible solution. McTigue et al. designed a simple, not recuperated Brayton cycle [25], even though they're mentioning, that recuperation would be feasible due to the high-temperature difference between compression and expansion.

Due to the high potential of CO₂ in its supercritical state, this paper investigates another design of Brayton sCO₂ PTES. The proposed cycle is recompressed and employs double recuperation because this layout is reaching the highest efficiencies for sCO₂ cycles [28,29].

2 Concept of a supercritical CO₂ Brayton cycle with liquid hot and cold storage

2.1 Description of the hot and cold storage

The proposed supercritical CO₂ Brayton cycle has a liquid hot, as well as cold, two-tank storage. For the discharging cycle, a turbine and two compressors (one for recompression) are needed. The same principle applies to the charging cycle, where two turbine sections and one

compressor are necessary. For the charging cycle, a heat exchanger to ambient air is necessary due to irreversibilities within the cycle. Further, each configuration needs two heat exchangers for recuperation. Two heat exchangers for transferring heat between the cycle and the storage tanks are used for charging and discharging. Since the heat pump and the power cycle can employ the same pressure ratio due to the flexibility in mass flows through the recompression stage, it seems possible, that some of the turbomachinery can be used in charging and discharging mode. Possible effects are not considered further.

Each storage consists out of two tanks, from which one contains storage material at high-temperature and the other one material at low-temperature. Within a tank, the storage material is kept at a constant temperature. Figure 5 shows the working principle of the two-tank storage. During charging, the material from the colder tank of the hot storage is pumped through a heat exchanger, which is transferring heat from the cycle to the storage media. It is then stored in the second tank at a higher temperature. For the cold storage, the fluid is cooling down during the charging cycle, heating the cycle fluid. In the discharging phase, the fluid is pumped the other way around. The hot tank of the hot storage is emptying while the colder tank is filling up, and the level of fluid in the cold tank of the cold storage is descending while it is rising in the warmer tank. Through maintaining a constant flow between a charged and discharged tank of a storage, where both tanks maintain a constant temperature but only vary in the amount of stored material, the heat flux in the heat exchanger is constant. The constant heat flux is an advantage to packed beds, where the problem of a non-constant temperature output, is a challenge faced in cycle design.

The hot storage material is solar salt with the chemical composition of 60% NaNO_3 + 40% KNO_3 . It has a melting temperature of 221.04 °C and thermal stability up to 588.51 °C [30]. The mean heat capacity for the operating temperatures of the hot storage is $1.518 \text{ kJ kg}^{-1} \text{K}^{-1}$ [31]. The cold storage can work with thermal oil, like THERMINOL 66, due to the lower temperatures (thermal stability up to 380 °C) [32]. The mean heat capacity of the thermal oil at cold storage temperatures is $1.782 \text{ kJ kg}^{-1} \text{K}^{-1}$. Self-discharge of the storages is neglected.




Figure 5: Scheme of the hot and cold two-tank storage

2.2 Double recuperated and recompressed Brayton Cycle with CO₂ as working fluid

The PTES is designed to deliver 10 MW of thermal power (3.4 MW electric). Self-discharging of the storages, the pumps on the storage side, as well as mechanical and electrical losses, are neglected, while losses due to heat transfer were considered. A sensitivity analysis was carried out to optimise cycle performance, as well as a pinch-point analysis.

2.2.1 Cycle layout for charging the (hot) storage

In Figure 6, the layout of the charging cycle is shown. At a pressure ratio of 3, the system is operating between 16 °C and 513 °C. From point 1 to 2 the CO₂ is compressed to a pressure of 24 MPa, and between 2 and 3, the heat is used for charging the hot storage, cooling down the fluid. The heat at the lower temperature is recuperated between 3 and 4. At point 4, the mass flow is split, to continue with recuperation from 4 to 5 and expansion from 4 to 8. After point 5, irreversibilities are dissipated to the environment in a heat exchanger between 5 and 6. From 6 to 7, the second portion of the working fluid is expanded back to 8 MPa in the turbine and then heated from 7 to 8 by cooling down the cold storage. At point 8 the flow is merged with the parallel expanded portion, and from 8 to 9 and 9 to 1 heated with the recuperated heat from 3 to 4 and 4 to 5. By splitting the flow in point 4 and merging it in point 8, the amount of heat, transferred to the cold storage can be influenced.




Figure 6: Double recuperated sCO₂ Brayton Cycle as a heat pump with dual expansion (charging)

2.2.2 Cycle layout for discharging the (hot) storage

The layout for the discharging cycle can be seen in Figure 7. The upper and lower temperature are given through the terminal temperature difference of 8K between the working fluid and the hot storage during charging and discharging. The pressure ratio for this cycle is 3 as well (8 MPa/24 MPa). From state A to B the CO₂ is expanded, following recuperation B to C and C to D. At D the flow is split into a share which is cooled by discharging the cold storage (D to E) compressed (E to F) and recuperated (F to G) and a part being directly recompressed (D to G) before merged again in point G. Second heating with recuperation from G to H and with the heat from the hot storage from H to A.

DISCHARGE




Figure 7: Double recuperated and recompressed CO₂ Brayton Cycle (discharging)

2.2.3 Thermodynamic model

Both the charging and discharging cycle are illustrated in Figure 8. The nominal value of the low pressure is 8 MPa and therefore, close to the critical value. With the mentioned pressure ratio of 3, the nominal high pressure is 24 MPa. The efficiency of the discharging cycle of the PTES system η_{dc} is 34.9% (1), and the coefficient of performance of the heat pump (charging cycle) COP_{cc} of the PTES system is 1.11 (2). All CO₂ properties were retrieved from the REFPROP library [33].

$$\eta_{dc} = \frac{W_{net,dc}}{Q_{hotstor,dc}} = \frac{W_{exp,AB} - W_{comp,EF} - W_{comp,DG}}{Q_{HA}} \quad (1)$$

$$COP_{cc} = \frac{Q_{out,hotstor,cc}}{W_{net,cc}} = \frac{Q_{23}}{W_{comp,12} - W_{exp,67} - W_{exp,48}} \quad (2)$$

W_{net} denotes the cycle work (net cycle work), W_{exp} the expansion work and W_{comp} the compression work, while $Q_{hotstor}$ and $Q_{coldstor}$ describe the heat flux between cycle and hot and cold storage, respectively. The indices dc and cc are further describing the discharging or charging cycle, while the numbers (for the charging cycle) and letters (for the discharging cycle) describe specifically between which states the change takes place.

The round-trip efficiency η_{rt} of the proposed system is 38.9% and calculated with the net work ratio of charging and discharging cycle (3) or expressed differently with (1) and (2), by multiplying the COP of the heat pump and the efficiency of the heat engine (4).

$$\eta_{rt} = \frac{W_{net,dc}}{W_{net,cc}} = \frac{W_{exp,AB} - W_{comp,EF} - W_{comp,DG}}{W_{comp,12} - W_{exp,67} - W_{exp,48}} \quad (3)$$

$$\eta_{rt} = COP_{cc} \cdot \eta_{dc} \quad (4)$$

Table 1 lists the isentropic efficiencies of the turbomachinery, the work and the heat transfer rates within and over the boundaries of the cycle. The heat flux from the hot storage to the cycle during discharging is set by the power of the system $\dot{Q}_{\text{system}}=3.4\text{MW}$ and the efficiency of the discharging cycle (5). Further, the total mass flow rate \dot{m} is calculated with the enthalpy difference Δh of the storage (6).

$$\dot{Q}_{\text{hotstor}} = \frac{\dot{Q}_{\text{system}}}{\eta_{dc}} \quad (5)$$

$$\dot{m}_{dc} = \dot{Q}_{\text{hotstor}} \cdot \Delta h_{HA} \quad (6)$$

Around a mass flow ratio $\dot{m}_{dc,\text{maincomp}} / \dot{m}_{dc,\text{total}}$ of 0.8, the pinch-points within and between the charging and discharging cycle are in the desired range. Together with the enthalpy difference from D to E, the heat flux from the cycle to the cold storage fluid is calculated (7)

$$\dot{Q}_{\text{coldstor}} = \dot{m}_{dc,\text{maincomp}} \cdot \Delta h_{DE} \quad (7)$$

The mass flow on the storage side, between the two tanks, is calculated in the same manner but is a little bit lower due to the irreversibilities in the heat exchanger. The effectiveness of the heat exchangers is represented by a minimum pinch-point between storage side and cycle. The enthalpy difference on the storage side then results from the corresponding temperatures and the heat capacity of the storage material.

The minimum amount of stored heat (8) and storage material (9) for the hot and cold storage, respectively, can be found by multiplying the mass flow rate with the storage discharging time.

$$Q_{\text{stor}} = \dot{Q}_{\text{stor}} \cdot t_{\text{discharge}} \quad (8)$$

$$m_{\text{stor}} = \dot{m}_{\text{stor},dc} \cdot t_{\text{discharge}} \quad (9)$$

Five hours were chosen for the duration of charging and discharging as this is a typical wind farm production time [34].




Figure 8: T-s diagram of the charging and discharging of the proposed PTES with recuperated and recompressed $s\text{CO}_2$ Brayton Cycle

2.2.4 Sensitivity analysis and cycle optimisation

To get full use of the positive effects of CO₂ close to its critical pressure, a low pressure of 8 MPa was chosen. In Figure 9 can be seen, that the round-trip efficiency (η_{rt}) is higher with a higher pressure ratio of the discharging cycle and a lower pressure ratio in the charging cycle. However, pressure ratios lower than 3 in the charging cycle and lower than 4, with a discharging cycle pressure ratio of 4, as well as pressure ratios during discharging higher than 4, are not possible in this PTES system, because minimum temperature differences would get violated. The best combination is a pressure ratio of 3 for charging as well as discharging cycle.




Figure 9: Effect of the pressure ratios of charging and discharging cycle on the systems round-trip efficiency

A greater difference between the minimum and maximum temperature results in a higher round-trip efficiency, as to be expected. 10 °C are therefore suggested as the minimum temperature of the ideal PTES (t_{low}). The resulting minimum temperature of the cycle fluid for the heat rejection to ambient is 20 °C. Figure 10 shows that a raise in the cycles low temperature would cause a drastic drop in the systems round-trip efficiency. The PTES is further proposed with a maximum temperature of 500 °C (t_{high}), which is the limit for many materials which could be used for the storage containers, turbomachinery, and storage materials.




Figure 10: Effect of the low temperature on the systems round-trip efficiency (with a high temperature of 500°C)

It can be seen in Figure 11 that with temperatures greater 600 °C, nearly 50% efficiency can be achieved. At temperatures as high as this, storage materials like the solar salt mixture 40% NaNO₂ + 7% NaNO₃ + 53% KNO₃ with a working range between 142.24 °C (melting point) and 630.97 °C and a heat capacity of 1439 J/kgK, as proposed for CSP plants by Fernández et al., could be used [30].




Figure 11: Effect of the high temperature on the systems round-trip efficiency (with a low temperature of 10 °C)

The effect of the isentropic efficiencies of the compressors and expanders is also clear. In Figure 12, the change of the round-trip efficiency with the isentropic compressor efficiency (η_{comp}) is shown. Once with a constant isentropic expander efficiency of 0.9 ($\eta_{exp}=0.9$) and one time with equal efficiency for all turbomachinery ($\eta_{comp}=\eta_{exp}$). The latter is a very simplified approach because generally, the turbine efficiency can be expected to be much higher than the compressor's efficiency. It is though certain, that the isentropic efficiency of the turbomachinery has a great impact on the systems round-trip efficiency.




Figure 12: Effect of the isentropic efficiencies of compressor and expander on the systems round-trip efficiency

The last analysed impact are the temperature differences of the various heat exchangers of the system. A special focus was also on the pinch-point problem, as investigated for the optimised cycle in the next chapter (2.2.5). Generally, a smaller temperature difference, e.g. higher effectiveness of the heat exchangers, means a higher round-trip efficiency of the system, as to be seen in Figure 13. Besides the case, where the terminal temperature difference of the cold storage heat exchanger and the recuperator is each 5K ($tdT_{coldst} = 5$; $tdT_{recup} = 5$, yellow line), the temperature difference of the heat exchanger to the cold storage is shown on the x-axis. In the mentioned case ($tdT_{coldst} = 5$; $tdT_{recup} = 5$), it is the temperature difference of the hot storage heat exchanger (tdT_{hotst}) instead. All variations are displayed in this one diagram to allow an easy visual choice of the best combination. The temperature difference compared in the diagram is the terminal temperature difference at the two ends of the heat exchanger and is therefore not transferrable to the heat exchanger effectiveness, which is corresponding to the minimum temperature difference. The minimum temperature difference in the cycle-to-storage heat exchangers is sometimes lower than the temperature difference at

the ends of the heat exchanger, due to the severe pinch-point problem of sCO₂ (explained in 1.4 and visualised for the proposed cycle in 2.2.5).




Figure 13: Effect of the temperature differences at the heat exchanger ends on the systems round-trip efficiency

2.2.5 Heat exchanger analysis

The heat exchangers were checked on the pinch-point problem with the following analysis.

The hot storage heat exchanger is transferring heat between the CO₂ cycle and the solar salt of the storage. Figure 14 shows the charging and Figure 15 the discharging of the hot storage. The terminal temperature difference at the hot and cold end of the heat exchanger is 8K with a pinch-point of 7.5K (during charging mode). The necessary heat flux is 10 MJ/s. In total, an amount of 180GJ heat is stored in the solar salt, and 777 tons are required as a minimum to transfer the heat between the two-tank storage and the charging cycle. The molten salt has a working range between 221.04 °C (melting point) and 588.51 °C [30], with a mean heat capacity of 1518 J/kgK for the working temperature range of the storage [31].




Figure 14: Heat transfer from the (charging) cycle to the hot storage




Figure 15: Heat transfer from the hot storage to the (discharging) cycle

Between the CO₂ cycle and the thermal oil of the cold storage, a heat exchanger with pinch-point of 7.5K is used (Figs. 16, 17). The terminal temperature difference during discharge operation is 18K. The necessary heat flux is about 6.5 MJ/s. The heat capacity of the oil (THERMINOL66) is 1779 J/kgK [35] on average between the heat capacity at the minimum and maximum temperature of the heat transfer. The thermal oil is stable up to a maximum temperature of 380 °C. 117GJ of heat is stored in the thermal oil, also assuming no losses through self-discharging. This amount of heat, transferred between the given temperatures, equals 387 tons of thermal oil.




Figure 16: Heat transfer from the (charging) cycle to the cold storage




Figure 17: Heat transfer from the cold storage to the (discharging) cycle

The heat transfer in the recuperators is shown in Figure 18 to Figure 21. They have a pinch-point of 8K (in the high-temperature recuperator) or greater, and the terminal temperature difference is always higher than that, up to 43K.




Figure 18: Heat transfer in the high-temperature recuperator during charging




Figure 19: Heat transfer in the high-temperature recuperator during discharging




Figure 20: Heat transfer in the low-temperature recuperator during charging




Figure 21: Heat transfer in the low-temperature recuperator during discharging

3 Results and discussion

Table 1 summarises the results of the optimised thermodynamic model of this work. The efficiency of the discharging cycle of the PTES system η_{dc} is 34.9%, which is a little bit lower than the maximum efficiency, which can be theoretically reached without integration in a PTES system. Such a standard supercritical CO₂ Brayton cycle (without integration in a PTES system) can reach efficiencies of about 20.5%. If it is recuperated, 42.6% are possible. If it is recompressed, with double recuperation, it can be up to 45.0% [18]. The lower efficiency of the cycle while being integrated into a PTES system as its discharging cycle could be explained with the boundary conditions applying to the cycle through the attached storages, and due to the unavoidable rejection of heat to the environment, as well as simply through the desired optimum between high COP of the heat pump and high efficiency of the power cycle. The heat dissipation to the environment is necessary because of the inevitable irreversibilities (entropy generation) during charging and discharging. The coefficient of performance of the heat pump (charging cycle) COP_{cc} is 1.11, reaching a round-trip efficiency η_{rt} of 38.9% for the proposed system.

Table 1: Thermal model key inputs and results for the proposed PTES
Temperatures and pressures

Temperatures and pressures					
	t_{low}	16		[°C]	
	t_{high}	513		[°C]	
	$p_{nom,low}$	8		[MPa]	
	Pressure ratio	3		[-]	
Mass flow charging cycle			Mass flow discharging cycle		
$\dot{m}_{total,cc}$	56.9	[kg/s]	$\dot{m}_{total,dc}$	56.9	[kg/s]
Ratio \dot{m}	0.8	[-]	Ratio \dot{m}	0.4	[-]
Efficiency compressor and turbine					
	η_{comp}	0.9		[-]	
	η_{exp}	0.9		[-]	
Terminal temperature difference			Pinch Point		
Cold storage	18	[K]	7.5		[K]
Hot storage	8	[K]	7.4		[K]
Recuperation	8	[K]	8		[K]
Cycle efficiency					
	COP_{cc}	1.10		[-]	
	η_{dc}	0.342		[-]	
	$\eta_{overall}$	0.378		[-]	
Charging cycle			Discharging cycle		
$W_{comp,12}$	9294	[kW]	$W_{exp,AB}$	-7249	[kW]
$W_{exp,48}$	-272	[kW]	$W_{comp,EF}$	2530	[kW]
$W_{exp,67}$	-33	[kW]	$W_{exp,DG}$	1225	[kW]
$Q_{in,coldstor,78}$	6506	[kW]	$Q_{out_coldstor,DE}$	-6506	[kW]
$Q_{out,hotstor,23}$	-10000	[kW]	$Q_{in,hotstor,HA}$	10000	[kW]
$Q_{amb,56}$	-5495	[kW]	$Q_{recup,BC}$	-5664	[kW]
$Q_{recup,34}$	-14987	[kW]	$Q_{recup,GH}$	5664	[kW]
$Q_{recup,91}$	14987	[kW]	$Q_{recup,CD}$	-8876	[kW]
$Q_{recup,45}$	-1139	[kW]	$Q_{recup,FG}$	8876	[kW]
$Q_{recup,89}$	1139	[kW]			
$W_{net,cc}$	8989	[kW]	$W_{net,dc}$	-3494	[kW]

Pressure losses due to heat exchange were calculated for each heat exchanger, assuming the use of shell and tube heat exchangers. The power consumption of the pumps transporting the liquid

through the storages, as well as the power drain of the motor and generator, are neglected. However, if we assume $\eta_{generator} = 98\%$ and $\eta_{motor} = 98\%$, while the hot storage pump reduces the net work by $W_{hotstorPump} = 10.6kW$ and the cold storage pump by $W_{coldstorPump} = 15.9kW$, the round-trip efficiency reduces to about 37.6% as by formula (10).

$$\eta_{rt, reduced} = \frac{(W_{net, dc} - W_{storPump}) \cdot \eta_{gen}}{(W_{net, cc} - W_{storPump}) \cdot \eta_{mot}} \quad (10)$$

Formula (10) can also be written as in (11), with $W_{net, dc, reduced} = W_{net, dc} - W_{hotstorPump}$ and $W_{net, cc, reduced} = W_{net, cc} - W_{coldstorPump}$.

$$\eta_{rt, reduced} = \frac{W_{net, dc, reduced} \cdot \eta_{gen}}{W_{net, cc, reduced}} = \frac{W_{net, dc, reduced}}{W_{net, cc, reduced}} \cdot \eta_{gen} \cdot \eta_{mot} \quad (11)$$

This allows us to express the reduced round-trip efficiency with the reduced COP of the charging cycle and the reduced efficiency of the discharging cycle (12).

$$\eta_{rt, reduced} = COP_{cc, reduced} \cdot \eta_{dc, reduced} \cdot \eta_{gen} \cdot \eta_{mot} \quad (12).$$

The above-proposed cycle was optimised based on the sensitivity analysis introduced in 2.2.4. It is apparent that maximising the pressure ratio and the difference between the minimum and maximum temperature is improving not only the efficiency of the stand-alone cycle but also of the overall system and that although the COP of the heat pump is decreasing through these measures. If materials and cost wouldn't limit the upper temperature, this configuration could reach more than 50% round-trip efficiency at already 800 °C without any further changes to the original system. The lower temperature of the cycle is limited by the minimum temperature for heat exchange with the environment. Higher turbine efficiency is, of course, resulting in a higher round-trip efficiency as well, but limited by available technology. For today's available gas sCO₂ turbines, 90% efficiency might be possible, while for the compressor this theoretical value is most likely too high. If the compressor didn't reach such high efficiency, the round-trip efficiency would reduce drastically, and a realisation would most likely not be feasible, especially considering the complexity of the cycle. The heat exchanger effectiveness is in a more realistic range, and it is also clear that a higher efficiency (lower temperature difference) leads to better overall results.

Because the same pressure ratio was chosen for the charging and the discharging cycle, which is only possible through the recompression, the temperatures for storing and recuperating heat are relatively fixed and the possibilities for improving the cycle efficiency limited. This cycle configuration was, however, still chosen and analysed because it could allow the use of reciprocating devices and all heat exchangers for both, the heat pump and the power cycle. For a similar cycle, with slightly different pressure ratios, recompression would not be necessary, and a similar or higher round-trip efficiency could be reached.

4 Conclusion

CO₂ in its supercritical state can be used in a Brayton cycle as part of an energy storage system with hot and cold storage. The usual measures to enhance the CO₂ cycle performance are much harder to realise for a Carnot-Battery, due to its complexity. The upside of a recuperated sCO₂

Brayton cycle, the small turbomachinery, are being reduced by the space needed for the heat exchangers (heat exchanger areas around 70 to 100 m²). Therefore other cycle layouts, as well as other working mediums, should definitely be further investigated. Some heat needs to be released to ambient for energy balance within the system. This heat could be used in district heating or for an attached ORC as it is still at a temperature of about 130 °C. The modelled system provides a round-trip efficiency of 38.9%. For such a complex system, with recompression and double recuperation, this round-trip efficiency is comparably low. Simpler configurations of sCO₂ Brayton cycles might reach same or higher efficiencies, as also the analysis of McTigue et al. in 2019 suggests. They proposed a simple sCO₂ Brayton cycle, which could reach up to 60.4% with a low-temperature cycle (200 °C) and 78.4% with a high-temperature cycle (560 °C). They're mentioning that recuperation would be feasible due to the high-temperature difference between compression and expansion but didn't analyse it. This paper, however, shows that recuperation is difficult to implement and might actually not improve the round-trip efficiency of a sCO₂ Brayton PTES as expected, due to the limitations of the integration in the storage system.

Acknowledgements

This work was supported by the Grant Agency of the Czech Technical University in Prague, grant No. SGS20/116/OHK2/2T/12.

References

- [1] Gallo A. B. et al.: Energy storage in the energy transition context: A technology review. *Renewable and Sustainable Energy Reviews*, 65 2016, p. 800–822. doi:10.1016/j.rser.2016.07.028.
- [2] Pawson S.: GMAO MERRA: Modern Era Retrospective-Analysis for Research and Applications. Available at: <https://gmao.gsfc.nasa.gov/reanalysis/MERRA/>. Accessed March 5, 2020.
- [3] Söllch M.: Netzrelevante Daten. Available at: <https://www.main-donau-netz.de/header/veroeffentlichungen/strom/netzrelevante-daten.html>. Accessed June 19, 2016.
- [4] IEA, International Energy Agency: Technology Roadmap Energy storage 2014.
- [5] Wang X. et al.: Investigation of thermodynamic performances for two-stage recompression supercritical CO₂ Brayton cycle with high temperature thermal energy storage system. *Energy Conversion and Management*, 165 2018, p. 477–487. doi:10.1016/j.enconman.2018.03.068.
- [6] Valera-Medina A. et al.: Ammonia for power. *Progress in Energy and Combustion Science*, 69 2018, p. 63–102. doi:10.1016/j.peccs.2018.07.001.
- [7] Barmeier T.: Electric Thermal Energy Storage (ETES). Available at: https://windenergietage.de/wp-content/uploads/sites/2/2017/11/26WT0811_F11_1120_Dr_Barmeier.pdf. Accessed August 16, 2020.
- [8] Pumped thermal energy storage (Carnot Batteries): Overview and Prospects. 16.10.2019.
- [9] The Engineer: Team connects first grid-scale pumped heat energy storage system. Available at: <https://www.theengineer.co.uk/grid-scale-pumped-heat-energy-storage/>. Accessed August 13, 2020.
- [10] Howes J.: Concept and Development of a Pumped Heat Electricity Storage Device. *Proc. IEEE*, 100 (2) 2012, p. 493–503. doi:10.1109/JPROC.2011.2174529.
- [11] Siemens Gamesa Renewable Energy, S.A.: Start of construction in Hamburg-Altenwerder: Siemens Gamesa to install FES heat-storage for wind energy. Available at: <https://www.siemensgamesa.com/en-int/newsroom/2017/11/start-of-construction-in-hamburg-altenwerder>. Accessed August 13, 2020.
- [12] Siemens Gamesa Renewable Energy, S.A.: World first: Siemens Gamesa begins operation of its innovative electrothermal energy storage system. Available at: <https://www.siemensgamesa.com/en-int/newsroom/2019/06/190612-siemens-gamesa-inauguration-energy-system-thermal>. Accessed August 13, 2020.
- [13] Siemens Gamesa Renewable Energy, S.A.: Thermal energy storage with ETES I Siemens Gamesa. Available at: <https://www.siemensgamesa.com/en-int/products-and-services/hybrid-and-storage/thermal-energy-storage-with-etes>. Accessed August 13, 2020.
- [14] Dumont O. et al.: Carnot battery technology: A state-of-the-art review. *Journal of Energy Storage*, 32 2020, p. 101756. doi:10.1016/j.est.2020.101756.
- [15] Dumont O. (ed): First Experimental Results of a Thermally Integrated Carnot Battery Using a Reversible Heat Pump / Organic Rankine Cycle. 09.2020.
- [16] Morgan R. et al.: Liquid air energy storage – Analysis and first results from a pilot scale demonstration plant. *Applied Energy*, 137 2015, p. 845–853. doi:10.1016/j.apenergy.2014.07.109.
- [17] Highview Power: Plants: Pilot Plant. Available at: <https://highviewpower.com/plants/>. Accessed November 26, 2020.
- [18] Brun K. et al.: Fundamentals and applications of supercritical carbon dioxide (sCO₂) based power cycles. Duxford, United Kingdom: Woodhead Publishing an imprint of Elsevier, 2017.

- [19] Weihe S. et al.: Untersuchung zur Evaluierung von Forschungspotentialen hinsichtlich Prozessen, Komponenten und Werkstoffen von trans- und superkritischen CO₂-Anwendungen 2016.
- [20] Morandin M. et al. (eds): Thermo-electrical energy storage: a new type of large scale energy storage based on thermodynamic cycles. 2011.
- [21] Mercangöz M. et al.: Electrothermal energy storage with transcritical CO₂ cycles. *Energy*, 45 (1) 2012, p. 407–415. doi:10.1016/j.energy.2012.03.013.
- [22] Kim Y. M. et al.: Transcritical or supercritical CO₂ cycles using both low- and high-temperature heat sources. *Energy*, 43 (1) 2012, p. 402–415. doi:10.1016/j.energy.2012.03.076.
- [23] Ayachi F. et al.: Thermo-Electric Energy Storage involving CO₂ transcritical cycles and ground heat storage. *Applied Thermal Engineering*, 108 2016, p. 1418–1428. doi:10.1016/j.applthermaleng.2016.07.063.
- [24] Steinmann, Jockenhöfer, Bauer: Thermodynamic Analysis of High-Temperature Carnot Battery Concepts. *Energy Technol.*, 140 2019. doi:10.1002/ente.201900895.
- [25] McTigue J. et al. (eds): Pumped Thermal Electricity Storage with Supercritical CO₂ Cycles and Solar Heat Input. 2019.
- [26] Kim Y.-M. et al.: Isothermal transcritical CO₂ cycles with TES (thermal energy storage) for electricity storage. *Energy*, 49 2013, p. 484–501. doi:10.1016/j.energy.2012.09.057.
- [27] Morandin M. et al.: Thermo-economic design optimization of a thermo-electric energy storage system based on transcritical CO₂ cycles. *Energy*, 58 2013, p. 571–587. doi:10.1016/j.energy.2013.05.038.
- [28] Dostal V. et al.: A supercritical carbon dioxide cycle for next generation nuclear reactors. 2004.
- [29] Angelino G.: Carbon Dioxide Condensation Cycles For Power Production. *Journal of Engineering for Power*, 90 (3) 1968, p. 287–295. doi:10.1115/1.3609190.
- [30] Fernández A. G. et al.: Thermal characterization of HITEC molten salt for energy storage in solar linear concentrated technology. *J Therm Anal Calorim*, 122 (1) 2015, p. 3–9. doi:10.1007/s10973-015-4715-9.
- [31] SQM International N.V.: Thermo-solar Salts.
- [32] Solutia: THERMINOL 66: High Performance Highly Stable Heat Transfer Fluid.
- [33] Lemmon E.: NIST Reference Fluid Thermodynamic and Transport Properties Database: Version 9.0, NIST Standard Reference Database 23. National Institute of Standards and Technology, 1989.
- [34] Attonaty K. et al.: Thermodynamic analysis of a 200 MWh electricity storage system based on high temperature thermal energy storage. *Energy*, 172 2019, p. 1132–1143. doi:10.1016/j.energy.2019.01.153.
- [35] Solutia: THERMINOL 66: High Performance Highly Stable Heat Transfer Fluid.