

An Open-Source Virtual Testbed for a Real Net-Zero Energy Community

Sen Huang ^a, Jing Wang ^b, Yangyang Fu ^b, Wangda Zuo ^{b,c*}, Kathryn Hinkelman ^b,
Raymond M. Kaiser ^d, Dong He ^e, Draguna Vrabie ^a

^a *Pacific Northwest National Laboratory, 902 Battelle Boulevard, WA 99354, U.S.A.*

^b *University of Colorado Boulder, 1111 Engineering Dr, Boulder, CO 80309, U.S.A.*

^c *National Renewable Energy Laboratory, Golden, CO 80401 U.S.A.*

^d *Amzur Technologies, Inc., Tampa, FL 33607, U.S.A.*

^e *School of Automation, Chongqing University, Chongqing, 400044, China*

* *Wangda.Zuo@colorado.edu*

An Open-Source Virtual Testbed for a Real Net-Zero Energy Community

Abstract: Net-zero energy communities (NZECs) are critical to assuring the sustainability and resilience of modernized power systems. System modeling helps overcome technical challenges in designing and operating NZECs. In this paper, we present an open-source NZEC virtual testbed in Modelica based on a real NZEC in Florida, USA. This testbed consists of two sets of models: (1) higher-fidelity physics-based models that consider the interaction between subsystems of the studied NZEC and capture fast dynamics, and (2) lower-fidelity data-driven models that require fewer resources to establish and/or run. All models are validated against measurements from this real NZEC. In addition, this testbed includes a simulation framework that streamlines the processes for simulation and thus allows the use of developed models to form a virtual testbed. To demonstrate the usage of the virtual testbed, a case study is conducted where a building-to-grid integration control is evaluated via simulation. The evaluation results suggest that the tested control significantly smooths the power draw of the studied community and does not sacrifice thermal comfort to a great extent.

Keywords: Net-Zero Energy Communities, Virtual Testbed, Modelica, Building-to-Grid Integration

1 Introduction

According to Peterson et al. (2015), “A net-zero energy community is an energy-efficient community where, on a source energy basis, the actual annual delivered energy is less than or equal to the on-site renewable exported energy.” A net-zero energy community (NZEC) usually consists of energy generation from renewable sources (e.g., solar, wind); energy distribution through electric- and thermal-distribution systems; energy usage by space conditioning, lighting, and a wide range of miscellaneous loads; energy storage by electric cars and other devices; and interaction with the electric power system. Achieving net-zero energy at the end-use side is critical to realizing the sustainability and resilience of modernized power systems (Hachem-Vermette et al. 2018). Traditionally, net-zero energy is mainly studied at the building level because buildings are major consumers of electricity (Fabrizio et al. 2014; Moore 2014; Lu et al. 2015). However, NZECs provide significant economic and environmental advantages over net-zero energy buildings, such as greater flexibility to accommodate large energy infrastructures and richer load diversity to reduce the design capacity of energy systems (Managan 2012; Athienitis et al. 2015; Kallushi et al. 2012).

Because of those advantages, various efforts in designing and building NZECs have been reported, including Gaiser et al. (2014); Lu et al. (2014); Marique et al. (2014); De Coninck et al. (2014); Hachem-Vermette et al. (2015); Kilkis (2015). One example is the West Village, California, USA. (Gaiser et al. 2014). The West Village is an all-electric campus that consists of solar photovoltaic (PV) arrays, a bio-digester generator, and heat pumps with backup electric heaters. The PV arrays produce the main power, the generator provides additional electricity supply, and the heat pumps generate the domestic hot water (DHW). Although the West Village is intended to achieve the NZEC goal, according to its annual report (UC Davis West Village

2014), its renewable energy generation only covered 82% of its energy demand during 2013–2014. Another example is the Historic Green Village (HGV) on Anna Maria Island, Florida, USA. The HGV is a small NZEC consisting of five mixed-use commercial buildings (retail, including a bakery and general store; office; and residences). The community achieved its net-zero energy goal in 2014. Section 2 of this paper provides a detailed introduction to the HGV.

Despite these encouraging applications, designing and operating an NZEC is challenging, primarily because of the coupling relationships between subsystems within NZECs. An NZEC is a complex combination of multiple subsystems, usually including renewable energy generation; heating, ventilation, and air conditioning (HVAC); refrigeration; DHW; and other miscellaneous equipment. These subsystems interact with one another. For example, to reduce the energy used by the DHW system, the waste heat from the HVAC system is used to preheat the water supply for the DHW system (Miranda et al. 2015). Thus, when evaluating the performance of the DHW system, it is necessary to simultaneously consider the HVAC operations. In addition, an NZEC typically needs to achieve multiple objectives, such as reducing emissions, minimizing demand charges, and accommodating grid supply interruptions. These objectives pose challenges to the design process because a multi-objective optimization needs to be solved to make trade-offs among these requirements, especially when sizing each subsystem to assure economic feasibility. These objectives also complicate the operation process. For example, to minimize demand charges with energy storage capacity, research suggests that building system control parameters should be continuously updated according to the operation conditions (Muruganantham et al. 2017).

To support the design and operation of NZECs, system modeling is widely used in the literature to better understand the characteristics of NZECs, as summarized in Table 1. However,

gaps are also identified in existing system modeling. For example, the interaction between systems from different domains tends to be ignored. Because an NZEC includes heterogeneous, overlapping subsystems that span multiple, distinct physical domains, it is necessary to model all the domains as a whole to understand their interactions and interdependencies (Wetter 2011). In addition, fast dynamics are sometimes excluded from the modeling. Given the importance of controls to the system operation, modeling of the transient control processes is indispensable (Wetter 2011). Therefore, to better evaluate how the above factors influence the design and operation of NZECs, an accurate representation of the fast dynamics is necessary. Furthermore, the models developed in those studies are not validated against real-world data, limiting the usability of those models.

Table 1. Review of current research for NZEC

Studied Community	Modeling Scope	Cross-discipline Modeling	Fast Dynamic Modeling?
A dummy community, Belgium (De Coninck et al. 2014)	DHW system (Modelica [Modelica Association])	Only models for the DHW system	Yes
West Village, California, USA (Gaiser et al. 2014)	- Building system (eQuest) - PV system (PolySun and SAM) - DHW system (Building America Report)	Separate models for building, electrical, and DHW systems	No
Qingshan Lake District in Hangzhou, China (Lu et al. 2014)	- Combined heat and power system - Small-scale wind turbine system - Solar photovoltaic system - Solar thermal heater system (MATLAB [MathWorks])	Coupled models for building and electrical systems	No
A dense neighborhood and a low-density suburban neighborhood in Neupré, Belgium (Marique et al. 2014)	- Space heating, cooling, and ventilation system (in-house code) - Appliances, cooking, and DHW system (estimated based on the number of inhabitants in the building) - On-site energy production system (Townscope)	Separate models for building and electrical systems	No
A dummy community, Calgary, Alberta, Canada (Hachem-Vermette et al. 2015)	- DHW, heating/cooling, PV system (TRNSYS) - Lighting and equipment system (EnergyPlus)	Coupled models for thermal and electrical systems	Yes

A village in Graubünden, Switzerland (Orehounig et al. 2014)	Building System (EnergyPlus)	Only models for building system	Yes
---	------------------------------	------------------------------------	-----

In this paper, we present an open-source NZEC virtual testbed in Modelica based on a real NZEC, the HGV. This testbed consists of two sets of models: (1) higher-fidelity physics-based models that consider the interaction between subsystems of the studied NZEC and capture fast dynamics, and (2) lower-fidelity data-driven models that require fewer resources to establish and/or run. All models are validated against measurements from this real NZEC. The open-source NZEC testbed has been publicly released at <https://bitbucket.org/sbslab-zuo/scc-nzec>. In addition, this testbed includes a simulation framework that streamlines the simulation processes and thus allows the use of developed models to form a virtual testbed. To demonstrate the usage of the virtual testbed, a case study is conducted where a building-to-grid integration control is evaluated via simulation.

This paper contributes to the literature as follows. First, we develop and validate an open-source NZEC virtual testbed. This testbed can meet different requirements for designing and operating NZECs and provides great flexibility in terms of model selection and integration for simulation and optimization. Second, we performed a comprehensive evaluation on a demand-response control strategy with this virtual testbed. The evaluation results can be used to determine the feasibility of adapting the studied control and further improve the control performance.

The rest of the paper is organized as follows. First, we provide a detailed introduction to the HGV. We then discuss how we realize the virtual testbed with different models and a software framework. After that, we present the evaluation of a building-to-grid integration control with the proposed virtual testbed. Finally, we present our conclusions and discuss future work.

2 Historic Green Village

2.1 Overview

Located on Anna Maria Island, Florida, USA, the HGV is a small community (2,776 m²) that consists of two retail stores, one commercial office, and two residences, as shown in Figure 1. The climate of Anna Maria Island is categorized as Zone 2A, which is hot and humid (ASHRAE 2007). The average annual solar radiation is around 19.33 MW/m²/day (Wilcox 2012), providing a significant resource for renewable energy. In addition, by employing aggressive measures in energy efficiency (e.g., cool roofs, Low-E glass, extra insulation, and waste heat recovery from water-source heat pumps), the HGV achieved its net-zero energy goal in 2014 after operating for two and a half years (beginning in June of 2011), as shown in Figure 2.



Figure 1. HGV on Anna Maria Island, FL.

The HGV has three renewable energy systems: a solar PV electric generation subsystem, a solar thermal DHW subsystem, and a ground source heat pump (GSHP) subsystem. The solar PV system generates electricity during daylight hours. Excess generation is sold to the utility provider and purchased from the utility as needed. The GSHP subsystem provides both cooling and heating to all buildings in the community. During cooling-dominated periods, the GSHPs

also supplement the DHW requirements. The solar thermal DHW subsystem provides domestic water. Excess hot water generated during the day is stored in a tank. The building subsystem represents the energy usage of the five buildings for different activities. All five subsystems are interconnected. For instance, the buildings are conditioned by heat pumps, which are powered by electricity from either the PV panels or the utility.




Figure 2. The electricity generation and demand of the HGV.

2.2 Energy Subsystems

2.2.1 Solar PV Generation

The solar PV system generates on-site electric power. To achieve net-zero energy, PV panels are installed on building roofs, two solar carports, and a neighboring warehouse building. The configuration of the PV system is shown in Table 2. In total, the PV system is 612.09 m² with a total peak capacity of 60 kW.

Table 2. PV system specifications.

Building Name	PV Group	PV Panel Area [m ²]	Array Tilt [°]	Array Azimuth [°]	Rated Module Efficiency [%]	Rated DC/AC Conversion
---------------	----------	---------------------------------	----------------	-------------------	-----------------------------	------------------------

						Efficiency
Thelma	A	15.36	30.0	-45	14.9	0.8
		15.36	15.0	45	14.9	0.8
Rosedale	B	46.08	5	-45	14.9	0.8
		38.40	5	-45	14.9	0.8
		25.60	30	45	14.9	0.8
Sears	C	51.20	20.0	-45	14.9	0.8
Pickle Fish	D	29.34	5.0	-45	16.0	0.8
Pillsbury	E	17.93	10.0	45	16.0	0.8
		19.56	5.0	45	16.0	0.8
		13.04	5.0	-45	16.0%	0.8
		9.78	10.0	45	16.0	0.8
North Carport	NC	84.48	5.0	-45	14.9	0.8
South Carport	SC	96.00	5.0	-45	14.9	0.8
Warehouse	W	149.96	5.0	45	16.0	0.8

AC is alternating current; DC is direct current.

2.2.2 Utility-provided Power and Buildings

The utility subsystem is treated as a virtual battery. If the solar panels meet the electricity load of the NZEC, the excess electricity “charges” the utility subsystem by feeding the electricity to the power grid; if on-site production is insufficient to meet the HGV load, the utility subsystem “discharges” the electricity by drawing electricity from the power grid to the HGV, as shown in Figure 2. By having the utility as a virtual battery with inexhaustible capacity, one avoids the high cost of installing on-site energy storage systems. In addition, each building in the HGV is equipped with miscellaneous electric equipment, including lighting, refrigeration, food preparation (dishwasher, coffee maker, and dryer), hot water, and miscellaneous equipment and plug loads.




Figure 3. Schematic of the utility distribution system.

2.2.4 Ground Source Heat Pump

As shown in Figure 4, the GSHP subsystem consists of a water loop that connects nine water-to-air heat pumps in the buildings, five refrigerator racks, and a heat exchanger linked to a ground source geothermal system. The nine heat pumps provide cooling and heating to the buildings. The heat pumps' cooling capacities vary from 5.4 kW to 17.3 kW. The total cooling capacity of the nine heat pumps is 87.3 kW. Depending on the building cooling/heating loads, some buildings may have two or three heat pumps. On the waterside, each heat pump has two dedicated circulating water pumps. This water loop also supplies direct cooling for the five refrigeration units.

The GSHP subsystem consists of one sink well and one source well. Those wells penetrate a layer of limestone rock at 137 m (450 ft) deep, where the underground water has a constant temperature of 26.7 °C (80 °F). A variable speed well pump controls the flow rate of the extracted groundwater through the heat exchanger to maintain the temperature of the outlet water

from the heat exchanger in the water loop. In cooling mode, when the outlet water temperature exceeds 28.3 °C (83 °F), the well pump speeds up from 20% to 100% of the maximum speed to reduce the water temperature. In heating mode, when the outlet water temperature is below 23.9 °C (75 °F), the well pump speeds up from 20% to 100% of the maximum speed to increase the water temperature.




Figure 4. Schematic of a GSHP subsystem in the HGV.

2.2.5 Domestic Hot Water

The DHW system serves one retail store (Pickle Fish; Table 2). In this system, the makeup water from the municipal water is preheated by a solar collector to around 37.8 °C (100 °F) and is then stored in a tank with a capacity of 0.6 m³ (120 gallons). When makeup water is needed, the water is pumped to another tank where heat is recovered from the two GSHPs (HP8 and HP9) and absorbed by the makeup water. When the recovered heat is not available, an electric backup heater is activated to provide more heat.

3 System Modeling

3.1 Model Architecture

As mentioned above, the HGV contains different subsystems. We package the models within each subsystem into one subsystem model, while the energy/mass/information connections between different subsystems are then modeled with corresponding information buses. The decomposition of the HGV results in a model architecture, as shown in Figure 5. This architecture has three advantages: (1) subsystem models can be easily isolated for calibration or testing purposes; (2) connections between subsystems can be managed in a flexible and scalable way; and (3) each subsystem can be assigned a dedicated solver so that each subsystem can have unique simulation time steps to capture internal dynamics at lower computational costs.




Figure 5. The exchange and communication of different subsystem models in the HGV.

3.2 Model Methods

It is generally preferable to have high-fidelity physics-based models when detailed information of the studied systems is required. Having such models, however, may not always be practical.

Physics-based models require a detailed understanding of the studied system and impose a significant computational demand (Braun et al. 2002). In a real-world setting, the necessary conditions may be difficult to meet. For example, occupancy has a significant influence on building energy demand and thus should be considered in load modeling. However, the stochastic nature of occupancy in time and space (Feng et al. 2015) makes it difficult to model accurately. Computational fluid dynamics models are effective in modeling thermal comfort levels but are very computationally intensive. This limits their applicability to real-world adaptive controls (Zuo et al. 2010). In addition, physics-based models may require detailed operating data to calibrate the parameters. Such data may be inaccessible due to a lack of meters or sensors. The data-driven models, on the other hand, are often more suitable when resources are limited. They can be built without any information regarding physics. They are usually computationally efficient because they often contain only linear equations. Further, they can be developed with limited types of data, although the accuracy of the models is directly related to the number of training data points available (Braun et al. 2002).

Given the pros and cons of physics-based models and data-driven models, we believe it is desirable to have a hybrid model that includes both physics-based models and data-driven models. The physics-based models can be used to model the most critical subsystems, or those with more known and detailed operating data, when computational resources permit. The data-driven models can be used to model systems that lack either a good physics-based model or detailed operating data, or where computational performance is a limiting factor. In this study, we used Modelica to implement the physics-based models. Modelica is an equation-based, object-oriented modeling language for dynamic systems. Examples of building-related modeling with Modelica include the modeling of building envelopes, a data center cooling system, a

single-zone cooling system, a DHW system, and chiller plants (Nouidui et al. 2012; Zuo et al. 2014; Huang, Malara, et al. 2016; Zuo et al. 2016).

3.3 System Models

Applying the model structure and the model methods from the previous two sections, we created models for the entire HGV in a hierarchical fashion. Figure 6 shows the top-level model, which mainly includes the following five subsystem models: renewable energy generation, grid, buildings, water-source heat pumps, and information bus. The top-level model is implemented in Modelica. The data and signals can be exchanged using the bus connectors that exist in Modelica. The following sections discuss the lower-level models in more detail.




Figure 6. Diagram of top-level models for the HGV.

(1) Renewable Energy Generation

Figure 7 shows the model diagram for the entire PV subsystem, which is composed of models for the eight arrays shown in Table 2. For each PV array, we developed a dedicated model for each array. The direct current (DC) output of the array is converted to alternating current (AC) through an inverter. The AC output is aggregated to one output port terminal to connect with other subsystem models. In addition, the PV energy production information is transferred to other subsystem models for further control purposes via the data bus, which is an expandable connector for data communication.




Figure 7. Diagram of Modelica models for the PV subsystem.

We create both a physics-based model and a data-driven model for the PV array. For the physics-based model, we used the *PVSimpleOriented* model in the Modelica Buildings Library (Wetter et

al. 2014). This model calculates the electrical power, P , generated by the PV panel using the following equation:

$$P = Af_{act}\eta G\eta_{DCAC}, \quad (1)$$

where A is the area of each PV panel, f_{act} is the fraction of the aperture area, η is the PV panel efficiency, G is the total solar irradiation, and η_{DCAC} is the efficiency of the conversion between DC and AC. In this model, G is the sum of direct and diffuse irradiation and is calculated by:

$$G = G_{Dif} + G_{Dir}, \quad (2)$$

where G_{Dif} and G_{Dir} are the sums of the diffuse and direct irradiation on a tilted surface, respectively.

$$G_{Dir} = \text{Max}(0, \cos(\text{incAng})HDirNor), \quad (3)$$

where incAng is the solar incidence angle on the surface and $HDirNor$ is the direct normal radiation.

$$G_{Dif} = G_{SkyDif} + G_{GroDif}, \quad (4)$$

where G_{SkyDif} and G_{GroDif} are the hemispherical diffuse solar irradiation on a tilted surface from the sky and hemispherical diffuse solar irradiation on a tilted surface from the ground, respectively.

For the data-driven model, we employed a forward backpropagation neural network model (Hecht-Nielsen 1989). As shown in Figure 8, there are four neurons (x_1, x_2, x_3, x_4) and one output layer with one output (y_1) in this neural network model. In addition, there is also one hidden layer with 12 neurons. For the PV panel modeling, we select x_1, x_2, x_3 , and x_4 as the direct normal radiation, diffuse horizontal solar radiation, global horizontal radiation, and the power generation of the PV panel a half-hour before the current time, respectively. Variable y_1 is the power generation of the PV panel at the studied time. This neural network model is implemented with MATLAB. To enable data exchange between MATLAB and the Modelica

environment during runtime, we utilize the Python interface in the Modelica Buildings Library and the MATLAB Engine API for Python (Mathworks 2017).




Figure 8. The structure of the neural network model.

(2) Power Grid

In this research, we used the *Electrical.AC.OnePhase.Sources.Grid* model in the Modelica Buildings Library to build the physics-based model for the utility-supplied power. The input for this model is a fixed voltage signal, while the output will be the power supplied by the utility at a point of common coupling (PCC) to the HGV electric distribution system. We define a convention that the power is positive if real power is consumed from the grid and negative if it is flowing out of the PCC. We did not build a data-driven model for the utility distribution system because we do not have sufficient historical data to characterize the distribution system behavior.

(3) Buildings

The equipment in the HGV can generally be categorized as having either easy load pattern recognition or difficult load pattern recognition. As an example of an easily recognizable pattern,

Figure 9 shows the load profile of the lighting equipment in a retail building for 20 days. We can see that all the days share the same pattern: from 9:00 to 17:00, the lighting load is maintained around 300 W, and the rest of time, the lighting is close to zero. From this, we can easily build simple data-driven models for such equipment. For an example of a load pattern that is difficult to understand, Figure 10 shows the load profile of fridges in a restaurant building for 20 days. We can see that the fridge power load changes randomly, mainly due to the cycling control of the compressors. For simplification, we assume the loads for this equipment are always constant.




Figure 9. Electricity load profiles of lighting equipment in a retail building (each line represents one day of data).




Figure 10. Electricity load profiles of fridges in a restaurant building (each line represents one day of data).

(4) GSHP Subsystem

The GSHP subsystem is the major energy load type in the HGV. We create both physics-based and data-driven models for the GSHP subsystem. When creating the physics-based model, we respect the real topology of the GSHP subsystem, which results in a top-level model for the GSHP subsystem, shown in Figure 11. In this top-level model, the major components include a weather bus, internal heat gain, a condenser water loop, a heat recovery loop, zone controllers, and GSHPs. The weather bus component provides external disturbances, while the internal heat gain component estimates internal disturbances in the GSHP operation. The condenser water loop component and the heat recovery loop component are modeled as constant flow loops with constant speed pumps. In addition, the GSHP module contains sub-models, as shown in Figure 12, including one heat pump model and the thermal zone model. Both models are from the

Modelica Buildings Library; readers can find more information in (Wetter et al. 2014).

Specifically, the thermal zone model calculates the power of each GSHP using

$$P_{hp} = P_{hp,nom} PLR \cdot COP_{nom} / \left(\frac{T_{eva}}{T_{con} - T_{eva}} \varepsilon_{carnot} \varepsilon_{PLR}(PLR) \right), \quad (5)$$

where $P_{ch,nom}$ is the nominal power of the GSHP, PLR is the partial load ratio (the ratio of the cooling load handled by the GSHP to its nominal capacity), COP_{nom} is the GSHP's coefficient of performance at the nominal condition, and T_{eva} and T_{con} are the temperatures in the evaporator and condenser sides of the GSHP, respectively. The ε_{carnot} is the Carnot effectiveness (assumed to be constant), and ε_{PLR} is the operation effectiveness at partial loads, which is a function of the PLR :

$$\varepsilon_{PLR}(PLR) = c_1 + c_2 PLR + c_3 PLR^2 + (1 - c_1 - c_2 - c_3) PLR^3, \quad (6)$$

where c_1, c_2, c_3 are constant coefficients to mimic the internal capacity control of each GSHP.




Figure 11. Diagram of Modelica models for the GSHP subsystem.




Figure 12. Diagram of Modelica models for the GSHP module.

In addition, we employ a neural network model to establish a data-driven model for the GSHP subsystem. The structure of the neural network model for the geothermal subsystem is the same as that for the PV subsystem, as shown in Figure 8. However, x_1 , x_2 , x_3 , and x_4 are different because they represent the day type, the hour index in one day, the outdoor dry bulb temperature, and the power of the heat pump in the previous hour, respectively. Table 3 shows the definitions of each day type. For more details regarding day type, refer to (Huang, Zuo, et al. 2016). We do not have a dedicated power meter for HP 4, HP 5, HP 8, and HP 9; instead, there is one aggregated meter for HP 4 and HP 5 and one aggregated meter for HP 8 and HP 9. Thus, we must model HP 4 and HP 5 as one heat pump and HP 8 and HP 9 as another heat pump.

Table 3. Day type categories in the HGV.

Index	Day Category Name	Description
1	Weekday in Peak Season	Weekday from December 15 to May 14
2	Weekend in Peak Season	Weekend from December 15 to May 14
3	Weekday in Non-Peak Season	Weekday from May 15 to December 14
4	Weekend in Non-Peak Season	Weekend from May 15 to December 14

(5) DHW Subsystem

We create only a physics-based model for the DHW subsystem due to the lack of operation data for developing a data-driven model. We established the physics-based model based on the design specification and engineering judgment of the DHW system. Figure 13 shows the top-level model for the DHW subsystem. The major components include the city water module, the solar collector, the water usage profile, and the backup heater. We build the models for the above modules again with the Modelica Buildings Library. For simplicity, we assume water usage, pump power, and heater efficiency are constant.




Figure 13. Diagram of Modelica models for the DHW subsystem.

3.4 Validation

We validate the developed model with data from the HGV. For data acquisition, we installed

web servers with 12–24 current transformers in each electric service panel. This allows us to log circuit-level power demand and generation and upload data to a cloud-based application that can aggregate the data by building and load type (HVAC, lighting, refrigeration, etc.). Solar radiation data was obtained from an authoritative source, the National Solar Radiation Database (NSRDB) (The Renewable Resource Data Center), at a resolution of 4 km by 4 km using geostationary satellites. When validating the models, we use the developed system models to predict the power for a test period of 1 week (Aug 25–31, 2014) for each subsystem. Then, we demonstrate the power prediction results at the community level. For the DHW system, no validation is conducted due to the lack of historical data.

3.4.1 Renewable Energy Generation

Figure 14 shows the aggregated power results for the PV subsystem, which demonstrate that the data-driven models are quite close to the measurements, except occasionally near noon. The predictions from the physics-based models are significantly lower than the measurements, and the deviation can be up to 17%.




Figure 14. Comparison of the predicted and measured aggregated PV power generation.

3.4.2 Building System

As shown in Figure 15, although the prediction can capture the general pattern of the measurement, relatively large deviations exist. This means that the simple method we used to model the equipment in the second category may be oversimplified.




Figure 15. Comparison of the predicted and measured miscellaneous electric equipment power at the aggregated level.

3.4.3 GSHP

Figure 16 shows the aggregated power results for the GSHP subsystem. In general, the predictions by both the physics-based models and the data-driven models match the measurement pattern well. However, for some time intervals, there are relatively large deviations in both models. These deviations are up to 18% for the data-driven model and up to 30% for the physics-based models.




Figure 16. Comparison of the predicted and measured aggregated heat pump power.

3.4.4 Community

Figure 17 shows the aggregated power results for the entire community from the data-driven models, but the pump energy consumption in the DHW subsystem is not included in these results. Negative power means that power generation exceeds power demand, while positive power means that power generation is insufficient to meet power demand. At the community level, we can see that the prediction closely matches the measurement. It is worth noting that the aggregated power for the entire community turns out to be a typical “duck curve,” i.e., after times of high solar generation, the grid must rapidly increase power output around sunset to compensate for the drop in solar generation. The “duck curve” may cause load-supply balance

issues (Denholm et al. 2015). An energy storage system or a peak load shaving or shifting strategy can resolve this issue.




Figure 17. Comparison of the predicted and measured aggregated power for the HGV.

4 Simulation Framework

As shown in Figure 18, this framework is designed to facilitate the use of the models and is composed of four modules: pre-processing, modeling, optimization, and post-processing. The pre-processing module processes the input data for the virtual testbed. For instance, gaps may exist during the data collection process. In this case, the pre-processing module is used to fill the gaps through interpolation to provide continuous input for the dynamic simulation. The modeling

module simulates all the models developed for the studied NZEC, while the optimization module performs model-based optimizations using the input data as well as the objective functions.

Various optimization engines have been integrated into this virtual testbed, such as the Python-based pyOpt framework (Perez et al. 2012), GenOpt (Wetter 2004), and the MATLAB Optimization Toolbox. The post-processing module processes the results from simulation and optimization based on predefined metrics.

This framework automates the process of identifying the optimal design and the optimal operation scheme for the HGV. Specifically, in the design phase, architects and engineers can compare the simulation results of various designs to further enhance the design. In the operation phase, facility managers can improve the operation by altering the optimal control variables or by changing demand-side management strategies.




Figure 18. Simulation framework.

5 Case Study

In this case study, we demonstrate the use of the developed models and the simulation framework as a virtual testbed for evaluating a building-to-grid integration method that adjusts the thermostat settings to smooth the power draw of NZECs from the power grid.

5.1 Testing Control Method

The control method smooths the power draw of NZECs from the grid, as defined in:

$$J = \operatorname{argmin} \left(\sum_{i=1}^n |P_{D,i} - P_{G,i}| \right), \quad (7)$$

where $P_{D,i}$ is the power demand of NZECs and $P_{G,i}$ is the power generation of NZECs at time step i . A smooth power draw helps the power grid achieve a balance between power supply and demand.

As illustrated in Figure 19, this control method is a distributed control strategy and contains both campus-level control and building-level controls. The campus-level control takes the measured power draw as an input and generates a price of electricity at time step i , by:

$$\lambda_i = \lambda_0 + \Delta\lambda \left(k(P_{D,i} - P_{G,i}) + I \left(\sum_{j=1}^i (P_{D,j} - P_{G,j}) \right) \right), \quad (8)$$

where λ_0 is the base price, $\Delta\lambda$ is the maximum changing range for the price, and k and I are parameters. Equation (2) is essentially a proportional-integral control that uses the measured power draw as feedback to adjust the price signal.




Figure 19. Proposed control method.

The building-level control establishes mapping between the electricity price and the thermostat setpoint, as illustrated in Figure 20. Only the cooling mode is considered for simplicity. We can see that, in general, the thermostat setpoint is proportional to the electricity price. However, the thermostat setpoint is only allowed to vary in a range of $[T_{set,0} - k\Delta T, T_{set,0} + k\Delta T]$, where $T_{set,0}$ is the nominal setpoint and ΔT is the maximum deviation from the nominal setpoint. Additionally, for each building, the parameter k is determined based on occupant preference. If the occupants highly value thermal comfort, then k approaches the minimum value of 0; otherwise, k is closer to the maximum value of 1.




Figure 20. Mapping between the electricity price and thermostat setpoint.

5.2 Deployment of Testing Control Method in the Virtual Testbed

To evaluate the proposed control method, we deploy it in the virtual testbed. Specifically, the control method is implemented in Python and coupled with the virtual testbed via the socket connection. The virtual testbed periodically (every 5 minutes) sends the power information to the proposed control method, which then returns the setpoint. Additionally, as shown in Figure 17, power generation is usually much larger than power demand in the HGV, meaning the PV subsystem is oversized and making it very difficult to achieve a smooth power draw. To provide a fair evaluation, we ignore the PV groups E, NC, SC, and W to reduce the capacity of PV generation. Furthermore, we employ the physics-based models of the renewable energy generation, power grid, GSHP, and DHW subsystems and the data-driven models for other subsystems in the evaluation. The simulation period is set to be a typical summer day, July 27, 2014, and measured weather data is used as the major input. The k value for each GSHP is randomly selected between 0.6 and 0.9 to reflect diversity in occupant preferences.

5.3 Results and Discussion

Figure 21 illustrates the power draw of the HGV with and without the control method. We can see that the power draw varies dramatically throughout the testing day in the baseline scenario. The power draw reaches its minimum value of -7 kW around 11:00 and reaches its maximum value of 15 kW around 19:00. Specifically, the power draw becomes negative from 8:00 to 18:00, which means the extra power generation must be absorbed by the power grid. In the control scenario where the proposed method is implemented, the control method achieves the control objective from approximately 8:00 to 18:00 because the power draw equals zero during this period. To do this, the control method varies the setpoints of all GSHPs from 21.5 °C to 23.5 °C. Because of different k values, however, each GSHP has a dedicated setpoint trajectory. For the remaining time, because there is very little or no power generated by the PV systems, the power grid is still larger than zero even though the setpoints are already set at the maximum values. This suggests that the HGV has little power flexibility that can be utilized during those periods.




Figure 21. Power draw (top) and cooling temperature setpoint (bottom) under the baseline and under control.

Figure 22 compares the results during the control scenario and the testing scenarios. We can see that the control scenario uses more power from 8:00 to 17:00 and less power for most of the remaining hours. As a result, the accumulated energy consumption in the control scenario is less than that in the baseline scenario before 11:00 and larger than that in the baseline scenario after 11:00. It is worth mentioning that the energy consumption for the testing day in the control scenario is larger than that in the baseline scenario at the end of the testing day. This suggests that providing power from the grid may lead to more energy consumption by buildings.




Figure 22. Power and energy consumption of the HGV under the baseline and under control.

Figure 23 shows the details of how one GSHP operates under the control scenario and the baseline scenario. Under the baseline scenario, the zone temperature is quite close to the setpoint for most of the time. The speed ratio of the compressor varies from 0 to 0.9, and the peak value occurs at around 12:00. On the other hand, in the control scenario, the setpoint is set to be 23.5 °C from 0:00 to 8:00. In that case, because the temperature is lower than the setpoint, the compressor is shut off. From 9:00 to 18:00, the setpoint decreases, leading to a peak speed ratio of almost 1. After 17:00, the setpoint increases again, and the compressor is shut off accordingly.




Figure 23. Power and energy consumption of the HGV under the baseline and under control.

6 Conclusion and Future Work

In this paper, we proposed a virtual testbed for designing and operating NZECs. The virtual testbed consists of a series of system models and a software framework. The system models are developed with physics-based and data-driven modeling methods, respectively, and the framework is designed to streamline simulation and optimization. We compared the prediction power results with the measurements from a real NZEC, and the outcome suggests that (1) in general, the system models achieve good accuracy in predicting power. For the community-level model, the model can track the trajectory of the power for the testing week while the R^2 value is 0.95. (2) For PV system modeling, the data-driven models perform better than the physics-based models. The reason for this difference is the variability of the information used in the models that should be related to model characteristics. (3) For miscellaneous electric equipment modeling,

the load patterns of some equipment are randomly distributed. (4) The aggregated load and solar generation profiles of the HGV indicate that there is an inherent imbalance between energy demand and supply. Exploring opportunities to reduce coincident peak demand of electric and thermal loads can reduce the cost of achieving energy resilience at the community and grid scales. Beyond comparing the prediction and measurement results, we also applied the virtual testbed to evaluate building-to-grid integration control. Based on the evaluation results, applying this control in the HGV to address the “duck curve” issue is a promising avenue; furthermore, the studied control respects the performance of the occupants, which can simplify control deployment.

The research described in this paper focuses on establishing a foundation for exploring the design and operations of an NZEC. With additional resources, a series of studies can be conducted based on the testbed developed here. For example, smart thermostats and occupancy sensors would allow us to develop adaptive control strategies that maximize on-site solar energy consumption, demonstrate the ability to reduce coincident peak electric and thermal loads, reduce demand charges, and participate in demand-response programs. Occupancy-related studies should be conducted to help us better understand how occupancy affects the operation of building systems. In the future, it would be helpful to distinguish between weather and occupant effects for different load types. Additional operating data and smart controls can allow system designers to correctly size mechanical systems and energy (thermal and chemical) storage systems. Facility operators can devise operational and control strategies to preheat and precool spaces based on typical load patterns, weather and occupancy forecasts, and available distributed energy resources.

Acknowledgment

To be added

References

- ASHRAE, ASHRAE Standard. 2007. "Standard 90.1-2007, Energy Standard for Buildings Except Low-Rise Residential Buildings." *American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.*
- Athienitis, Andreas, and William O'Brien. 2015. "Modeling, Design, and Optimization of Net-Zero Energy Buildings." Germany: Wiley.
- Braun, James E., and Nitin Chaturvedia. 2002. "An Inverse Gray-Box Model for Transient Building Load Prediction." *HVAC&R Research* 8 (1):73-99.
- De Coninck, Roel, Ruben Baetens, Dirk Saelens, Achim Woyte, and Lieve Helsen. 2014. "Rule-based demand-side management of domestic hot water production with heat pumps in zero energy neighbourhoods." *Journal of Building Performance Simulation* 7 (4):271-88.
- Denholm, Paul, Matthew O'Connell, Gregory Brinkman, and Jennie Jorgenson. 2015. "Overgeneration from Solar Energy in California: A Field Guide to the Duck Chart." National Renewable Energy Laboratory
- Fabrizio, Enrico, Federico Seguro, and Marco Filippi. 2014. "Integrated HVAC and DHW production systems for Zero Energy Buildings." *Renewable and Sustainable Energy Reviews* 40 (2014):515-41. doi: 10.1016/j.rser.2014.07.193.
- Feng, Xiaohang, Da Yan, and Tianzhen Hong. 2015. "Simulation of occupancy in buildings." *Energy and Buildings* 87 (2015):348-59.
- Gaiser, Kyle, and Pieter Stroeve. 2014. "The impact of scheduling appliances and rate structure on bill savings for net-zero energy communities: Application to West Village." *Applied Energy* 113 (2014):1586-95.
- Hachem-Vermette, C., E. Cubi, and J. Bergerson. 2015. "Energy performance of a solar mixed-use community." *Sustainable Cities and Society*.
- Hachem-Vermette, Caroline, Francesco Guarino, Vincenzo La Rocca, and Maurizio Cellura. 2018. "Towards Achieving Net-zero Energy Communities: Investigation of Designstrategies and Seasonal Solar Collection and Storage Net-zero." *Solar Energy* In press.
- Hecht-Nielsen. 1989. "Theory of the backpropagation neural network." Paper presented at the International Joint Conference on Neural Networks, Washington, D.C.
- Huang, Sen, Ana Carolina Laurini Malara, Wangda Zuo, and Michael D. Sohn. 2016. "A Bayesian Network Model for the Optimization of a Chiller Plant's Condenser Water Set Point." *Journal of Building Performance Simulation* In Press.
- Huang, Sen, Wangda Zuo, and Michael D. Sohn. 2016. "A Bayesian Network Model for Predicting the Cooling Load of Educational Facilities." Paper presented at the ASHRAE and IBPSA-USA SimBuild 2016 Building Performance Modeling Conference Salt Lake City, UT
- Kallushi, Abi, Jeffrey Harris, John Miller, Matt Johnston, and Ab Ream. 2012. "Think Bigger: Net-Zero Communities." Paper presented at the ACEEE Summer Study on Energy Efficiency in Buildings, Pacific Grove, CA, U.S.A
- Kilkis, Siir. 2015. "Exergy transition planning for net-zero districts." *Energy* (2015):1-17.
- Lu, Hai, Zitao Yu, Kari Alanne, Liang Zhang, Liwu Fan, Xu Xue, and Ivo Martinac. 2014. "Transition path towards hybrid systems in China: Obtaining net-zero exergy district using a multi-objective optimization method." *Energy and Buildings* 85 (2014):524-35.
- Lu, Yuehong, Shengwei Wang, and Kui Shan. 2015. "Design optimization and optimal control of grid-connected and standalone nearly/net zero energy buildings." *Applied Energy* 155 (1):463-77. doi: 10.1016/j.apenergy.2015.06.007.
- Managan, Katrina. 2012. "Net zero communities: one building at a time." Institute for Building Efficiency, Johnson Controls
- Marique, Anne-Françoise, and Sigrid Reiter. 2014. "A simplified framework to assess the feasibility of zero-energy at the neighbourhood/community scale." *Energy and Buildings* 82:114-22. doi: <http://dx.doi.org/10.1016/j.enbuild.2014.07.006>.
- MathWorks. "MathWorks - Makers of MATLAB and Simulink." <https://www.mathworks.com/>.

- Mathworks. 2017. "MATLAB Engine API for Python." Accessed March 18. <https://www.mathworks.com/help/matlab/matlab-engine-for-python.html>.
- Miranda, Reymundo, Sen Huang, German Barrios, Dan Li, and Wangda Zuo. 2015. "Energy Efficient Design for Hotels in the Tropical Climate using Modelica." Paper presented at the The 11th International Modelica Conference, Versailles, France.
- Modelica Association. "Modelica and the Modelica Association." <https://www.modelica.org/>.
- Moore, Trivess. 2014. "Modelling the through-life costs and benefits of detached zero (net) energy housing in Melbourne, Australia." *Energy and Buildings* 70 (2014):463-71. doi: 10.1016/j.enbuild.2013.11.084.
- Muruganantham, B., R. Gnanadass, and N.P. Padhy. 2017. "Challenges with Renewable Energy Sources and Storage in Practical Distribution Systems." *Renewable and Sustainable Energy Reviews* 73 (2017):125-34.
- Nouidui, Thierry Stephane, Kaustubh Phalak, Wangda Zuo, and Michael Wetter. 2012. "Validation of the Window Model of the Modelica Buildings Library." Paper presented at the the 9th International Modelica Conference, Munich, Germany.
- Orehounig, Kristina, Georgios Mavromatidis, Ralph Evins, Viktor Dorer, and Jan Carmeliet. 2014. "Towards an energy sustainable community: An energy system analysis for a village in Switzerland." *Energy and Buildings* 84 (2014):277-86.
- Perez, Ruben E, Peter W Jansen, and Joaquim RRA Martins. 2012. "pyOpt: a Python-based object-oriented framework for nonlinear constrained optimization." *Structural and Multidisciplinary Optimization* 45 (1):101-18.
- Peterson, Kent, Paul Torcellini, and Roger Grant. 2015. "A Common Definition for Zero Energy Buildings." The National Institute of Building Sciences
- The Renewable Resource Data Center. 2017. "National Solar Radiation Data Base." Accessed April 15. http://rredc.nrel.gov/solar/old_data/nsrdb/.
- UC Davis West Village. 2014. "UC Davis West Village Energy Initiative Annual Report 2013-2014."
- Wetter, M., W. Zuo, T. S. Nouidui, and X. Pang. 2014. "Modelica buildings library." *Journal of Building Performance Simulation* 7 (4):253-70.
- Wetter, Michael. 2004. "GenOpt®. Generic Optimization Program. User Manual, version 2.0.0. Lawrence Berkeley National Laboratory." Berkeley. Technical report LBNL-54199. <http://gundog.lbl.gov/GO>
- Wetter, Michael. 2011. "A view on future building system modeling and simulation." *Building Performance Simulation for Design and Operation*:481.
- Wilcox, Stephen M. 2012. "National solar radiation database 1991-2010 update: User's manual." National Renewable Energy Lab.(NREL), Golden, CO (United States)
- Zuo, Wangda, and Qingyan Chen. 2010. "Fast and informative flow simulation in a building by using fast fluid dynamics model on graphics processing unit." *Building and Environment* 45 (3):747-57.
- Zuo, Wangda, Michael Wetter, Dan Li, Minggang Jin, Wei Tian, and Qingyan Chen. 2014. "Coupled Simulation of Indoor Environment, HVAC and Control System by using Fast Fluid Dynamics and the Modelica Buildings Library." Paper presented at the ASHRAE/IBPSA-USA Building Simulation Conference, Atlanta, GA, U.S.A.
- Zuo, Wangda, Michael Wetter, Wei Tian, Dan Li, Minggang Jin, and Qingyan Chen. 2016. "Coupling Indoor Airflow, HVAC, Control and Building Envelope Heat Transfer in the Modelica Buildings library." *Journal of Building Performance Simulation* 9 (4):366-81.