

# Beyond signal quality: The value of unmaintained pH, dissolved oxygen, and oxidation-reduction potential sensors for remote performance monitoring of on-site sequencing batch reactors

Schneider, Mariane Yvonne<sup>1,2\*</sup>; Carbajal, Juan Pablo<sup>1</sup>; Furrer, Viviane<sup>1</sup>; Sterkele, Bettina<sup>1</sup>; Maurer, Max<sup>1,2</sup>; Villez, Kris<sup>1,2</sup>

1 Eawag, Swiss Federal Institute of Aquatic Science and Technology, 8600 Dübendorf, Switzerland.

2 Institute of Civil, Environmental and Geomatic Engineering, ETH Zürich, 8093 Zurich, Switzerland.

\*Contact Address: Mariane Schneider Eawag, Swiss Federal Institute of Aquatic Science and Technology, Urban Water Management Überlandstrasse 133, 8600 Dübendorf, Switzerland.

E-mail: mariane.schneider@eawag.ch (M. Y. Schneider)

## Abstract

Sensor maintenance is time-consuming and is a bottleneck for monitoring on-site wastewater treatment systems. Hence, we compare maintained and unmaintained pH, dissolved oxygen (DO), and oxidation-reduction potential (ORP) sensors to monitor the biological performance of a small-scale sequencing batch reactor (SBR). We created soft sensors using engineered features: ammonium valley for pH, oxidation ramp for DO, and nitrite ramp for the ORP. We found that the pH soft sensors are able to reliably identify the completion of ammonium oxidation in the SBR's effluent even without sensor maintenance for over a year. In contrast, the DO soft sensor using data from a maintained sensor showed slightly better detection performance than that using data from unmaintained sensors, as the DO soft sensor using maintained data is much less sensitive to the optimisation of cut-off frequency and slope tolerance than the soft sensor using unmaintained data. The nitrite ramp provided no useful information on the state of nitrite oxidation, so no comparison of maintained and unmaintained ORP sensors was possible in this case. We identified two hurdles when designing soft sensors for unmaintained sensors: i) Sensors' type- and design-specific deterioration affects performance. ii) Feature engineering for soft sensors is sensor type specific, and the outcome is strongly influenced by operational parameters such as the aeration rate. In summary, we provide soft sensors that allow the performance of unstaffed small-scale SBRs to be monitored with unmaintained sensors and therefore the maintenance and reliability of OST systems to be optimised.

## Abbreviations

<i>COD</i>	<i>chemical oxygen demand</i>
<i>DO</i>	<i>dissolved oxygen</i>
<i>DOC</i>	<i>dissolved organic carbon</i>
<i>ORP</i>	<i>oxidation-reduction potential</i>
<i>OST</i>	<i>on-site wastewater treatment (small, unstaffed wastewater treatment plants)</i>
<i>PE</i>	<i>population equivalents</i>
<i>SBR</i>	<i>sequencing batch reactor</i>
<i>TOC</i>	<i>total organic carbon</i>
<i>WWTP</i>	<i>wastewater treatment plant</i>

## 1 Introduction

Small scale on-site wastewater treatment (OST) plants are capable of achieving the relative performance of large-scale wastewater treatment plants (WWTP) (e.g. Abegglen and Siegrist, 2006). Consequently, a system of OST plants with adequate monitoring and associated demand-driven maintenance scheme might be able to deliver performance on par with a single centralised plant (Eggimann et al., 2017). OST systems with capacities of approximately 4–50 population equivalents (PEs) are an attractive option for several reasons: i) Modular systems have a high market potential in rural areas of OECD countries because of their low investment costs and the short planning horizon (Eggimann et al., 2018); ii) OST systems can adapt more flexibly to strong demographic changes as their lifespan is considerably shorter than corresponding networked systems (Neumann et al., 2015); and iii) from a global perspective, OST systems have the potential to rapidly improve sanitation and water pollution in urban areas without having to complete extensive public sewerage networks (Langergraber and Muellegger, 2005; Larsen et al., 2016). However, small OST plants are typically unstaffed and often exhibit undetected failures (Moelants et al., 2008). Therefore, a change towards decentralised treatment requires solutions for monitoring the performance of OST systems.

Rendering the evaluation of the performance of such OST systems feasible requires that the sensor maintenance burden be reduced. The scattered location of the unstaffed units means that using the sensor maintenance scheme for staffed units would incur high maintenance costs and risk a lack of diligent sensor management practice. Unmaintained sensors, which do not receive the recommended regular maintenance, may provide inaccurate measurements. However, if information about the plant performance is still retrievable from these inaccurate signals, unmaintained sensors might be an attractive monitoring solution for unstaffed OST plants. In recent years, several experiments have been conducted in which WWTPs were monitored and controlled over a long period with low-maintenance online sensors (Battistoni et al., 2008; Martín de la Vega et al., 2012; Peng et al., 2006; Rieger et al., 2005). Unfortunately, no information is available about the frequency of sensor maintenance. Various types of online sensor exist for monitoring and controlling centralised WWTPs (Bourgeois et al., 2001; Olsson et al., 2014). Vanrolleghem and Lee (2003) review the most mature and some newer online sensor technologies for reliability, fouling, and calibration, and they classify the sensors according to the maintenance each requires. Numerous studies to monitor (Lee et al., 2008) and quantify the performance (Weirich et al., 2015) of small but staffed WWTPs (5000-10000 PEs) have also been conducted.

In striking contrast to those WWTPs, and despite calls for monitoring and control (Boller, 1997; Massoud et al., 2009; Prieto et al., 2013), few attempts have been made to monitor OST plants remotely. Moreover, the deterioration of signal due to lack of sensor maintenance is still poorly understood. Recent research on aging sensors suggest that signal deterioration due to sensor aging can be characterised: Ohmura et al. (2018) studied pH sensor drifts in urine nitrification processes and observed that the sensitivity of 12 sensors hovered around the ideal value. Samuelsson et al. (2018) studied biofilm fouling on dissolved oxygen sensors and characterised their bias progression to design effective sensor maintenance routines. Two other studies have recently been conducted, one to correct the drifting signal of ion-selective electrodes (Papias et al., 2018) and the other to understand the fouling of ion-selective electrodes (Cecconi et al., 2018).

To our knowledge, no systematic, long-term comparisons between maintained and unmaintained online soft sensors exist yet for wastewater treatment. In this paper, we use the term soft sensor to mean a sensor together with software designed to identify particular features in the sensor data to obtain a specific type of information. The only other study we found monitored coastal waters over 100 days with various sensor designs and was used to tune the frequency of service intervals (Gray and Heitsenrether, 2013). In this study, we tested three types of online sensors for their feasibility to monitor a pilot-scale sequencing batch reactor (SBR) without sensor maintenance: oxidation-reduction potential (ORP), dissolved oxygen (DO), and pH. The key question is: How well

do the soft sensors using unmaintained sensors (unmaintained soft sensors) fare compared to those of maintained sensors (maintained soft sensors)? We formulated three hypotheses:

- i. in the unmaintained ORP signal, we can identify the presence of the nitrite ramp feature in the aeration phase, also called the nitrogen breakpoint (Martín de la Vega and Jaramillo-Morán, 2018; Ra et al., 1999), to detect the end of the nitrification process, when all nitrite is oxidised to nitrate;
- ii. in the unmaintained DO signal, we see a step change, the aeration ramp feature, which we can use to identify the end of the nitrification process as defined in i); and
- iii. in the unmaintained pH signal, we can detect the ammonium valley (Al-Ghusain et al., 1994) feature to observe when the ammonium oxidation is completed.


## 2 Materials and Methods

### 2.1 Experimental setup

The experiment took place from 20 May 2017 to 22 May 2018 in an SBR that was launched in May 2016 with sludge from a large-scale WWTP. The pilot-scale SBR setup is depicted schematically in Figure 1. The wastewater is pumped from the main trunk of a combined sewer with approximately 100,000 PEs in its catchment to the primary clarifier. From there, approximately 800 L of pretreated wastewater is transferred to a buffer tank once a day. Urine was added to about half of the sampled cycles. Every four hours the SBR is filled with 80-120 L of wastewater from this buffer tank. Table 1 characterises these influent concentrations.

*Table 1: Average concentrations, standard deviation, minimum, and maximum of the inflow to the SBR during the measurement campaign and the number of measurements. These concentrations include the added urine. Additionally, the ratio between ammonium nitrogen ( $NH_4-N$ ) and total nitrogen ( $N_{tot}$ ) is given.*

	average (std.)	minimum	maximum	number of measurements
$NH_4$ (mg <sub>N</sub> /L)	47 (22)	9	119	93
DOC (mg <sub>CO<sub>2</sub></sub> /L)	55 (21)	27	152	94
TOC (mg <sub>TOC</sub> /L)	134 (69)	45	399	93
COD <sub>fil</sub> (mg <sub>CO<sub>2</sub></sub> /L)	117 (34)	67	196	15
COD <sub>tot</sub> (mg <sub>CO<sub>2</sub></sub> /L)	423 (220)	164	1044	15
$N_{tot}$ (mg <sub>N</sub> /L)	88 (23)	64	115	5
$NH_4-N : N_{tot}$	0.68 (0.04)	0.61	0.71	5



*Figure 1: Schematic representation of the pilot-scale SBR setup. Sensor location is the level where the sensors are installed in the SBR. The system boundaries indicate which*

part of the setup the authors studied. Automatic samplers were used to sample the influent and the effluent.

**Buffer tank:** The buffer tank is refilled every morning between 10 and 11. It is usual to record peak concentrations for ammonium and chemical oxygen demand (COD) in the trunk sewer at that time of the day. The urine was added to the buffer tank to ensure a balanced dataset in which half the analysed samples show complete nitrification while the other half do not.

*Table 2: Recipe of the SBR cycles with phases in chronological order. Total cycle time: 234-242 minutes. The features in this article focus on phase 4; the aeration phase.*

Phase	Time [min]	Mixing	Aeration	Description
1: Idle	0.2	x	x	-
2: Filling	2-6	✓	x	Filling with 80-120 litres of wastewater
3: Denitrification	23	✓	x	Inflow stops before phase 3; no inflow until next cycle.
4: Nitrification (aeration phase)	114	✓	✓	Set point aeration between 2 and 2.2 mgO <sub>2</sub> /L based on the signal of the maintained DO sensor.
5: Denitrification	33	✓	x	Excess sludge removal once a day.
6: Settling	60	x	x	-
7: Decantation	2-6	x	x	Removal of 80-120 L supernatant.

**Reactor:** The SBR has a volume of 430 L and is operated in six cycles per day. One cycle takes approximately 240 minutes as shown in Table 2. The reactor phase length is time controlled. The relevant aeration phase is 114 minutes long. In addition to the wastewater from the combined sewer, we introduced three variabilities: air flow (1800 – 5600 norm-litres per hour), aerobic sludge age (2-10 days<sup>1</sup>), and inflow ammonium concentration (0-8 litres of urine added). Some 56 of 107 cycles used in this study had effluent ammonium concentrations above 1 mg<sub>N</sub>/L, 51 cycles below.

## 2.2 Sensors tested for value of maintenance

Three types of sensors (ORP, DO, and pH) were installed, each at least in triplicate. Figure 2 lists the individual sensors and the maintenance and sensor validation practice used for every sensor. Identical sensor designs were chosen for all three ORP and DO sensors, whereas two different designs were selected for the five pH sensors. One sensor of each type was maintained per manufacturer's recommendation. These sensors are henceforth called the maintained sensors. The other sensors were neither cleaned nor maintained throughout the entire measurement campaign and are called unmaintained sensors.

<sup>1</sup> The 2 days' sludge age, which is very short for OST, was chosen to stress the system, as the purpose was to observe cycles with incomplete ammonium and nitrite oxidation.




Figure 2: Installation, maintenance, and detection of failure of the tested sensors.

**pH:** Three pH sensors of CPS11D (Endress & Hauser) design and two of CPS91D (Endress & Hauser) were installed in the SBR. The difference between the two sensor designs is in the diaphragm of the reference half-cell. The CPS11D has a ring-shaped diaphragm. The CPS91D has an open aperture and is recommended for use in liquids with a high TSS concentration (Freudenberger, 2018). The maintained sensor was a CPS11D and was maintained every week according to the following procedure: i) reference measurement, as described for the unmaintained sensor below, at pH 4, ii) reference measurement in pH 7, iii) calibration whenever the drift from pH 7 was larger than 0.1 pH, and iv) control measurement in pH 7 if calibrated. The other four unmaintained pH sensors were compared weekly against the recommended buffer solutions of pH 4 and pH 7 (time in buffer 10-15 minutes). In the following, this procedure is called sensor validation.

**Dissolved oxygen (DO):** Three sensors of the COS61D (Endress & Hauser) design were installed. The maintained sensor was cleaned twice a week and validated once a week with the water-saturated air method (Endress & Hauser, 2016). Whenever the deviation from saturation concentration was larger than 0.4 mgO<sub>2</sub>/L, the maintained sensor was calibrated with the same water-saturated air method. The two unmaintained DO sensors were automatically cleaned with pressured air every 10 minutes during the aeration phase. Additionally, sensor validation measurements were taken once a week without drying or cleaning with the water saturated air method. The reference value was recorded after waiting at least 30 minutes. The first 11 cycles of the DO signals were excluded from analysis, as the automatic cleaning was not yet installed.

**Oxidation/reduction potential (ORP):** Three sensors of the CPS12D design (Endress & Hauser) were installed. The maintained sensor was cleaned and validated once a week as the manufacturer recommended (Endress & Hauser, 2017) with 220 mV and 468 mV reference solution and was calibrated (for the last eight months of the experiment) with a 220 mV solution as soon as the validation surpassed the lower limit of 190 mV. On 27

November 2017, the maintained sensor recorded a temperature of 134°C and was replaced by a new sensor of the same design on 7 December 2017. The two unmaintained sensors were neither cleaned nor maintained; however, regular sensor validation with the 220 mV buffer solution was performed during the last two months of the measurement campaign.

### 2.3 Process monitoring sensors

Joss et al. (2009) originally set up the reactor with automatic controls and a Siemens MICROMASTER 420 converter system, and we adapted the setup for this study. In addition to the sensors discussed in the previous chapter, one pressure sensor was installed to control the filling and emptying of the SBR. Furthermore, an ISEmax CAS40D ion-selective electrode (Endress & Hauser) was installed in the SBR to measure ammonium and nitrate. This measurement was used to decide which samples to analyse in the laboratory.

### 2.4 Reference measurements

Over the course of the experimental period, samples were taken with two cooled (4°C) automatic samplers (TP5 C, MAXX, 2016). One sampled the inflow during the filling phase with a bypass to the inflow tube, the other from the SBR close to the outflow during the decantation phase. Figure 1 shows the sampling locations. The samples were filtered with glass-fibre filters (GF-5, 47 mm diameter, MACHEREY-NAGEL) and analysed for dissolved organic carbon with a nondispersive infrared sensor (TOC-L, Shimadzu), nitrate and nitrite with ion chromatography (IC 761 compact with anion column Metrosep A Supp4 and Supp4/5 Guard, Metrohm), and ammonium with flow injection analysis (QC 8500 FIA Series 2 with precision dilutor PDS200, Lachat) and ion chromatography (930 Compact IC Flex with cation column Metrosep C6 250/4 and C4 Guard, Metrohm). The detection limit for the ammonium measurements of the flow injection analysis is 0.2 mg<sub>N</sub>/L and of the IC 0.5 mg<sub>N</sub>/L. Additionally to the 107 cycles used for the analysis in this paper, 21 further cycles were sampled. These 21 data sets were separated and used for another study. Moreover, only 96 cycles could be used for the DO evaluation, as the automatic cleaning was not functional at the beginning of the experiment (see section 2.2).

### 2.5 Computational Methods

The focus of this study is on comparing soft sensors using data from maintained and unmaintained sensors, and the aim is to share our findings with a large community under a suitable open-source licence<sup>2</sup>. The feature detection algorithms were selected to be as simple as possible for straightforward implementation, software maintenance for practical applications, and ease of sharing. Note that elaborate methods such as shape-constraint splines (Villez et al., 2013) are also available. However, these were ruled out at the time of writing due to the complexity of their implementation.

All the methods are implemented using Python 3, and a module is available for download (Carbajal and Schneider, 2018). The module builds on the functionality provided by the Scipy 1.0.0 Python module (Jones et al., 2001).

#### 2.5.1 General structure of feature computation

All computed features are phase (see Table 2) and sensor type specific. Point, or local, features take a signal and return an  $n$ -dimensional point and functional, or nonlocal, features take a signal and return another signal (a  $d$ -dimensional vector where  $d$  is not specified). In this paper, we only use point features. The structure of the algorithms for all features is the following:

- i. Select phase and/or time interval

---

<sup>2</sup> a license allowing copying, modification, and redistribution; e.g. GPLv3 compatible

- ii. Filter signal
- iii. Compute feature

In the subsequent sections, we provide details about the filters we used in step ii) (Section 2.5.2), and the computation of features in step iii) (Section 2.5.3). The selected phase was always the aeration phase.

## 2.5.2 Digital filters

There are three reasons for a filtering stage: i) signals have noise; ii) during the aeration phase, oscillations are induced in the signal by the on-off controller operation of the air valve; and iii) most features require a degree of regularity in the representation of the signal, such as continuous time derivatives.

The algorithms implementing our features are agnostic as to the filter the user wants to use. The user needs only to provide a function with the signature `filtered_signal = smoother (time_vector, signal)` where `signal`, `time_vector`, and `filtered_signal` are the original sensor signal, its time vector, and the corresponding filtered signal, respectively; the `smoother` here is simply a placeholder for the user-defined function. In the current study, we used frequency-based low-pass Butterworth filters (Function `butter` from Scipy's `signal` module), which are useful for removing the oscillations induced by the aeration method (pH and DO signal). The frequency contents of these oscillations is clearly separated from the slowly varying components that provide the features. In our case, this corresponds to removing all the frequencies above a cut-off frequency (low-pass). However, users might consider using other kinds of filter, such as matching filters or time-based filters, for better performance.

## 2.5.3 Signal features

The features defined in our module accept a hierarchy. Basic features are the general properties of signals (extrema, inflection points: see under “Basic point features” below). Sensor-specific features combine or select basic features to make them specific for the signal analysed (e.g. valley in the pH signal during aeration phase, see under “Sensor-type-specific features” below).

For most of the computations, we assume that the filtered signals have at least their first derivative with respect to time continuous in the interval of the analysed phase (i.e. aeration), i.e.  $C^1([0, 1])$ . However, some features assume more regularity. Hence, features exploit spline representations of the smoothed signals. These splines have at least continuous derivatives with respect to time up to order 2. Hence, we use the term *derivative* to mean *derivative with respect to time*.

### 2.5.3.1 Basic point features

All features used for the current study rely on two basic features:

- i. **Signal extrema** are defined as points at which the first derivative is zero and the second derivative is not zero. Extrema are computed on a spline model of the signal. The computation is performed in closed form if the degree of the spline allows it; otherwise it uses a root-finding algorithm.
- ii. **Inflection points** are defined as points at which the second derivative is zero and the lowest-order (above the second) nonzero derivative is odd (e.g. third, fifth, etc.). If additionally, the first derivative is zero, then the point is called a saddle. In our module, we compute inflection points based on spline models of the filtered data.

### 2.5.3.2 Sensor-type-specific features

All sensor-type-specific features are shown in Figure 3.

**pH:** The valley is a global minimum (signal extrema) of the pH signal during the aeration phase and is also known as the ammonium valley (Al-Ghusaini et al. 1994). The pH program function of the feature used in this study is called the `aeration_valley`, and this point feature indicates the time at which the minimum was found and the pH at this time.

**Dissolved oxygen:** The ramp is a maximum of the first derivative of the DO signal during the aeration phase. The DO program function used in this study is called the `aeration_ramp`. The product of the function is a three-dimensional point feature composed of the time of occurrence of the ramp, the value of the signal, and its derivative at that time, which is used for the slope tolerance.

**Oxidation / reduction potential:** The nitrite ramp feature is also a maximum of the first derivative; it is an inflection point where the second derivative is zero and the third derivative is negative. The ORP program function used in this study is called the `nitrite_ramp`. Visual classification of all ORP cycle signals in a randomised order by one of the authors (MYS) revealed no systematic feature that could be exploited as a nitrite ramp. Therefore, no automatic classification was tested based on the proposed feature. Instead, we performed an exploratory analysis of the ORP signals.




Figure 3: Synthetic signal that shows possible variations introduced by aeration. This signal is smoothed. The aeration ramp and the nitrite ramp (ramp) and the ammonium valley (valley) are then taken from the smoothed curve.

## 2.6 Data labels for classification of sensor signals

The performance of the soft sensors is evaluated by their classification power. The cycle labels used for classification are derived from the concentrations of ammonium measured in the effluent. If ammonium nitrogen was equal to or below the 1 mg<sub>N</sub>/L threshold, the cycle label is *positive*; 51 cycles have the positive label. If the ammonium nitrogen in the effluent is above 1 mg<sub>N</sub>/L, the cycle label is *negative*; 56 cycles have the negative label. This threshold was set before we started the analysis with the effluent concentration as a classifier. We decided to use double the detection limit. This is one option of several (five effluent concentrations lie between 0.75 mg<sub>N</sub>/L and 1.25 mg<sub>N</sub>/L). The choice of a threshold allows us to ignore the issue of assigning a concentration to the measurements below the detection limit: it only matters that these measurements are below the threshold but not by how much. We assume that the measured concentrations do not suffer from systematic errors and that the stochastic error is negligible for the classification.



## 2.7 Parameter optimisation

We use the following definitions to characterise our results:

- *True positive (TP)*: A feature is detected, and the cycle label is positive.
- *True negative (TN)*: No feature is detected, and the cycle label is negative.
- *False positive (FP)*: A feature is detected despite a negative cycle label.
- *False negative (FN)*: No feature is detected despite a positive cycle label.

The results for the different parameters are visualised using a receiver operating characteristic (ROC) curve (Swets, 1961). The true positive rate (TPR) and the false positive rate (FPR) are computed using Equations 1 and 2, respectively.

$$TPR = \frac{TP}{TP + FN} \quad (1)$$

$$FPR = \frac{FP}{FP + TN} \quad (2)$$

## 3 Comparison between maintained and unmaintained sensors

### 3.1 Tuning of the cut-off frequency for the ammonium valley feature

To tune the cut-off frequency for the ammonium valley detection, we used a grid search. Figure 4 shows the ROC curve for the different cut-off frequencies to smooth the signal. The ROC curve shows no difference between the maintained and unmaintained sensors. This suggests that maintained and unmaintained sensors provide the same information content and information quality. Different cut-off frequencies for maintained (2.25 Hz) and unmaintained (three times 1.82 and once 2.57 Hz) soft sensors provide the same prediction ability. This implies that parameter tuning is required to choose a suitable trade-off between the TPR and FPR.




Figure 4: ROC curve for the evaluation of all five pH soft sensors, which plots the true positive rate (TPR) against the false positive rate (FPR) with the FPR < 0.03 as the boundary where the cut-off frequency is optimal for the FPR. The chosen cut-off frequency is given in Hz.

### 3.2 Tuning of cut-off frequency and slope tolerance for the aeration ramp feature

For the oxygen soft sensor, two parameters were tuned: the cut-off frequency and the slope tolerance. The parameter landscape plot in Figure 5 shows that algorithms using data from the maintained sensor will always perform better than the ones from the unmaintained and are less sensitive than those using unmaintained sensor data. However, for some parameter combinations, the sum of the true predictions of the unmaintained soft sensors is nearly as high as for the maintained soft sensor, and the sum of the false prediction is nearly as low for the unmaintained soft sensors as for the maintained soft sensor.

A minimal slope tolerance of  $21.5^\circ$  and a cut-off frequency of 2.54 Hz for the maintained soft sensors was chosen and minimal slope tolerance of  $40^\circ$  and a cut-off frequency of 2.5 Hz for the unmaintained ones.




Figure 5: The total of all true predictions for the DO soft sensor's parameters, which are minimal slope and cut-off frequency. The maintained sensor is compared to the unmaintained sensor.

### 3.3 Ammonium valley detection based on the pH signal

The automatic identification of the ammonium valley in 107 SBR cycles, with the cut-off frequencies identified, shows that 85% of the maintained pH cycles and 84-85% of the unmaintained pH cycles were classified correctly (compare Table 3, true positive and true negative, divided by total) when compared to the ammonium effluent concentration. Only one cycle (Figure 6) of the maintained and unmaintained soft sensors had a false positive classification, and the measurement of this effluent sample had been marked as untrustworthy before we observed any feature results. Therefore, this false positive is very likely an outlier of the reference measurements. Hence, if the algorithm identifies an ammonium valley, we are confident that the ammonium concentration is below the threshold of 1 mg<sub>N</sub>/L. Conversely, false negative identifications indicate that nondetection of the feature does not necessarily mean that the ammonium concentrations are above the threshold.

Similarly, in Figure 4, we cannot see any significant difference in the feature detection performance of the maintained and unmaintained soft sensors. This means that we were able to reliably identify the end of the ammonium oxidation process with unmaintained pH sensors.




Figure 6: Ammonium valley (pH soft sensor) – Measured effluent ammonium concentration against the ammonium valley feature detection time (% of length of cycle passed during the aeration phase). The upper plot shows the concentrations for cycles in which the ammonium valley was not detected. The detection of the feature should correspond to a concentration below threshold, here shown with a vertical line (1 mg<sub>N</sub>/L). The analysis from the maintained sensor is shown by a large circle, the unmaintained sensors by smaller circles with decreasing diameters. The colours of the markers indicate whether the classification was true (purple/darker) or false (orange/lighter).

Table 3: Results of the binary feature detection with the selected parameters for the maintained and the unmaintained pH soft sensors.

pH sensors	number of FP	number of FN	number of TN	number of TP
maintained	1	15	50	41
unmaintained	1	16	50	40
unmaintained2	1	15	50	41
unmaintained3	1	16	50	40
unmaintained4	1	16	50	40

### 3.4 Dissolved oxygen soft sensors

#### 3.4.1 Aeration ramp detection based on the DO signal

The automatic identification of the aeration ramp for the 96 fully characterised SBR cycles showed that 92% of the maintained DO cycles and 80% for the first unmaintained DO and 85% for the second unmaintained DO sensor, respectively, were classified correctly (compare Table 4, true positive and true negative, divided by total). Only 2 cycles of the maintained signal are classified wrongly, and none of the unmaintained signals are. Therefore, if the algorithm does identify an aeration ramp, we are confident that the ammonium concentration is below 1 mg<sub>N</sub>/L at the end of the cycle. Additionally, 5 false negative identifications of the aeration ramp were made with the maintained soft sensor and 19 and 14 with the unmaintained soft sensors. When the parameters are tuned to minimise the number of false positive classifications, we observe that the number of false positives is insensitive to sensor maintenance, but the number of false negatives is larger without maintenance of the sensor.




Figure 7: Aeration ramp (DO soft sensor) – Measured effluent ammonium nitrogen concentration against the feature detection time during the aeration phase. The feature is a steep slope in the DO signal. The upper plot shows the concentrations for cycles in which no feature was detected. The presence of the feature should correspond to a concentration below the threshold, here shown with a vertical line (1 mg/L). The analysis from the maintained sensor is shown by a large circle, the unmaintained sensors by smaller circles with decreasing diameters. The colours of the markers indicate whether the classification was true (purple/darker) or false (orange/lighter).

Table 4: Results of the binary feature detection with the selected parameters for the maintained and the unmaintained DO soft sensor.

DO sensors	Number of FP	Number of FN	Number of TN	Number of TP
maintained	2	5	49	40
unmaintained	0	19	51	26
unmaintained2	0	14	51	31

### 3.5 Exploratory analysis of the ORP signal

A basic exploratory analysis showed that i) the mean and variance of the signals are highly correlated over time (see Figure 8a), and ii) it is hard to distinguish the signals of maintained sensors from those of unmaintained sensors by their summary statistics. Observation i) is expected due to the experimental procedures in which activated sludge remains across several cycles, and biological processes develop slowly over time. However, the observation is relevant to future efforts aimed at building models for forecasting effluent concentrations. Observation ii) indicates that ORP might be still a good candidate variable for unmaintained monitoring provided that the operational conditions leading to detectable ORP features are identified. Figure 8 b) and c) show the lack of classification potential using the mean and variance of a locally detrended signal

and the projection in the first two principal vectors. The outliers in Figure 8 b) correspond to cycles for which the sensors were validated.




Figure 8: Results of the exploratory analysis of the ORP signals. A) shows the mean and standard deviation of the signals. The time of the cycle within the experimental period is indicated by the area of the circles (small = cycle at the beginning, large = at the end). B) shows the mean and standard deviation of the residuals on a log scale (after removing a moving linear trend with a Savitzky–Golay filter), and C) shows the first and second principal components.

### 3.6 Time required for maintenance

It took us about 15 minutes per week to validate the maintained pH sensor, 30 minutes to validate the DO sensor, and 5 minutes to validate the ORP sensor. Most of this time was spent waiting until the measurements were stable. When a calibration was performed, the time required for the reference measurements multiplied by the number of points that were used for the calibration (two for pH and one for DO and ORP) results in a total of 45 minutes for all pH sensors, 60 minutes for all DO sensors, and 10 minutes for all ORP sensors. This calculation excludes the time travelling to the test site.

## 4 Discussion

Our extensive monitoring campaign has enabled us to successfully demonstrate that, given an appropriate engineered feature, unmaintained sensors can provide the same information and information quality as maintained sensors. In this section, we discuss the circumstances under which this is expected to be true. We first discuss the features of each sensor type and what the results suggest for further feature development. Second, we compare the prediction ability of maintained and unmaintained soft sensors, including which of the soft sensors we would recommend using. Finally, we make suggestions for future research.

## 4.1 Feature Engineering

Proton concentrations, measured by the pH sensor, and dissolved oxygen concentrations, measured by the DO sensor and indirectly by the ORP sensor, are not only strongly affected by nitrification but also depend on a series of other factors, such as aeration rate and heterotrophic bacteria growth. These factors act as potential confounding factors during feature detection. Indeed, our methods assume that a feature, such as a minimum in the pH signal, can only be produced by the target phenomenon of interest (i.e. ammonium oxidation completion).

For example, with the experience gained in this study and an additional OST in operation, we observed that the aeration rate is the predominant factor for all the features that we tested. Similarly, another study has found that the ORP is strongly affected by residual oxygen (Holman and Wareham, 2003). As the influence of each confounding factor can be reduced by appropriate control of aeration, we are convinced that the low-level controls of SBRs should be designed and tuned to ensure that the high-level monitoring functionalities provided by soft sensors are guaranteed.

In the following, we discuss the detection of three features: nitrite ramp, aeration ramp, and ammonium valley.

- **ORP:** Ra et al. (1999) identified the nitrogen breakpoint, here called nitrite ramp, in swine manure treatment. We did not observe the nitrite ramp feature in the ORP signal of our data despite complete oxidation of ammonium and nitrite to nitrate in 30 cycles. One possible explanation is that the ammonium oxidation rate is too low, especially relative to the aeration rate (controlled between 2 and 2.2 mg<sub>O<sub>2</sub></sub>/L), as discussed above. However, tests with a lower aeration rate did not support this. Similarly, Peddie et al. (1990) observed a plateau instead of a nitrite ramp.
- **DO:** A feature that relies on the DO signal has a direct causal relation via the oxygen uptake rate to the ammonium effluent concentration, which makes it a compelling signal for feature engineering. The feature we use is based on visual observation. The driving factor behind this feature is the oxygen uptake rate, which was reported previously as a reliable measure for SBR processes (Villez et al., 2010). In a constantly or fixed-time-interval aerated system, we would expect this ramp to appear even more clearly than with on-off feedback control of the DO.
- **pH:** The ammonium valley proved to be a very robust feature in our case. However, similarly to the nitrite ramp, the ammonium valley feature could be absent from the pH signal (as a test in the same reactor showed where we controlled the DO between 4 and 4.4 mg<sub>O<sub>2</sub></sub>/L). Indeed, if the aeration is strong enough to strip CO<sub>2</sub> faster than the nitrifying bacteria produce protons, no ammonium valley occurs despite a full ammonium oxidation. As stronger aeration is a waste of energy, there is no trade-off between the performance of the treatment process and the feature occurrence: both benefit from a lower aeration rate.

## 4.2 The value of sensor maintenance

To our knowledge, this is the first time that the same type and design of maintained and unmaintained sensors were installed in a wastewater treatment plant and a systematic comparison made over one year. As sensor maintenance is time-consuming, hence preventing the application of sensors in OSTs, the findings described below are potential game-changers. In the following, we discuss how the unmaintained ORP, DO, and pH soft sensors fare compared to the maintained soft sensors:

- **ORP:** Several elements of the experiments lead to new insights: i) under our operating conditions, the nitrite ramp is absent, which means that we do not gain information about the system's performance from this feature, and ii) the

unmaintained and maintained sensor signals are statistically not distinguishable, based on this exploratory analysis of the signals.

- **DO:** Both unmaintained DO sensors show very similar behaviour but distinct from the maintained sensor. This suggests that the sensor deterioration processes for both unmaintained sensors are similar. Studying these disturbances may lead to robust features to compensate for deterioration effects. Possible causes might be the formation of a layer of fat that the treatment with pressured air does not remove, gradual abrasion of the sensor membrane by pressured air, or the growth of a nitrifying biofilm. This last would explain the sudden change observed in the offset at the end of nitrification, where no ammonium is present to cause additional oxygen consumption on the sensor membrane (see Appendix A.2). Despite these disturbances, which might mislead human experts when classifying visually, the soft sensor does not classify a false-positive ramp. This means that prediction from the unmaintained soft sensor is reliable.
- **pH:** No difference could be observed between the maintained and unmaintained pH soft sensor when detecting ammonium valleys. The comparably high information content of the unmaintained pH sensor signal can be explained by the design of the soft sensors. We used features that are robust to additive disturbances of the signal, such as an offset or a drift that is slow compared to the length of an SBR cycle. While observing a drift, we did not find any variation in sensitivity, which is in line with a recent study with 12 pH sensors lasting for two years that observed stable sensitivity (Ohmura et al., 2018).

With the algorithms that we used, the DO soft sensor performs better with data from a maintained sensor than do the pH and ORP soft sensors. However, the DO sensor with automatic cleaning is about as informative with unmaintained-sensor data as the pH soft sensors with either kind of data. The performance of the soft sensors with maintained-sensor data is treated as the benchmark, because they are equivalent to the best performance achievable with unmaintained sensors. However, it should be noted that this is not a universal benchmark, because using a different algorithm could lead to better performances of soft sensors with maintained-sensor data.

In our study, the ammonium valley detection for the pH signal is at its full potential. In contrast, the aeration ramp could be improved by first characterising and then compensating the disturbances in soft sensors.

### 4.3 Implications for OSTs

An extensive literature study and conversations with practitioners across Asia and Europe confirmed that no continuous, remote monitoring of the biological processes of OST plants is currently executed in practice. This has a detrimental effect on overall treatment performance and cost, as performance failures are only detected during maintenance, and maintenance is executed to a fixed schedule instead of when it is actually needed.

Our study demonstrates that unmaintained sensors can be used to monitor biological processes in OSTs, which allows one of the main hurdles to widespread monitoring, sensor maintenance costs, to be overcome. Therefore, we suggest using soft sensors with unmaintained sensors as a cost-effective solution that enables continuous monitoring of OST plants.

This result offers potential improvements for OSTs: Demand-driven maintenance of OSTs could lead to an overall increase of system performance and thus improve the reputation of OST systems. Moreover, the data this gathered can be used to refine and further improve the soft sensors presented in this work.

## 4.4 Further research

Based on the new insights this study has given us on the potential of unmaintained sensors, we are currently exploring whether feature engineering can be used to predict exact ammonium effluent concentrations. We will also evaluate how transferable these features are to other OST plants in operation.

The dataset that we provide with this study can be explored further for

- the possibility of employing human experts instead of time- and resource-consuming ammonium measurements to detect ammonium valleys and/or aeration ramps, which are then used as a benchmark against which the features under development can be tested;
- the use of unmaintained ORP, DO, and pH sensors to determine the inflow and the effluent concentrations of other compounds than ammonium, such as for example COD; and
- extracting information from as-yet-unexploited auxiliary data, such as the aeration pattern. This could enable more transferable feature design.

Furthermore, other sensors, such as ion-selective electrodes for ammonium measurement and off-gas sensors, could be tested for use without maintenance.

## 5 Conclusion

The goal of this study was to identify sensors to monitor on-site wastewater treatment (OST) plants without sensor maintenance for at least one year. We performed experiments using a small scale SBR monitored by ORP, DO, and pH sensors. For each sensor type, multiple sensors of the same design were used: one was maintained while the others were left unmaintained. This experimental design allowed us to study and understand the value of maintenance for three different types of sensors. The main findings are that

- The automatic detection of the end of the ammonium oxidation using a feature based on a pH signal, called the ammonium valley, is reliable with and without maintenance. No difference in the quality of the ammonium valley detection between maintained and unmaintained pH soft sensors could be observed, despite a significant signal drift in the unmaintained pH sensors. This finding clearly shows that pH sensors can be used to monitor wastewater treatment processes in SBRs with minimal maintenance.
- The signals of the two unmaintained optical DO sensors both showed similar, nonlinear disturbances. These unexplained disturbances make automatic feature detection difficult. Additionally, the perturbations might mislead experts who are used to oxygen signals from maintained sensors, as these differ considerably. For these reasons, we would not recommend relying on unmaintained DO sensors in OSTs as long as the effects of the disturbances and the fault-inducing processes are poorly understood.
- The nitrite ramp, also known as the nitrogen breakpoint, could not be observed in either the maintained or the unmaintained ORP sensor signals. This suggests that the nitrate ramp, which indicates the end of nitrite oxidation during the aeration phase, is not a sufficiently robust feature for OST plants. A better feature than the nitrite ramp would be needed to test the hypothesis that either the maintained or the unmaintained ORP sensors can be used to monitor OST plants. Therefore, further comparison of the maintained and unmaintained ORP sensor signals with different features would be interesting.
- Successful application of the features presented in this study depends on the low-level process control of the SBR, particularly on the aeration. This shows that adapting the control, especially aeration, to the feature design is vital.



In this paper, we refute the widespread belief that frequent sensor maintenance is always necessary. We show that robust soft sensors can be designed to deliver key process indicators while enabling a drastic reduction in maintenance frequency. We expect these findings to have a broad impact, because they open the path towards autonomous and remote monitoring of OST plants.

#### Acknowledgements

Karin Rottermann and Sylvia Richter for careful sample analysis; Adriano Joss, Marco Kipf, Simon Dicht, Daniel Iten, and Stefan Vogel for technical support; Philipp Beutler, Lena Mutzner, and Christoph Ort for valuable input; and Simon Milligan for language editing. JPC acknowledges support from the EmuMore discretionary funding scheme of The Swiss Federal Institute of Aquatic Science and Technology.

#### Authors' contributions

MYS designed the experiment and led the project and the writing of the article. MYS & JPC wrote software and executed data analysis. VF supported the reference measurements. BS did most of the reference measurements, KV & JPC provided ideas and expertise. KV & MM supervised the work. All authors contributed to the writing of this document.

## Appendix

### A. Perturbations of the low maintenance sensors:

pH, DO and ORP sensors each show a different pattern of aging. The pH sensor values drift, the DO drifts and is dampened and for the unmaintained ORP sensor we do not have enough data to clearly identify a drift, however even the sensor validation of the maintained sensor shows a high standard deviation.

#### A.1. Reference measurements of the pH sensors




Figure A. 1: Sensor drift based on reference measurement of the maintained and the unmaintained pH sensors with buffer solution at pH 7 between July 2017 and July 2018.




Figure A.2: Sensor drift based on reference measurement of the maintained and the unmaintained pH sensors with buffer solution at pH 4 between July 2017 and July 2018.

## A.2. Signal behaviour of the DO sensors over time




Figure A.3: Behaviour of the unmaintained DO signals represented by four cycles during the experimental period which showed non-linear deterioration effects

### A.3. Reference measurements of the DO sensors




Figure A.4: Reference measurements of maintained DO sensor – cleaned with soap, then measured in water saturated air, calibrated if necessary between July 2017 and July 2018. The cross represents the target concentration for the present temperature and altitude.




Figure A.5: Reference measurements of unmaintained DO sensors – in water saturated air without cleaning between July 2017 and July 2018. The asterisk represents the target concentration for the present temperature and altitude.

#### A.4. Reference measurements of the ORP sensors




Figure A.6: Reference measurements of the maintained ORP sensor – cleaned, calibrated, and validated regularly between July 2017 and July 2018. Sensor was exchanged due to a fault with unknown on-set at the dotted line.




Figure A.7: Reference measurements of unmaintained ORP sensors – frequent measurements from July 2017 to July 2018.

## References

- Abegglen, C., Siegrist, H., 2006. Domestic wastewater treatment with a small-scale membrane bioreactor. *Water Sci. Technol.* 53, 69–78. <https://doi.org/10.2166/wst.2006.077>
- Al-Ghusain, I.A., Huang, J., Hao, O.J., Lim, B.S., 1994. Using pH as a real-time control parameter for wastewater treatment and sludge digestion processes. *Water Sci. Technol.* 30, 159–168.
- Battistoni, E.M., Fatone, F., Pavan, P., Beltritti, R., Raviola, M., 2008. Process control automation and remote on-line supervision: the strategy for wastewater treatment in an Italian piedmont. *Water Sci. Technol.* 57, 1571. <https://doi.org/10.2166/wst.2008.152>
- Boller, M., 1997. Small wastewater treatment plants - a challenge to wastewater engineers. *Water Sci. Technol.* 35, 1–12. <https://doi.org/10.2166/wst.1997.0237>
- Bourgeois, W., Burgess, J.E., Stuetz, R.M., 2001. On-line monitoring of wastewater quality: a review. *J. Chem. Technol. Biotechnol.* 76, 337–348. <https://doi.org/10.1002/jctb.393>
- Carbajal, J.P., Schneider, M.Y., 2018. SBR Feature Package, <https://gitlab.com/kakila/sbrfeatures>.
- Cecconi, F., Reifsnnyder, S., Donikian, N.A., Ito, Y., Jimenez, M., Sobhani, R., Rosso, D., 2018. Field Evaluation of ISE-ammonium Sensors and Their Influencing Factors in WRRFs. Presented at the WEFTEC 2018: Session 420 through Session 429. <https://doi.org/10.2175/193864718825135685>
- Eggimann, S., Mutzner, L., Wani, O., Schneider, M.Y., Spuhler, D., Moy de Vitry, M., Beutler, P., Maurer, M., 2017. The Potential of Knowing More: A Review of Data-Driven Urban Water Management. *Environ. Sci. Technol.* 51, 2538–2553. <https://doi.org/10.1021/acs.est.6b04267>
- Eggimann, S., Truffer, B., Feldmann, U., Maurer, M., 2018. Screening European market potentials for small modular wastewater treatment systems – an inroad to sustainability transitions in urban water management? *Land Use Policy* 78, 711–725. <https://doi.org/10.1016/j.landusepol.2018.07.031>
- Endress & Hauser, 2017. pH/ORP sensors and reference half cells, Operating Instructions.
- Endress & Hauser, 2016. Oxymax COS61D, Operating Instructions.
- Freudenberger, M., 2018. pH Measurement, What's the magic behind pH? Let us understand the theory and instrumentation behind!
- Gray, G.B., Heitsenrether, R., 2013. NOAA's recent field testing of coastal water quality monitoring systems - quantifying impacts of biofouling and investigating chloride measurement techniques, in: 2013 OCEANS - San Diego. Presented at the 2013 OCEANS - San Diego, pp. 1–9. <https://doi.org/10.23919/OCEANS.2013.6741346>
- Holman, J.B., Wareham, D.G., 2003. Oxidation-Reduction Potential as a Monitoring Tool in a Low Dissolved Oxygen Wastewater Treatment Process. *J. Environ. Eng.* 129, 52–58. [https://doi.org/10.1061/\(ASCE\)0733-9372\(2003\)129:1\(52\)](https://doi.org/10.1061/(ASCE)0733-9372(2003)129:1(52))
- Jones, E., Oliphant, T., Peterson, P., others, 2001. SciPy: Open source scientific tools for Python.
- Joss, A., Salzgeber, D., Eugster, J., König, R., Rottermann, K., Burger, S., Fabijan, P., Leumann, S., Mohn, J., Siegrist, H., 2009. Full-scale nitrogen removal from digester liquid with partial nitrification and anammox in one SBR. *Environ. Sci. Technol.* 43, 5301–5306.
- Langergraber, G., Muellegger, E., 2005. Ecological Sanitation--a way to solve global sanitation problems? *Environ. Int.* 31, 433–44. <https://doi.org/10.1016/j.envint.2004.08.006>

- Larsen, T.A., Hoffmann, S., Lüthi, C., Truffer, B., Maurer, M., 2016. Emerging solutions to the water challenges of an urbanizing world. *Science* 352, 928–933. <https://doi.org/10.1126/science.aad8641>
- Lee, M.W., Hong, S.H., Choi, H., Kim, J.-H., Lee, D.S., Park, J.M., 2008. Real-time remote monitoring of small-scaled biological wastewater treatment plants by a multivariate statistical process control and neural network-based software sensors. *Process Biochem.* 43, 1107–1113. <https://doi.org/10.1016/j.procbio.2008.06.002>
- Martín de la Vega, P., Jaramillo-Morán, M., 2018. Obtaining Key Parameters and Working Conditions of Wastewater Biological Nutrient Removal by Means of Artificial Intelligence Tools. *Water* 10, 685. <https://doi.org/10.3390/w10060685>
- Martín de la Vega, P.T., Martínez de Salazar, E., Jaramillo, M.A., Cros, J., 2012. New contributions to the ORP & DO time profile characterization to improve biological nutrient removal. *Bioresour. Technol.* 114, 160–167. <https://doi.org/10.1016/j.biortech.2012.03.039>
- Massoud, M.A., Tarhini, A., Nasr, J.A., 2009. Decentralized approaches to wastewater treatment and management: applicability in developing countries. *J. Environ. Manage.* 90, 652–9. <https://doi.org/10.1016/j.jenvman.2008.07.001>
- MAXX, 2016. MAXX TP5 C, portable sampler, [http://www.maxx-gmbh.com/english/tender\\_documents/TP5\\_C.pdf](http://www.maxx-gmbh.com/english/tender_documents/TP5_C.pdf).
- Moelants, N., Janssen, G., Smets, I., Van Impe, J., 2008. Field performance assessment of onsite individual wastewater treatment systems. *Water Sci. Technol.* 58, 1–6. <https://doi.org/10.2166/wst.2008.325>
- Neumann, M.B., Rieckermann, J., Hug, T., Gujer, W., 2015. Adaptation in hindsight: Dynamics and drivers shaping urban wastewater systems. *J. Environ. Manage.* 151, 404–415. <https://doi.org/10.1016/j.jenvman.2014.12.047>
- Ohmura, K., Thuerlimann, C.M., Kipf, M., Carbajal, J.P., Villez, K., 2018. Characterizing Long-term Wear and Tear of Ion-Selective pH Sensors. <https://doi.org/10.31224/osf.io/mv6tz>
- Olsson, G., Carlsson, B., Comas, J., Copp, J., Gernaey, K.V., Ingildsen, P., Jeppsson, U., Kim, C., Rieger, L., Rodríguez-Roda, I., Steyer, J.-P., Takács, I., Vanrolleghem, P.A., Vargas, A., Yuan, Z., Åmand, L., 2014. Instrumentation, control and automation in wastewater - from London 1973 to Narbonne 2013. *Water Sci. Technol. J. Int. Assoc. Water Pollut. Res.* 69, 1373–85. <https://doi.org/10.2166/wst.2014.057>
- Papias, S., Masson, M., Pelletant, S., Prost-Boucle, S., Boutin, C., 2018. *In situ* continuous monitoring of nitrogen with ion-selective electrodes in a constructed wetland receiving treated wastewater: an operating protocol to obtain reliable data. *Water Sci. Technol.* 77, 1706–1713. <https://doi.org/10.2166/wst.2018.052>
- Peddie, C.C., Mavinic, D.S., Jenkins, C.J., 1990. Use of ORP for monitoring and control of aerobic sludge digestion. *J. Environ. Eng.* 116, 461–471. [https://doi.org/10.1061/\(ASCE\)0733-9372\(1990\)116:3\(461\)](https://doi.org/10.1061/(ASCE)0733-9372(1990)116:3(461))
- Peng, Y.Z., Ma, Y., Wang, S.Y., 2006. Improving nitrogen removal using on-line sensors in the A/O process. *Biochem. Eng. J.* 31, 48–55. <https://doi.org/10.1016/j.bej.2006.05.023>
- Prieto, A.L., Vuono, D., Holloway, R., Benecke, J., Henkel, J., Cath, T.Y., Reid, T., Johnson, L., Drewes, J.E., 2013. Decentralized Wastewater Treatment for Distributed Water Reclamation and Reuse: The Good, The Bad, and The Ugly—Experience from a Case Study, in: Ahuja, S., Hristovski, K. (Eds.), *Novel Solutions to Water Pollution*. American Chemical Society, Washington, DC, pp. 251–266. <https://doi.org/10.1021/bk-2013-1123.ch015>

- Ra, C.S., Lo, K.V., Mavinic, D.S., 1999. Control of a swine manure treatment process using a specific feature of oxidation reduction potential. *Bioresour. Technol.* 70, 117–127. [https://doi.org/10.1016/S0960-8524\(99\)00035-8](https://doi.org/10.1016/S0960-8524(99)00035-8)
- Rieger, L., Thomann, M., Gujer, W., Siegrist, H., 2005. Quantifying the uncertainty of on-line sensors at WWTPs during field operation. *Water Res.* 39, 5162–74. <https://doi.org/10.1016/j.watres.2005.09.040>
- Samuelsson, O., Björk, A., Zambrano, J., Carlsson, B., 2018. Fault signatures and bias progression in dissolved oxygen sensors. *Water Sci. Technol.* 78, 1034–1044. <https://doi.org/10.2166/wst.2018.350>
- Swets, J.A., 1961. Is There a Sensory Threshold? *Science, New Series* 134, 11.
- Vanrolleghem, P.A., Lee, D.S., 2003. On-line monitoring equipment for wastewater treatment processes: state of the art. *Water Sci. Technol.* 47, 1–34. <https://doi.org/10.2166/wst.2003.0074>
- Villez, K., Rosén, C., D'hooge, E., Vanrolleghem, P.A., 2010. Online Phase Length Optimization for a Sequencing Batch Reactor by Means of the Hotelling's  $T^2$  Statistic. *Ind. Eng. Chem. Res.* 49, 180–188. <https://doi.org/10.1021/ie801907n>
- Villez, K., Venkatasubramanian, V., Rengaswamy, R., 2013. Generalized shape constrained spline fitting for qualitative analysis of trends. *Comput. Chem. Eng.* 58, 116–134. <https://doi.org/10.1016/j.compchemeng.2013.06.005>
- Weirich, S.R., Silverstein, J., Rajagopalan, B., 2015. Simulation of Effluent Biological Oxygen Demand and Ammonia for Increasingly Decentralized Networks of Wastewater Treatment Facilities. *Environ. Eng. Sci.* 32, 232–239. <https://doi.org/10.1089/ees.2014.0407>