

## Supplemental Information

### Probabilistic analysis of ecological, economic, and health tradeoffs of decarbonization pathways for New England, USA

Amir M. Gazar<sup>1,2</sup>, Chloe Jackson<sup>3</sup>, Georgia Mavrommati<sup>3</sup>, Rich B. Howarth<sup>4</sup>, Ryan S.D. Calder<sup>1,2,5\*</sup>

<sup>1</sup> Department of Population Health Sciences, Virginia Tech, Blacksburg, VA, 24061, USA

<sup>2</sup> Global Change Center, Virginia Tech, Blacksburg, VA, 24061, USA

<sup>3</sup> School for the Environment, University of Massachusetts Boston, Boston, MA 02125, USA

<sup>4</sup> Environmental Program, Dartmouth College, Hanover, NH, 03755, USA

<sup>5</sup> Department of Civil and Environmental Engineering, Duke University, Durham, NC, 27708, USA

\* Contact: [rsdc@vt.edu](mailto:rsdc@vt.edu).

#### Supplemental methods

1.	Decarbonization pathways and scheduling of new generation and retirements .....	3
2.	Model formulation .....	5
2.1.	Notation .....	5
2.1.1.	Sets and indices .....	5
2.1.2.	Parameters .....	5
2.1.3.	State and decision variables.....	5
2.2.	Demand .....	6
2.3.	Low-carbon generation .....	6
2.3.1.	Wind and solar generation.....	6
2.3.2.	Nuclear, domestic hydropower, and biomass generation.....	7
2.4.	Commercial battery storage .....	7
2.4.1.	Power cap from inverter and duration .....	7
2.4.2.	State update with retention and symmetric round trip.....	8
2.5.	Imports from other jurisdictions.....	8
2.5.1.	Imports netting logic (headroom allocation) .....	9
2.6.	Fossil fuel generation .....	10
2.6.1.	System level fossil requirement (aggregate, pre unit-level dispatch).....	11
2.6.2.	Per unit constraints and ramping (two pass adjustment) .....	12
2.6.3.	Facility level probabilistic sampling.....	12
2.7.	Curtailments and unmet demand.....	13
2.7.1.	Energy balance .....	13
2.7.2.	Curtailments and shortages.....	13
2.8.	CAPEX, FOM,VOM, and fueling costs.....	15
2.9.	Costs of imports from other jurisdictions.....	16
2.10.	Greenhouse gas emissions costs.....	17
2.11.	Air pollutant emissions costs.....	17
2.12.	Unmet demand penalty costs.....	18
2.13.	Direct costs .....	19
2.14.	Indirect costs .....	19
2.15.	Total system cost and NPV .....	19
3.	Monte Carlo analysis .....	20
4.	Model validation .....	20
4.1.	Total annual load calculation .....	20
4.2.	Goodness-of-fit metric .....	21
5.	Accounting for costs of increased imports of Canadian hydroelectric power .....	21

## Supporting figures

Figure S1: Illustration of how direct and indirect costs are allocated for imports of Canadian hydropower under two accounting methods. ....	22
Figure S2: Pay for performance rates and the value of lost load curve used by ISO-NE.....	24
Figure S3: Modeled electricity generation by resource (top panels) and battery discharge (bottom panels) for the eight decarbonization pathways from 2025 to 2050 (simulation #1) .....	25
Figure S4: Deterministic validation of generation trajectories (2025–2050). ....	26
Figure S5: Spearman correlation matrix showing pairwise relationships between uncertain model parameters and outputs. ....	27
Figure S6: Normalized global importance of uncertainty sources for cost-related variables. ....	28

## Supporting tables

Table S1: Build-out/retirement by 2050 of technologies under each decarbonization pathway (yearly schedule provided in Supplemental Information (SI) Table S2). ....	3
Table S2: Yearly capacity schedule for eight decarbonization pathways (2025–2050).....	30
Table S3: Average annual (2022–2050) electricity generation capacity changes under a no Inflation Reduction Act scenario .....	38
Table S4: Facility and unit-level operational characteristics, ramp category, retirement timelines, and emissions factors for all fossil fuel power plant facilities in New England.....	39
Table S5: Externally derived parameters for the generation expansion model .....	51
Table S6: Externally derived parameters for cost calculations .....	52
Table S7: Summary of fuel-specific emission factors, including non-biogenic CO <sub>2</sub> -eq for CH <sub>4</sub> and N <sub>2</sub> O emissions, PM rates and ratios, and estimated CO and VOC emissions .....	53
Table S8: Facility specific social costs of air emissions (2024-USD tonne <sup>-1</sup> ).....	54
Table S9: Methane emissions from Canadian reservoirs and relevant facilities .....	65
Table S10: Net present value of costs (in billions of 2024 USD, discounted at 1.5%) across eight decarbonization pathways .....	66
Table S11: Net present value of costs (in billions of 2024 USD, discounted at 2%) across eight decarbonization pathways .....	67
Table S12: Net present value of costs (in billions of 2024 USD, discounted at 2.5%) across eight decarbonization pathways .....	68
Table S13: Net present value of costs (billions of 2024 USD, discounted at 2%) for All-Options Pathway.....	69
Table S14: Net present value of air emission costs (in millions of 2024 USD, discounted at 1.5%) across eight decarbonization pathways .....	70
Table S15: Net present value of air emission costs (in millions of 2024 USD, discounted at 2%) across eight decarbonization pathways .....	72
Table S16: Net present value of air emission costs (in millions of 2024 USD, discounted at 2.5%) across eight decarbonization pathways .....	74
Table S17: Environmental impact metrics of energy technologies across scenarios .....	76

## 1. Decarbonization pathways and scheduling of new generation and retirements

We model pathways already proposed and evaluated by ISO-NE in order to (1) validate our methodology by comparing select endpoints shared between this analysis and analysis previously undertaken by ISO-NE and (2) provide more detailed information on the spatial and temporal distribution of costs and benefits for pathways already known to be of interest. This includes pathways A, B1, B2 and B3. We also model pathways not previously considered by ISO-NE but of interest to local stakeholders and/or the research community. This includes pathways C1, C2, C3 and D, including build-out of small modular nuclear reactors. As described in the main text, the model does not optimize a portfolio based on an objective function but calculates the direct and indirect cost tradeoffs associated with prescribed pathways.

Pathway A represents “status quo” where no new generation or transmission assets are built and demand is satisfied by dispatching existing resources. No generators are retired over the period of analysis. Pathways B1, B2, and B3 were proposed by ISO-NE as alternative pathways based on increased intertie capacity with Canada (constrained in B2) and increased offshore wind (constrained in B3). ISO-NE considers that new construction of hydroelectric generation capacity in Quebec (on the order of ~9 GW, according to recent estimates by ISO-NE) would be necessary to provide the level of exports in B3 (Commonwealth of Massachusetts, 2020). The ~9 GW build-out aligns with Hydro-Québec’s stated potential and provides a plausible high-capacity benchmark for intertie feasibility.

Table S1: Build-out/retirement by 2050 of technologies under each decarbonization pathway (yearly schedule provided in Supplemental Information (SI) Table S2).

Technology	Pathway							
	A	B1	B2	B3	C1	C2	C3	D
<b>New interties with Quebec</b>	None	+4.1 GW	None	+6 GW	None	None	+4.1 GW	+4.1 GW
<b>New hydropower reservoirs in Quebec</b>	None	None	None	~9 GW reservoir	None	None	None	None
<b>New offshore wind</b>	None	+33 GW	As required to balance 10 GW growth in demand by 2050 (>41 GW)	+28.5 GW	None	+33 GW	+28.5 GW	+1.5 GW
<b>New small modular reactors</b>	None	None	None	None	+42 GW	+4.2 GW	+2.1 GW	None
<b>New natural gas power plants</b>	None	None	None	None	None	None	None	+20 GW
<b>Forced coal retirements</b>	None	All retired by 2030	All retired by 2030	All retired by 2030	All retired by 2030	All retired by 2030	All retired by 2030	None
<b>New solar</b>	None	+64 GW	+64 GW	+64 GW	None	+64 GW	+64 GW	+ 14 GW
<b>New onshore wind</b>	None	+12 GW	+12 GW	+12 GW	None	+12 GW	+12 GW	+ 5 GW
<b>Battery storage</b>	None	+16.4 GW	+16.4 GW	+16.4 GW	None	+16.4 GW	+16.4 GW	+16.4 GW

All these pathways represent plausible bounds of alternative futures rather than forecasts.

Pathways C1, C2, and C3 are based on deployment of small modular nuclear reactors (SMRs), a pathway not currently envisioned by ISO-NE but of increasing interest to the public, advocacy organizations, policymakers, and other stakeholders. Recent developments such as partial reactivation of Three Mile Island in Pennsylvania to supply energy for a Microsoft data center and interest by other companies such as Amazon and OpenAI point to a likely future for SMRs, but these are not widely considered in other studies or in state/utility energy plans (Bowman, 2024; Castelveccchi, 2024; Gazar, 2023; L’Her et al., 2024; Vanatta et al., 2024). Scheduling of new generators is described below.

Pathway D considers construction of new natural gas plants and is not a pathway retained by ISO-NE but may nonetheless be plausible under certain changes in energy policy, for example, rescission or expiry of credits or incentives under the Inflation Reduction Act (Gerrard, 2024; Osaka, 2024; U.S. EIA AEO, 2023). We assume the following capacity build-up for this pathway includes 1.5 GW offshore wind, 5 GW onshore wind and 14 GW of solar PV. This pathway assumes addition of 20 GW of natural gas capacity with technical specifications drawn from CPV Towantic Energy Center combined cycle power plant located in Oxford, CT (nameplate capacity 565.5 MW), the most recently (operating started in 2018) constructed natural gas facility in New England.

Across all pathways, we assume that existing large nuclear power plants and natural gas plants will be maintained through 2050. Pathways A and D have no retirements, following the U.S. EIA “No IRA [Inflation Reduction Act] Scenario”. Details from this U.S. EIA scenario are included in SI Table S2.

The magnitudes and locations of new onshore wind, offshore wind, and solar capacity were derived from ISO-NE resource-adequacy studies and constrained to realistic coastal and inland siting densities. Offshore capacity was distributed by ISO-NE among federally leased areas off Massachusetts, Rhode Island, and Maine, whereas onshore wind and solar additions were allocated according to land availability and historical project density.

Pathways other than A and D consider likely retirements of existing generators over the period 2025 to 2050, including those already scheduled. This includes a complete phase-out of coal-fired power plants and the retirement of 75% of conventional oil-fired units, including dual-fuel facilities. This corresponds to the schedule established in ISO-NE’s modeling assumptions in (Commonwealth of Massachusetts, 2020).

We considered that 75% of oil-fired units (5,250 MW) would be retired by 2030 (Commonwealth of Massachusetts, 2020) by filtering facilities using oil as their primary fuel type, calculating the 75<sup>th</sup> percentile of their real average capacity factor, identifying those at or below that threshold, and assigning them a 2030 retirement date, thereby ensuring less-utilized (higher marginal cost) facilities are retired first.

Additionally, plants are retired when they reach the end of their economic lifetime: 75 years for coal-fired plants, 45 years for wood-fired plants, and 55 years for other fossil fuel plants based on NREL’s end of lifetime estimates for these plants (NREL, 2024). These ages are calculated based on data reported to the United States Environmental Protection Agency (U.S. EPA) Emissions & Generation Resource Integrated (eGRID) database and to the U.S. Energy Information Agency (EIA) via U.S. EIA Form 860 (U.S. EIA 860, 2023; U.S. EPA eGrid, 2022). Facility specific retirement details are included in SI Table S3.

## 2. Model formulation

### 2.1. Notation

#### 2.1.1. Sets and indices

$t \in \mathcal{T}$ : hours

$g \in \mathcal{G} = \{\text{Solar, Wind}_{\text{onshore}}, \text{Wind}_{\text{offshore}}, \text{Nuclear, Hydro, Biomass, SMR, Fossil}\}$

$u \in \mathcal{U}$ : fossil fuel-based generating units

$j \in \mathcal{J} = \{\text{HQ, NYISO, NBSO}\}$ : interties to neighboring regions

$\omega \in \Omega$ : Monte Carlo draw

$y \in Y$ : year between 2025 and 2050 (for Social Cost of Carbon schedule)

$s \in \mathcal{S}$ : pathways

#### 2.1.2. Parameters

$D_t$ : demand (MWh)

$\text{Cap}_{g,t}$ : installed capacity (MW)

$\text{CF}_{g,t}(\omega) \in [0,1]$ : capacity factor (percentile mapped to historical variable hourly capacity factors)

$\text{Cap}_{j,t}^{\text{LT}}, \text{Cap}_{j,t}^{\text{spot}}$ : import capacities for long-term contracts (LT) and spot-market (spot) (MW)

$\bar{I}_t$ : imports ceiling (MWh)

$\eta \in (0,1)$ : one-way efficiency

$\rho \in (0,1]$ : hourly retention factor

$E_{\max,t}$ : storage energy cap (MWh)

$P_{\max,t}$ : storage inverter or power cap (MW)

$P_u, \bar{P}_u$ : unit min and max generation capacity (MW)

$\bar{R}_u$ : ramp limit (maximum generation dispatch limit (MWh))

$\chi_{u,t} \in \{0,1\}$ : availability or retirement

$\kappa_j$ : import price (USD/MWh)

$f_u, v_g$ : fuel and VOM rates (USD/MWh)

$s_{k,y}^{\text{GHG}}$ : social cost for GHG  $k \in \{\text{CO}_2, \text{CH}_4, \text{N}_2\text{O}\}$  in year  $y$  (2024 – USD per tonne)

$\hat{v}^k$ : damage factor for pollutant  $k \in \{\text{CO}, \text{NO}_2, \text{SO}_2, \text{PM}_{2.5}, \text{PM}_{10}, \text{VOC}\}$  (2024 – USD per tonne)

$\pi_{\text{short}}$ : value of lost load (USD/MWh)

$r, y_0$ : discount rate, base year

#### 2.1.3. State and decision variables

$G_{g,t} \geq 0$ : non fossil generation (MWh)

$G_{u,t} \geq 0$ : fossil unit generation (MWh)

$I_{j,t}^{\text{LT}}, I_{j,t}^{\text{spot}} \geq 0$ : imports (MWh)

$\text{SOC}_t \in [0, E_{\max,t}]$ : state of charge (MWh)

$c_t, d_t \geq 0$ : charge and discharge (MWh)

$\text{Curt}_t, \text{Short}_t \geq 0$ : curtailment and shortage (MWh)

## 2.2. Demand

Hourly demand forecasts for New England were obtained from the Commonwealth of Massachusetts via request under the Massachusetts Public Records Act. These data support the publicly available decarbonization roadmap (Commonwealth of Massachusetts, 2020) and correspond to the ISO-NE 2025-2050 “High Electrification” pathway. This pathway assumes a medium level of flexibility in end-use loads, including incentivized consumer behavior to reduce consumption during peak demand (e.g., 53,715 MW on January 24<sup>th</sup>, 2050 and total demand in 2050 of 203 TWh). Raw data for all demand pathways are provided in the SI to allow for reanalysis under alternative forecasts.

We implement a load duration curve approach utilizing the full hourly demand profile, totaling 227,880 timesteps for the period from 2025 to 2050, consistent with the methodology used by other recent energy models (Dagoumas & Koltsaklis, 2019). The model can also be run using less computationally demanding representative demand curves or individual time slices if required.

## 2.3. Low-carbon generation

Low-carbon energy sources are dispatched first to satisfy hourly demand as a function of installed capacity and capacity factor (either deterministic or drawn from a probability distribution ( $\omega \in \Omega$ )). The distribution is jointly distributed for solar and onshore and offshore wind as described in SI Section 2.3.1 and independent for others. Generally, hourly renewable generation at timestep  $t$  ( $G_t$ ) is the sum of installed capacity (Cap) multiplied by capacity factors (CF) for each low-carbon technology. Low-carbon technologies ( $\mathcal{G}\{\text{lowcarbon}\}$ ) are solar, onshore wind ( $\text{wind}_{\text{on}}$ ), offshore wind ( $\text{wind}_{\text{off}}$ ), nuclear, hydropower, biomass, and small modular nuclear (SMR). This is formalized in Equations 1 to 8.

$G_t^{\text{lowcarbon}}$	$\equiv$	$\sum_{g \in \mathcal{G}\{\text{lowcarbon}\}} G_{g,t}$	<i>Eq. 1</i>
$G_{\text{Solar},t}$	$=$	$\text{Cap}_{\text{Solar},t} \text{CF}_{\text{Solar},t}(\omega)$	<i>Eq. 2</i>
$G_{\text{Wind}_{\text{on}},t}$	$=$	$\text{Cap}_{\text{Wind}_{\text{on}},t} \text{CF}_{\text{Wind}_{\text{on}},t}(\omega)$	<i>Eq. 3</i>
$G_{\text{Wind}_{\text{off}},t}$	$=$	$\text{Cap}_{\text{Wind}_{\text{off}},t} \text{CF}_{\text{Wind}_{\text{off}},t}(\omega)$	<i>Eq. 4</i>
$G_{\text{Nuclear},t}$	$=$	$\text{Cap}_{\text{Nuclear},t} \text{CF}_{\text{Nuclear}}$	<i>Eq. 5</i>
$G_{\text{Hydro},t}$	$=$	$\text{Cap}_{\text{Hydro},t} \text{CF}_{\text{Hydro}}$	<i>Eq. 6</i>
$G_{\text{Biomass},t}$	$=$	$\text{Cap}_{\text{Biomass},t} \text{CF}_{\text{Biomass}}$	<i>Eq. 7</i>
$G_{\text{SMR},t}$	$=$	$\text{Cap}_{\text{SMR},t} \text{CF}_{\text{SMR}}$	<i>Eq. 8</i>

In hours where demand can be satisfied with available low-carbon sources and/or required ramping of fossil fuels to meet future demand (SI Section 2.6), excess energy is used to charge batteries within technical constraints (SI Section 2.4). If this is inadequate to dissipate excess energy, then wind and solar are curtailed. Considering no meaningful historical exports out of New England is recorded we do not consider exports to other jurisdictions in the future as part of this model. However, in order to consider such exports can be ) considered as sold to other jurisdictions within historical constraints by assigning a negative value to imports.

### 2.3.1. Wind and solar generation

Contribution of wind (onshore and offshore) and solar resources is determined by multiplying installed capacity (increasing between 2025 and 2050 according to the Pathway retained as described in SI Section 1) by a capacity factor. Capacity factors are described by probability distributions specific to each hour within a calendar year and are calculated using simulated capacity factors supplied by ISO-NE (ISO-NE, 2024a) as described in more detail in our methods on Monte Carlo simulation (SI Section 3).

Wind and solar correlations across weather years are maintained through covariance-based sampling of probability distributions (SI Section 3). Capacity-factor distributions are location-specific for wind and solar but uniform for hydropower (SI Table S9) given limited intra-annual variability across ISO-NE facilities.

### 2.3.2. *Nuclear, domestic hydropower, and biomass generation*

Data from the National Renewable Energy Laboratory's Annual Technology Baseline (NREL ATB) 2024 are used to derive deterministic capacity factors for large nuclear (0.93), domestic hydropower (0.56), and biomass (0.60) generators (NREL, 2024). These are dispatched following wind and solar due to low marginal cost at timesteps where renewables alone cannot satisfy demand (Commonwealth of Massachusetts, 2020). Similarly, we selected the 300 MWe SMR with capacity factor of 0.9 since this is currently the only SMR in the NREL portfolio projected to be available from 2030 (NREL, 2024).

Across pathways, existing large nuclear generation accounts for 27.29 TWh per year by 2050 (13% of annual demand), domestic hydropower accounts for 4.42 TWh (2% of demand), and biomass accounts for 2.10 TWh (1.03% of demand). In pathways C1, C2, and C3, investments in SMRs lead to potential maximum generation of 331.12 TWh, 33.11 TWh, and 16.56 TWh per year (representing 163%, 16%, and 8% of annual demand) by 2050, respectively.

## 2.4. Commercial battery storage

We model battery storage with symmetric charge and discharge efficiencies of 92% in each direction, yielding an 85% round-trip efficiency, meaning that 85% of the input energy is effectively stored and later available for use (NREL, 2024). State-of-charge dynamics follow this formulation, ensuring that energy accounting correctly represents storage losses. Discharge occurs only when renewable generation plus imports are insufficient to meet demand, and simultaneous charge–discharge is disallowed (NREL, 2024). We model the operation of commercial lithium-ion battery storage systems by utilizing surplus generation to charge the batteries during timesteps when generation exceeds demand. This occurs at hours when demand is exceeded by the supply of low-carbon energies and/or fossil fuel sources ramping upward to meet future demand. Conversely, batteries are discharged during timesteps when renewable generation and imports are insufficient to meet demand.

To determine the maximum charge and discharge rates, we adopt an inverter-to-storage ratio of 1.67 (i.e., fast charging and discharging), as recommended by the NREL in the 2024 ATB (NREL, 2024). Long-duration energy storage (LDES) is represented with an explicit duration parameter (default = 8 hours) that can be extended by pathway flag. Unlike short-duration systems, LDES may not fully cycle each day; state-of-charge retention between cycles is modeled via an efficiency-weighted persistence term. This captures dispatch flexibility without making duration a decision variable.

### 2.4.1. *Power cap from inverter and duration*

Storage dispatch is bounded by a power limit derived from the installed energy capacity and the chosen duration, as well as by the installed inverter capacity. Let nameplate energy capacity at time  $t$  be  $E_{\max,t} \equiv \text{Cap}_t^{\text{stor}}$  (MWh) and duration be  $H^{\text{dur}}$  (h). The maximum charge or discharge power is therefore the minimum of the duration-implied power rating and the inverter limit:

$$P_{\max,t} = \min \left\{ \frac{E_{\max,t}}{H^{\text{dur}}}, \text{Inv}_t \right\}, P_{\max,t} \geq 0 \quad \text{Eq. 9}$$

#### 2.4.2. State update with retention and symmetric round trip

Battery state of charge (SOC) evolves according to one-way efficiency, hourly retention, and physical bounds. Let  $\eta_{rt}$  denote round-trip efficiency and  $\eta = \sqrt{\eta_{rt}}$  the symmetric one-way efficiency. Let  $\rho$  denote the hourly retention factor. Then SOC at time  $t$  is updated from  $t - 1$  as:

$$\text{SOC}_t = \min \left\{ \max \left( \rho \text{SOC}_{t-1} + \eta c_t - \frac{1}{\eta} d_t, 0 \right), E_{\max,t} \right\} \quad \text{Eq. 10}$$

Charging and discharging power are bounded by the power cap:

$$0 \leq c_t \leq P_{\max,t}, 0 \leq d_t \leq P_{\max,t}$$

Curtailed-only charging guard (battery may only charge from otherwise excess low-carbon supply):

$$c_t \leq \max \left( 0, G_t^{\text{low carbon}} + I_t - D_t \right)$$

Note on battery daily reset (optional). If multi day carry is disabled, set  $\text{SOC}_t \leftarrow 0$  at local midnight before applying retention.

We also define the modeled SOC change attributable to charging and discharging as:

$$\Delta_t^{\text{bat}} = \eta c_t - \frac{1}{\eta} d_t \quad \text{Eq. 11}$$

#### 2.5. Imports from other jurisdictions

ISO-NE imports energy from Hydro-Québec, New York ISO, and the New Brunswick System Operator (NBSO). Decarbonization pathways B1, B3, C3 consider increased imports from Quebec with (B3) or without (B1 and C3) expanded generation in Quebec. Recently negotiated import agreements between Quebec and New York/Massachusetts commit to a constant transmission schedule with fixed prices for a period of approximately 20–25 years (see NECEC’s 20-year fixed-price contracts (Central Maine Power Company, 2019; Hamlen & Lenzen, 2024) and CHPE’s 25-year benefit framework (CHPEXpress, 2021; Naldal, 2022)). Once agreed, the marginal price of these imports is zero, and so the model dispatches these resources ahead of fossil fuels. In these pathways, long-term contracts are to account for the all-new imports, therefore subject to a fixed capacity factor. We assume all new imports from Quebec under all pathways are under a fixed-price contract.

For other imports negotiated on the short-term spot market with variable costs, we use historical data for the period 2011 to 2023 to simulate hourly transmission and prices. We calculate historical variable hourly capacity factors by dividing real imports by available transmission capacity and apply that to the available transmission capacity available in the period 2025–2050. Transmission capacity for spot-market imports (unlike for long-term contractual imports as described above) is held constant for pathways A, B1-3, C1-3 and D. Historical data are used to develop prior distributions, which are randomly sampled. In the event that fossil fuel generation (SI Section 2.6) when added to the other available capacity is not adequate to satisfy hourly demand, spot market imports are resampled to select the value that will satisfy demand (within the constraints of historical maxima). If available fossil fuel resources (SI Section 2.6) and import capacity, when combined with other sources, cannot satisfy hourly demand, then an unmet demand penalty is applied (SI Section 2.7). Posterior distributions are saved and analyzed.

For Pathways B1, C3, and D, investments in transborder infrastructure lead to average imports up to 60.54 TWh per year (30% of annual demand) by 2050, respectively. For Pathway B3 these investments lead to average imports up to 76.35 TWh (38% of annual demand). For other Pathways (including “status quo” Pathway A), average imports from other jurisdictions account for 26.42 TWh per year (13% of annual demand).

Let  $\bar{C}F^{imp} = 0.95$  denote the maximum import capacity factor. Eq. 12 defines long-term contractual imports  $I_{j,t}^{LT}$  from jurisdiction  $j$  at time  $t$  as a fixed fraction of available long-term transmission capacity  $Cap_{j,t}^{LT}$ , reflecting constant schedules under fixed-price agreements. Eq. 13 bounds spot-market imports  $I_{j,t}^{spot}$  by available spot-market transmission capacity  $Cap_{j,t}^{spot}$  and a stochastic capacity factor  $CF_{j,t}^{spot}(\omega)$  drawn from historical data. Eq. 14 defines total imports  $I_t$  as the sum of long-term and spot-market imports across all jurisdictions. Finally, Eq. 15 imposes a system-wide upper bound on total imports  $\bar{I}_t$ , determined by aggregate transmission capacity and the maximum import capacity factor  $\bar{C}F^{imp}$ .

$I_{j,t}^{LT}$	=	$Cap_{j,t}^{LT} \cdot \bar{C}F^{imp}$	<b>Eq. 12</b>
$0 \leq I_{j,t}^{spot}$	$\leq$	$Cap_{j,t}^{spot} CF_{j,t}^{spot}(\omega)$	<i>Eq. 13</i>
$I_t$	=	$\sum_j (I_{j,t}^{LT} + I_{j,t}^{spot})$	<i>Eq. 14</i>
$I_t \leq \bar{I}_t$	=	$\bar{C}F^{imp} \sum_j (Cap_{j,t}^{LT} + Cap_{j,t}^{spot})$	<i>Eq. 15</i>

### 2.5.1. Imports netting logic (headroom allocation)

Eq. 14 defines net imports  $I_t^{net}$  prior to calibration. When a system shortfall  $Short_t > 0$  exists, imports are increased up to the remaining import headroom  $\bar{I}_t - I_t$ ; otherwise, imports are limited to the minimum required to meet residual demand after low-carbon generation, other generation  $G_{(u,t)}$ , and battery discharge  $d_t$ . In the calibration pass, any additional imports required  $\Delta I_t$  are allocated across interties based on available headroom, which is defined as unused import capability up to the maximum allowable capacity factor. Eq. 15 and Eq. 16 define

long-term and spot-market headroom  $H_{(j,t)}^{LT}$  and  $H_{(j,t)}^{spot}$  as the difference between maximum feasible imports and realized imports on each intertie. Eq. 17 and Eq. 18 allocate  $\Delta I_t$  sequentially to Hydro-Québec long-term and then spot-market imports, reducing the remaining requirement after each step. Eq. 19 enforces zero spot-market headroom for NYISO and NBSO under the assumed import structure.

Before calibration:

$$I_t^{\text{net}} = \begin{cases} I_t + \min(\text{Short}_t, \bar{I}_t - I_t), & \text{Short}_t > 0 \\ \min\left\{I_t, \max\left(0, D_t - \left(G_t^{\text{low carbon}} + \sum_u G_{u,t} + d_t\right)\right)\right\}, & \text{Short}_t = 0 \end{cases} \quad \text{Eq. 14}$$

In the calibration pass, any extra imports required  $\Delta I_t = \max(0, I_t^{\text{net,cal}} - I_t)$  are allocated to interties by available headroom to the max CF:

$$H_{j,t}^{LT} = \text{Cap}_{j,t}^{LT} \bar{CF}^{\text{imp}} - I_{j,t}^{LT} \quad \text{Eq. 15}$$

$$H_{j,t}^{spot} = \text{Cap}_j^{spot} CF_{j,t}^{spot}(\omega) - I_{j,t}^{spot} \quad \text{Eq. 16}$$

Then sequentially (LT then spot; then HQ):

$$\Delta I_{HQ,t}^{LT} = \min(\Delta I_t, H_{HQ,t}^{LT}), \Delta I_t \leftarrow \Delta I_t - \Delta I_{HQ,t}^{LT} \quad \text{Eq. 17}$$

$$\Delta I_{HQ,t}^{spot} = \min(\Delta I_t, H_{HQ,t}^{spot}), \Delta I_t \leftarrow \Delta I_t - \Delta I_{HQ,t}^{spot} \quad \text{Eq. 18}$$

NYISO and NBSO do not have spot CF under our assumptions:

$$H_{NYISO,t}^{spot} = H_{NBSO,t}^{spot} = 0 \quad \text{Eq. 19}$$

## 2.6. Fossil fuel generation

The difference between hourly demand (SI Section 2.2) and generation from wind and solar (SI Section 2.3.1), domestic hydropower, nuclear, and biomass (SI Section 2.3.2), battery discharges (SI Section 2.4), and imports from neighboring jurisdictions (SI Section 2.5) is accounted for by fossil fuel generation. The importance of potential fossil fuel generation by 2050 depends on the pathway considered as described in SI Section 1 and is as high as 107.6 TWh (representing 53% of annual demand) for pathways A and D and as low as 73.7 TWh (representing 36.2% of annual demand) for all other pathways. Additionally, in pathway D the potential generation of newly built natural gas plants accounts for 151.6 TWh (74.6% of the annual demand) by 2050.

The hourly fossil fuel demand in a given timestep is the sum of (1) demand unmet by renewables and other low-marginal-cost generation and imports described above and (2) increased generation necessary to respect ramping constraints to meet future demand. Ramping is carried out in accordance with each generating unit's ramping constraints. Each unit maintains a minimum generation level at all times, from which it ramps up as needed when demand increases. By using the look-ahead approach, if an upcoming demand is observed, we begin ramping sooner so the unit can reach maximum capacity precisely when the peak occurs.

Excess energy produced in ramping hours is balanced by (1) charging batteries (if available), (2) and, (2) curtailing wind and solar for that hour if (1) is not sufficient to dissipate excess energy.

We developed a database of 4,633 generating units at 1,379 electric utility generating facilities across the United States cross-referenced to hourly generation and CO<sub>2</sub>, NO<sub>x</sub>, and SO<sub>2</sub> emissions data for the period from 2013 to 2023, inclusively, from the U.S. EPA Clean Air Markets Program Data (CAMPD) API (U.S. EPA 2024). Emissions of CO, N<sub>2</sub>O, PM<sub>10</sub>, PM<sub>2.5</sub>, and VOC are determined by technology-specific emissions factors tabulated in SI Table S6. For all generating units and all generation and emissions variables, synthetic hourly probability distributions were fitted to the data for the period 2011 to 2023 to calculate 1<sup>st</sup> to 99<sup>th</sup> percentiles to be stochastically sampled (or run deterministically at the 50th percentile). Hourly generation in New England is cross-referenced with nameplate capacities from the EPA’s CAMPD, and if the resulting capacity factor exceeds 1 (indicating a misreported capacity), we correct it using EIA 860 or eGrid data (U.S. EIA 860, 2023; U.S. EPA CAMPD, 2024; U.S. EPA eGrid, 2022). This has been completed for all generators in the database across all regions of the U.S. All relevant data has been archived in storage managed by Virginia Tech ARC and is accessible via the supplemental information.

In New England, approximately 7% of generating units accounting for 1.81% of all installed capacity were not represented in the CAMPD database we used to develop hourly generation and emissions distributions. For these facilities, distributions were developed by pooling units of the same technology and, where nameplate capacity was reported, of the same nameplate capacity range ( $\pm 20$  MW). Technology groups were defined as combinations of unit types (e.g., “boiler”, “combined cycle”), and primary fuel type (e.g., “coal”, “natural gas”). This approach was also used to fill in emissions factors for CO<sub>2</sub>, NO<sub>x</sub> and SO<sub>2</sub> (3.24%, 1.81% and 8.98% of all installed capacity in New England respectively).

Hour-specific historical generation data is evaluated to ensure that it is mathematically possible to satisfy demand at a given timestep within historical maxima for that hour. Ensuring that historical maxima are not exceeded ensures that the model implicitly captures constraints such as within-grid bottlenecks or other technical constraints not explicitly modeled. If available fossil fuel resources cannot satisfy demand at a given timestep when added to previously sampled sources, then all generators are assigned generation corresponding to the historical maximum for the corresponding hour, and batteries are discharged subject to the discharge constraint. If these are not sufficient to meet demand, then imports from other jurisdictions (SI Section 2.5) are resampled (after verification that historical hourly maximum, when added to allocated generation and battery discharge, will satisfy demand). If historical hourly maximum fossil fuel generation and imports, when added to maximum battery discharge and available renewable supply, is insufficient to meet demand, then imports are also assigned the maximum historical hour-specific value, and an unmet demand penalty is applied (SI Section 2.7). Posterior distributions for all generation (and imports) are saved.

#### 2.6.1. *System level fossil requirement (aggregate, pre unit-level dispatch)*

Eq. 20 and Eq. 21 define the system-level fossil fuel requirement prior to unit-level dispatch. Eq. 20 defines residual fossil demand  $R_t^{fos}$  as unmet hourly demand after accounting for low-carbon generation  $G_t^{lowcarbon}$ , imports  $I_t$ , and battery discharge  $d_t$ . Eq. 21 constrains aggregate fossil generation across all fossil units  $u \in U$  to be nonnegative and bounded by the minimum of this

residual requirement and an exogenous hourly fossil envelope  $\bar{F}_t$ , which reflects legacy fleet availability derived from historical maximum–minimum fossil generation profiles with pathway-specific retirements.

$$R_t^{\text{fos}} = \max \{0, D_t - G_t^{\text{low carbon}} - I_t - d_t\} \quad \text{Eq. 20}$$

$$0 \leq \sum_{u \in \mathcal{U}} G_{u,t} \leq \min \{\bar{F}_t, R_t^{\text{fos}}\} \quad \text{Eq. 21}$$

For pathways without fossil retirements (Pathways A and D), the hourly fossil envelope  $\bar{F}_t$  is set equal to the historical hour-specific maximum fossil generation without retirements. For all other pathways,  $\bar{F}_t$  reflects pathway-specific retirements and is derived from historical hour-specific maximum fossil generation with retirements.

### 2.6.2. Per unit constraints and ramping (two pass adjustment)

Eq. 22 enforces unit availability and nameplate capacity limits, where  $\chi_{(u,t)} \in \{0,1\}$  is an availability indicator,  $\bar{P}_u$  is the minimum stable output, and  $\bar{P}_u$  is the maximum capacity; when  $\chi_{(u,t)} = 0$ , generation is zero. After initial hourly generation draws  $G_{(u,t)}^*$ , ramping constraints are enforced using a two-pass adjustment with hourly ramp budget  $\bar{R}_u$ . In the backward pass (Eq. 23), generation at  $t - 1$  is increased if necessary so that the change to  $t$  does not exceed  $\bar{R}_u$ . In the forward pass (Eq. 24), generation at  $t$  is adjusted relative to  $t - 1$  to prevent infeasible downward ramps. Finally, Eq. 25 applies minimum output constraints by setting adjusted generation  $G_{(u,t)}^{\text{adj}}$  to at least the unit's minimum stable output  $\bar{P}_u$ , ensuring unit-level feasibility while preserving the sampled profile as closely as possible.

$$\chi_{u,t} \bar{P}_u \leq G_{u,t} \leq \chi_{u,t} \bar{P}_u \quad \text{Eq. 22}$$

The hourly ramp budget is defined as  $\bar{R}_u$  (MWh per hour). The algorithm enforces, after initial sampling:

$$\text{Backward pass:} \quad G_{u,t-1}^* \leftarrow \max(G_{u,t}^* - \bar{R}_u, G_{u,t-1}^*) \quad \text{Eq. 22}$$

$$\text{Forward pass:} \quad G_{u,t}^* \leftarrow \max(G_{u,t-1}^* - \bar{R}_u, G_{u,t}^*) \quad \text{Eq. 23}$$

Then we apply minimum output and rounding:

$$G_{u,t}^{\text{adj}} = \max \{G_{u,t}^*, \bar{P}_u\} \quad \text{Eq. 24}$$

### 2.6.3. Facility level probabilistic sampling

Eq. 25 defines the initial, unconstrained hourly generation  $G_{(u,t)}^{raw}$  for each unit  $u$ , which is drawn from a facility-specific empirical distribution conditioned on the day type and hour of day. Specifically, generation is sampled from the lookup table  $\text{Gen}_u^{tbl}$  using the calendar label  $\text{DayLabel}(t)$ , the hour index  $\text{Hour}(t)$ , and a probabilistic draw  $p_\omega$ . If the sum of raw generation across all units exceeds the system-level fossil envelope  $\bar{F}_t$ , generation is reduced prior to applying ramping constraints, either proportionally across units or by curtailing lowest-capacity-factor units first, to ensure  $\sum_u G_{(u,t)} \leq \bar{F}_t$ .

Each hour's unit generation  $G_{u,t}^{raw}$  is drawn from the facility distribution for draw  $\omega \in p_\omega$ :

$$\mathbf{G}_{u,t}^{raw} = \mathbf{Gen}_u^{tbl}(\mathbf{DayLabel}(t), \mathbf{Hour}(t), p_\omega) \quad \text{Eq. 25}$$

If  $\sum_u G_{u,t}^{raw} > \bar{F}_t$ , proportional (or low CF first) reductions ensure  $\sum_u G_{u,t} \leq \bar{F}_t$  before ramp passes.

## 2.7. Curtailments and unmet demand

When renewable energy generation exceeds the system's ability to use or store the energy (either by satisfying demand or charging batteries), output must be curtailed. Curtailments are calculated as the portion of renewable energy left unused after meeting demand and accounting for available battery storage capacity. We do not assign a monetary penalty for curtailment, consistent with other models (Frew et al., 2021).

When all available generation and import capacity is inadequate to satisfy hourly demand, an unmet demand penalty is applied. This approximates the economic costs of demand curtailment and/or brownouts and has been used by ISO-NE. Specifically, we consider a variable cost curve (SI Figure S2) used by ISO-NE to estimate unmet demand penalties (Potomac Economics, 2024).

### 2.7.1. *Energy balance*

Eq. 26 enforces hourly energy balance. On the supply side, total non-fossil generation  $\sum_{g \neq \text{Fossil}} G_{(g,t)}$ , imports  $I_t$ , battery discharge  $d_t$ , and fossil unit generation  $\sum_u G_{(u,t)}$  must equal total demand  $D_t$  plus energy absorbed by battery charging  $c_t$ , renewable curtailment  $\text{Curt}_t$ , and unmet demand  $\text{Short}_t$ .

$$\sum_{g \neq \text{Fossil}} G_{g,t} + I_t + d_t + \sum_u G_{u,t} = D_t + c_t + \mathbf{Curt}_t + \mathbf{Short}_t \quad \text{Eq. 26}$$

### 2.7.2. *Curtilments and shortages*

Curtailment occurs when low-carbon generation exceeds the system's ability to absorb energy through demand satisfaction or battery charging. Unmet demand occurs when all available generation, battery discharge, and imports are insufficient to satisfy hourly demand. These quantities are represented as slack variables in the system energy balance.

Eq. 26 enforces hourly energy balance. Eq. 27 and Eq. 28 formally define curtailment  $Curt_t$  and unmet demand  $Short_t$  as nonnegative residuals that close the balance. Eq. 29 defines a diagnostic balance residual  $BalRes_t$ , which must be approximately zero and is used to verify numerical consistency.

After unit-level fossil dispatch is finalized, total fossil generation is recomputed (Eq. 30), and the model iterates over battery storage and imports to restore system-level consistency. Battery state of charge and charging and discharging flows are recalculated subject to the same technical constraints (Eq. 31), and imports are reallocated using the available headroom. This procedure yields calibrated net imports  $I_t^{net,cal}$ , curtailment  $Curt_t^{cal}$ , unmet demand  $Short_t^{cal}$ , and an updated diagnostic residual  $BalRes_t^{cal}$ , which is reported for the first calibration pass.

$$\mathbf{Curt}_t = \max \{0, G_t^{\text{low carbon}} + I_t + \sum_u G_{u,t} - D_t - c_t\} \quad \text{Eq. 27}$$

$$\mathbf{Short}_t = \max \{0, D_t - G_t^{\text{low carbon}} - I_t - d_t - \sum_u G_{u,t}\} \quad \text{Eq. 28}$$

Diagnostics residual must approximate to  $\approx 0$ :

$$\mathbf{BalRes}_t = \left( G_t^{\text{low carbon}} + I_t + \sum_u G_{u,t} + d_t \right) - (D_t + c_t + \mathbf{Curt}_t + \mathbf{Short}_t) \quad \text{Eq. 29}$$

Iteration over battery storage and imports

Given finalized fossil dispatch  $G_{u,t}^{\text{adj}}$ , recompute battery and imports against

$$G_t^{\text{fos}} \equiv \sum_u G_{u,t}^{\text{adj}} \quad \text{Eq. 30}$$

Re-evaluate surplus or deficit on  $(G_t^{\text{low carbon}} + I_t)$ , rerun storage state with the same guards and caps, then recompute imports with headroom allocation to obtain  $I_t^{\text{net,cal}}$ , new  $Curt_t^{\text{cal}}$ ,  $Short_t^{\text{cal}}$ , and calibrated SOC or flows:

$$\mathbf{SOC}_t^{\text{cal}} = \min \left\{ \max \left( \rho \mathbf{SOC}_{t-1}^{\text{cal}} + \eta c_t^{\text{cal}} - \frac{1}{\eta} d_t^{\text{cal}}, 0 \right), E_{\max,t} \right\} \quad \text{Eq. 31}$$

$$\mathbf{Curt}_t^{\text{cal}} \geq 0, \mathbf{Short}_t^{\text{cal}} \geq 0, I_t^{\text{net,cal}} \leq \bar{I}_t$$

Report an updated residual  $BalRes_t^{cal}$  as for the first pass.

## 2.8. CAPEX, FOM, VOM, and fueling costs

We calculate the capital expenditures (CAPEX), fixed operations and maintenance (FOM), and variable operations and maintenance (VOM) and fueling costs associated with the pathways described in SI Section 1. For all technologies except SMRs, these calculations leverage annual data from the 2024 NREL ATB using mature market rates with a 30-year recovery period, pooled (uniform distribution) across different ATB technology cost scenarios (“conservative”, “moderate” and “advanced”). For SMRs, we use the 2024 NREL ATB nascent market rate, with a 30-year recovery period pooled across different ATB technology cost scenarios starting in 2030. This method of calculating CAPEX includes direct land acquisition costs.

CAPEX accrues in the year of deployment of a new generation or transborder transmission asset in each Pathway. FOM and VOM recur in every year of operation of a new or existing generation asset. FOM and VOM are not calculated for existing transmission assets because these do not vary across pathways. Costs are actualized to a net present value (NPV) at a discount rate specified by the user. We adopt a real discount rate of 2 %, consistent with U.S. EPA guidance (Office of Management and Budget, 2023), which use for results presented in the main text, and perform a sensitivity analysis for rates of 1.5 %, 2 %, and 2.5 %. While higher rates reduce absolute NPVs, the ranking of pathways remains unchanged (SI Tables S10–S12).

In this study, costs for new transmission infrastructure focus solely on lines connecting New England with other regional transmission organizations, notably cross-border connections with Quebec. CAPEX and FOM costs associated with transmission infrastructure are modeled based on the total capacity of the line (\$ per MW). Therefore, we use CAPEX (\$0.7–\$1.0 million per MW) and FOM (\$700 - \$1,000 per MW) values based on cost estimates for the New England Clean Energy Connect (roughly \$950 million for a 1200 MW line) reported by Calder et al. (2022) adjusted to 2024-USD. To capture uncertainty, following industry guidelines (e.g., Association for the Advancement of Cost Engineering International recommended practices for “Class 3” cost estimates), total CAPEX and FOM costs are drawn from a normal distribution with 95% confidence interval  $\pm 20\%$  around the mean reported figure (Dysert, 2016).

We calculate fueling costs by multiplying annual generation by a fueling cost per MWh generated. We utilized the 2024 NREL ATB data for large nuclear and biomass fuel costs, applying mature market rates with a 30-year recovery period and pooling results across various ATB scenarios. For SMRs, we employed the 2024 NREL ATB nascent market rate with a similar 30-year recovery period, also pooled across different ATB scenarios beginning in 2030. We derived the fossil generation fuel costs from the NREL ATB data (2021), pooling mature market rates with a 30-year recovery period across multiple ATB scenarios

As we describe in more detail in SI Section 5, there are conceptual disagreements on whether and how to account for Canada-side costs in U.S. decarbonization pathways that increase imports of Canadian hydropower. For the sensitivity analysis in which we apportion a fraction of Canada-side costs to a hydropower-dependent pathway (CAPEX and FOM costs incurred from new large Canadian hydropower plants in Quebec for Pathway B3(2)), we use estimates from ISO-NE reports, indicating an average cost of \$7,144  $kW^{-1}$  (2024-USD) (Commonwealth of

Massachusetts, 2020). Scaled to a class 5 dam, this equates to a range of 8.3 to 19.7 million-USD  $\text{MW}^{-1}$  (2024-USD) (Hollmann et al., 2014). This cost range reflects the variability in project locations, regulatory requirements, and construction complexities. Moreover, IEA (2010) estimates that hydropower FOM costs are 1.5% to 2.5% of CAPEX annually which is 0.12-0.49 million-USD  $\text{MW}^{-1} \text{ year}^{-1}$  (2024-USD).

Sources and details of probabilistic treatment for all direct cost parameters are provided in SI Table S5. A summary of all resulting costs (mean and range) is presented in SI Tables S10, S11 and S12. All costs are easily changed via user input to adapt this generalizable framework to other regions or countries.

Eq. 32 defines annual capital expenditures  $\text{Cost}_y^{\text{CAPEX}}$  as the sum of capital costs for all generation and transmission assets  $a$  commissioned in year  $y$ , where  $A_y^+$  denotes the set of newly deployed assets in that year. Eq. 33 defines annual fixed operations and maintenance costs  $\text{Cost}_y^{\text{FOM}}$  as the sum of fixed costs for all assets  $A_y$  operating in year  $y$ .

Eq. 34 defines hourly variable operations and maintenance costs  $\text{Cost}_t^{\text{VOM}}$  as the sum over all generation technologies  $g$  of technology-specific variable cost coefficients  $v_g$  multiplied by hourly generation  $G(g,t)$ . Eq. 35 defines hourly fueling costs  $\text{Cost}_t^{\text{fuel}}$  as the sum of unit-level fuel costs  $f_u$  multiplied by adjusted fossil generation  $G_{(u,t)}^{\text{adj}}$ , plus technology-level fuel costs for nuclear, biomass, and SMR generation, which are modeled at the aggregate technology level.

$$\text{Cost}_y^{\text{CAPEX}} = \sum_{a \in A_y^+} \text{CAPEX}_a \quad \text{Eq. 32}$$

$$\text{Cost}_y^{\text{FOM}} = \sum_{a \in A_y} \text{FOM}_{a,y} \quad \text{Eq. 33}$$

$$\text{Cost}_t^{\text{VOM}} = \sum_g v_g G_{g,t} \quad \text{Eq. 34}$$

$$\text{Cost}_t^{\text{fuel}} = \sum_u f_u G_{u,t}^{\text{adj}} + \sum_{g \in \{\text{SMR}, \text{Biomass}, \text{Nuclear}\}} f_g G_{g,t} \quad \text{Eq. 35}$$

## 2.9. Costs of imports from other jurisdictions

We estimated import costs from NYISO to be between  $0.78\text{¢}$  to  $2.41\text{¢}$   $\text{kWh}^{-1}$  (2024-USD) (uniform distribution) within the U.S. (DeSantis et al., 2021). For imports from Canada, using the CHPE (339 miles) as a reference, we estimate delivery costs to be approximately  $2.12\text{¢}$   $\text{kWh}^{-1}$  (2024-USD) (Calder et al., 2022). Notably, this figure represents an upper bound estimate, while a similar uncertainty range as applied for NYISO yields a lower bound estimate of  $0.78\text{¢}$   $\text{kWh}^{-1}$  (2024-USD). These import costs apply to new and existing infrastructure, and we apply these as standardized leveled import costs from other jurisdictions.

Eq. 36 defines hourly import costs  $\text{Cost}_t^{\text{imports}}$  as the sum over all importing jurisdictions  $j$  of jurisdiction-specific levelized import cost coefficients  $\kappa_j$  multiplied by total imports from that jurisdiction. Total imports include both long-term contractual imports  $I_{(j,t)}^{\text{LT}}$  and spot-market imports  $I_{(j,t)}^{\text{spot}}$ , ensuring that import costs are applied consistently to all electricity imported into the system regardless of contract structure.

$$\text{Cost}_t^{\text{imports}} = \sum_j \kappa_j (I_{j,t}^{\text{LT}} + I_{j,t}^{\text{spot}}) \quad \text{Eq. 36}$$

## 2.10. Greenhouse gas emissions costs

We use the U.S. EPA estimates for social cost of GHG emissions at 2% discount rate in 2025 as \$253.71 tonne- $\text{CO}_2^{-1}$ , \$2,423.48 tonne- $\text{CH}_4^{-1}$  and \$72,126.48 tonne- $\text{N}_2\text{O}^{-1}$  in 2024 USD, escalating over time (U.S. EPA, 2023). These costs are applied to fossil fuel GHG emissions described in SI Section 2.6. As described in SI Section 5, we consider two alternative methods for valuing methane impacts from new hydroelectric generation in Quebec. Both Scenarios B3(1) and B3(2) consider substantially increased hydroelectric imports such that new generation capacity is triggered. In Scenario B3(1), emissions are valued based on the installed capacity of the reservoir. In Scenario B3(2), they are valued based on the power imported at each timestep. We assume that hydropower imports in other pathways are too low to trigger new development of reservoir hydropower in Canada and hence, from a consequentialist perspective, do not value methane emissions.

Eq. 37 defines hourly greenhouse gas damage costs  $\text{Cost}_t^{\text{GHG}}$  as the product of pollutant-specific social cost coefficients and corresponding emissions. Social cost coefficients  $s_{(g,y)}^{\text{GHG}}$  for  $\text{CO}_2$ ,  $\text{CH}_4$ , and  $\text{N}_2\text{O}$  are taken from U.S. EPA estimates at a 2% discount rate, expressed in 2024 USD and escalated over time. For all pathways, fossil fuel emissions of  $\text{CO}_2$ ,  $\text{CH}_4$ , and  $\text{N}_2\text{O}$  enter the cost calculation through hourly emissions  $E_t^{(g)}$ .

For Scenario B3(1), methane emissions associated with new reservoir hydropower in Québec are valued based on installed reservoir capacity through an additional reservoir-related methane term  $E_{(\text{res},t)}^{\text{CH}_4}$ . For Scenario B3(2), methane impacts are instead valued proportionally to hourly hydropower imports from Québec, represented by  $\theta_{\text{res}} I_t^{\text{HQ}}$ . In all other pathways, hydropower imports are assumed insufficient to induce new reservoir development, and only fossil fuel emissions are valued.

$$\text{Cost}_t^{\text{GHG}} = \begin{cases} s_{\text{CO}_2,y}^{\text{GHG}} E_t^{\text{CO}_2} + s_{\text{CH}_4,y}^{\text{GHG}} (E_t^{\text{CH}_4} + E_{\text{res},t}^{\text{CH}_4}) + s_{\text{N}_2\text{O},y}^{\text{GHG}} E_t^{\text{N}_2\text{O}} & \text{Scenario B3(1)} \\ s_{\text{CO}_2,y}^{\text{GHG}} E_t^{\text{CO}_2} + s_{\text{CH}_4,y}^{\text{GHG}} (E_t^{\text{CH}_4} + \theta_{\text{res}} I_t^{\text{HQ}}) + s_{\text{N}_2\text{O},y}^{\text{GHG}} E_t^{\text{N}_2\text{O}} & \text{Scenario B3(2)} \\ s_{\text{CO}_2,y}^{\text{GHG}} E_t^{\text{CO}_2} + s_{\text{CH}_4,y}^{\text{GHG}} E_t^{\text{CH}_4} + s_{\text{N}_2\text{O},y}^{\text{GHG}} E_t^{\text{N}_2\text{O}} & \text{Other scenarios} \end{cases} \quad \text{Eq. 37}$$

## 2.11. Air pollutant emissions costs

Eq. 38 defines hourly air pollution damage costs  $\text{Cost}_t^{\text{AP3}}$  as the sum over pollutant species  $k \in \{\text{NO}_x, \text{SO}_2, \text{PM}_{2.5}, \text{PM}_{10}, \text{VOC}, \text{CO}\}$  of pollutant-specific marginal damage values  $\hat{v}^k$  from the AP3 model multiplied by corresponding hourly emissions  $E_t^k$ . Resulting marginal emissions cost estimates at the facility level are reported in SI Table S8.

$$\text{Cost}_t^{\text{AP3}} = \sum_{k \in \{\text{NO}_x, \text{SO}_2, \text{PM}_{2.5}, \text{PM}_{10}, \text{VOC}, \text{CO}\}} \hat{v}^k E_t^k \quad \text{Eq. 38}$$

Resulting marginal emissions costs for each facility are provided in SI Table S8. Moreover, Eq. 39 defines unit-level emissions  $E_{(u,t)}^k$  for pollutant  $k$  as the product of adjusted generation  $G_{(u,t)}^{\text{adj}}$  and a pollutant-specific emissions intensity  $\phi_u^k$ . Eq. 40 aggregates emissions across all generating units to obtain total system-level hourly emissions  $E_t^k$ , which are used in downstream damage cost calculations.

Because unit-level emissions data are incomplete for a subset of units and pollutants, Eq. 41 defines a substitution rule for emissions intensities. When sufficient historical observations exist, unit-specific mean emissions intensities  $\hat{\phi}_u^k$  are used. When unit-level data are unavailable, emissions intensities default to a global mean  $\bar{\phi}^k$  computed across all units. This procedure ensures complete and internally consistent emissions accounting while preserving unit-level heterogeneity wherever data permit.

$$E_{u,t}^k = \phi_u^k G_{u,t}^{\text{adj}}, k \in \{\text{CO}_2, \text{NO}_x, \text{SO}_2, \dots\} \quad \text{Eq. 39}$$

$$E_t^k = \sum_u E_{u,t}^k \quad \text{Eq. 40}$$

Let  $\hat{\phi}_u^k$  be the unit's mean intensity estimated from available hours. If unavailable, fall back to the global mean  $\bar{\phi}^k$  across units:

$$\phi_u^k \leftarrow \begin{cases} \hat{\phi}_u^k, & \text{if defined} \\ \bar{\phi}^k, & \text{otherwise} \end{cases} \Rightarrow E_{u,t}^k = \phi_u^k G_{u,t}^{\text{adj}} \quad \text{Eq. 41}$$

## 2.12. Unmet demand penalty costs

During periods of capacity scarcity, when available supply is insufficient to meet demand, the marginal cost of electricity increases sharply due to market scarcity pricing and penalties imposed by ISO-NE under its pay-for-performance mechanism (SI Figure S2). The model assumes perfect foresight of demand over the ramping horizon, which is used to anticipate upcoming peaks and ramp fossil generation in advance so as to minimize infeasible ramping and resulting unmet demand, rather than to optimize battery charging decisions. Eq. 42 defines hourly shortage penalties  $\text{Cost}_t^{\text{short}}$  as the product of unmet demand  $\text{Short}_t^{\text{cal}}$  and the ISO-NE pay-for-performance penalty rate  $\pi_{\text{short}}$ , set to \$3,500 MWh<sup>-1</sup> 2024 USD (Potomac Economics, 2024).

$$\mathbf{Cost}_t^{\text{short}} = \pi_{\text{short}} \cdot \mathbf{Short}_t^{(\text{cal})} \quad \mathbf{Eq. 42}$$

### 2.13. Direct costs

Eq. 43 defines timestep-level direct operating costs  $\mathbf{Cost}_t^{\text{direct}}$  as the sum of all costs that vary with hourly system operation, including variable operations and maintenance  $\mathbf{Cost}_t^{\text{VOM}}$ , fuel expenditures  $\mathbf{Cost}_t^{\text{fuel}}$ , and electricity import costs  $\mathbf{Cost}_t^{\text{imports}}$ . These costs depend on realized generation, fuel use, and imports in each hour.

Eq. 44 aggregates hourly operating costs across all timesteps  $t$  within year  $y$  and combines them with annual costs that accrue independently of hourly operation. These include capital expenditures  $\mathbf{Cost}_y^{\text{CAPEX}}$ , which occur in the year new generation or transmission assets are commissioned, and fixed operations and maintenance costs  $\mathbf{Cost}_y^{\text{FOM}}$ , which recur annually for all operating assets. This formulation ensures that both short-run operating costs and long-run investment-related costs are consistently captured at the annual level.

$$\mathbf{Cost}_t^{\text{direct}} = \mathbf{Cost}_t^{\text{VOM}} + \mathbf{Cost}_t^{\text{fuel}} + \mathbf{Cost}_t^{\text{imports}} \quad \mathbf{Eq. 43}$$

$$\mathbf{Cost}_y^{\text{direct}} = \sum_{t \in y} \mathbf{Cost}_t^{\text{direct}} + \mathbf{Cost}_y^{\text{CAPEX}} + \mathbf{Cost}_y^{\text{FOM}} \quad \mathbf{Eq. 44}$$

### 2.14. Indirect costs

Eq. 45 defines timestep-level indirect costs  $\mathbf{Cost}_t^{\text{indirect}}$  as the sum of external damage costs from greenhouse gas emissions, air pollutant emissions, and unmet demand penalties. These costs represent societal impacts that are not directly borne by generators or system operators but are relevant for evaluating welfare outcomes across pathways.

Eq. 46 aggregates hourly indirect costs across all timesteps  $t$  within year  $y$  to obtain total annual indirect costs, ensuring that climate damages, air quality impacts, and reliability penalties are consistently accounted for over time.

$$\mathbf{Cost}_t^{\text{indirect}} = \mathbf{Cost}_t^{\text{GHG}} + \mathbf{Cost}_t^{\text{AP3}} + \mathbf{Cost}_t^{\text{short}} \quad \mathbf{Eq. 45}$$

$$\mathbf{Cost}_y^{\text{indirect}} = \sum_{t \in y} \mathbf{Cost}_t^{\text{indirect}} \quad \mathbf{Eq. 46}$$

### 2.15. Total system cost and NPV

Eq. 47 defines total system cost in year  $y$  as the sum of direct system costs and indirect societal costs. This captures both expenditures incurred by the electricity system and external damages associated with emissions and reliability shortfalls.

Eq. 48 computes the net present value (NPV) of total system costs by discounting annual costs over the analysis horizon  $Y$  to a reference year  $y_0$  using a real discount rate  $r$ . This formulation allows consistent comparison of costs across pathways with different temporal profiles of investment, operation, and external impacts.

$$\begin{aligned} \mathbf{Cost}_y &= \mathbf{Cost}_y^{\text{direct}} + \mathbf{Cost}_y^{\text{indirect}} && \text{Eq. 47} \\ \mathbf{NPV} &= \sum_{y \in \mathcal{Y}} \frac{\mathbf{Cost}_y}{(1+r)^{y-y_0}} && \text{Eq. 48} \end{aligned}$$

### 3. Monte Carlo analysis

ISO-NE supplies discretized, joint distributions for the capacity factors of solar and onshore and offshore wind identified as probability percentiles (1, 5, 10, 50, 90, 95, 99% yearly output). These percentiles account for the hourly correlations between, for example, wind and solar capacity factors, capacity factors at different hours, etc.

We apply linear interpolation to create hourly schedules for 99 percentiles  $p_\omega \in \{1, \dots, 99\}$ . The model draws randomly from distributions assigned for uncertain parameters for both the energy system, including from among the 99 percentiles for capacity output, and for ecological, health, and economic impacts defined in text. Initial parameter draws are propagated through the model so each simulation run tracks correlations in underlying input variables.

Let the random percentile sequence for simulation index be  $p_\omega \in \{1, \dots, 99\}$ . For each hour  $t$ :

$$\begin{aligned} \mathbf{CF}_{\text{Solar},t}(\omega) &= \mathbf{CF}_{\text{Solar}}^{\text{tbl}}(\text{DayLabel}(t), \text{Hour}(t), p_\omega) && \text{Eq. 49} \\ \mathbf{CF}_{\text{Wind}_{\text{on}},t}(\omega) &= \mathbf{CF}_{\text{Wind}_{\text{on}}}^{\text{tbl}}(\text{DayLabel}(t), \text{Hour}(t), p_\omega) && \text{Eq. 50} \\ \mathbf{CF}_{\text{Wind}_{\text{off}},t}(\omega) &= \mathbf{CF}_{\text{Wind}_{\text{off}}}^{\text{tbl}}(\text{DayLabel}(t), \text{Hour}(t), p_\omega) && \text{Eq. 51} \end{aligned}$$

Imports percentiles are analogously sampled per intertie  $j \in \{\text{HQ}, \text{NYISO}, \text{NBSO}\}$  from the imports CF table:

$$\mathbf{CF}_{j,t}^{\text{spot}}(\omega) = \mathbf{CF}_j^{\text{tbl}}(\text{DayLabel}(t), p_\omega) \quad \text{Eq. 52}$$

### 4. Model validation

To validate the model, we compared results for Scenario B1 of this model (run deterministically) against results for the *High Electrification* pathway presented in the Massachusetts 2050 Decarbonization Roadmap. We extracted ISO-NE estimated values for Total Annual Load and Renewable Generation at five-year intervals

$$y_{\text{validation}} \in \{2025, 2030, 2035, 2040, 2045, 2050\}$$

#### 4.1. Total annual load calculation

For the model trajectory, Total Annual Load ( $L_{model,t}$ ) was calculated as the sum of all generation sources and net imports, consistent with the ISO-NE accounting method:

$$L_{model,t} = \sum_{g \in G} Gen_{g,t} + Imports_{net,t} \quad Eq. 53$$

Where:

- $Gen_{g,t}$  represents the total annual generation from source  $g$  (solar, wind, hydro, biomass, nuclear, fossil).
- $Imports_{net,t}$  represents the calibrated net imports from neighboring jurisdictions.

#### 4.2. Goodness-of-fit metric

To quantify the alignment between the model outputs and the ISO-NE estimated trajectories, we calculated the coefficient of determination ( $R^2$ ) for both *Total Annual Load* and *Renewable Generation*.

$$R^2 = 1 - \frac{SS_{res}}{SS_{tot}} \quad Eq. 54$$

Where the sum of squares of residuals ( $SS_{res}$ ) and the total sum of squares ( $SS_{tot}$ ) are given by:

$$SS_{res} = \sum_t (y_{benchmark,t} - y_{model,t})^2 \quad Eq. 55$$

$$SS_{tot} = \sum_t (y_{benchmark,t} - \bar{y}_{benchmark})^2 \quad Eq. 56$$

Here:

- $y_{benchmark,t}$  is the observed ISO-NE estimated value in year  $t$ .
- $y_{model,t}$  is the model's median predicted value in year  $t$ .
- $\bar{y}_{benchmark}$  is the mean of the ISO-NE estimated values over the validation period.

#### 5. Accounting for costs of increased imports of Canadian hydroelectric power

There is debate about how to value direct and indirect costs associated with increased imports of Canadian hydroelectric power to the U.S. (Calder et al., 2022; Gazar et al., 2024). Within the U.S., direct costs are those associated with investments in new transmission infrastructure plus costs of imported power (either purchased on the spot market or negotiated in a long-term contract). If imports to one U.S. market have the effect of reducing exports to another U.S. market, then increased fossil fuel generation in that other market can be counted as indirect costs.

Costs in Canada derive from direct expenses in building and operating reservoirs and impacts from environmental and social effects of reservoir construction (e.g., global climate impacts from reservoir methane emissions, local impacts on Indigenous food systems, etc.).

Pathway B3 specifically assumes that new hydroelectric generation in Canada would be necessary to sustain the level of increased exports to the U.S. (Commonwealth of Massachusetts, 2020). From a “consequentialist” perspective (Calder et al., 2022; Curran et al., 2005; Earles & Halog, 2011; Ekvall, 2019), it is therefore necessary to account for the generation-side impacts of that hydroelectric development, i.e., costs in Canada. We retain two alternative accounting methods corresponding to two unique pathways: (1) U.S. costs only, i.e., costs of U.S. infrastructure plus costs of imports (a lower bound estimate of the costs of generation in Canada), corresponding to Pathway B3(1), described in SI Section 2.5; and (2) total social costs, accounting for costs of infrastructure in the U.S. and Canada (SI Section 2.5), plus indirect costs from reservoir methane (CH<sub>4</sub>) emissions, proportionally to the power exported to the U.S., corresponding to Pathway B3(2) (SI Section 2.10). Method (2) excludes the value of the imports/exports because this is not a cost to society from the energy system but rather a payment between actors. Figure S1 illustrates how direct (U.S. infrastructure, power purchase) and indirect (fossil displacement, reservoir CH<sub>4</sub>) costs are captured under the two cost-accounting methods (U.S.-only vs. total social cost).

Other pathways consider that Canadian hydroelectric resources are leveraged without stimulating new hydroelectric development in Canada, and therefore, from a consequentialist perspective, do not require consideration of impacts associated with existing reservoirs. While “attributional” analyses that apportion impacts of all existing infrastructure to incremental transmission expansion are common, they are known to overestimate total costs in comparison with alternatives when there is no causal connection between, for example, new transmission and new generation (Calder et al., 2020, 2022; Curran et al., 2005; Gazar et al., 2024)

Delwiche et al., (2022) reported emissions ranging from 5,685 to 16,744 mg CH<sub>4</sub>-C day<sup>-1</sup> for three existing reservoirs in Quebec, Canada (Eastmain, Robert-Bourassa, and LaForge-1). These reservoirs span a range of trophic statuses, ages, surface areas, and other parameters




Figure S1: Illustration of how direct and indirect costs are allocated for imports of Canadian hydropower under two accounting methods.

Method (1) (“U.S. costs only”) includes U.S. infrastructure plus payments for imports. Method (2) (“total social costs”) additionally includes new reservoir construction costs and methane (CH<sub>4</sub>) emissions in Canada if new hydropower capacity is triggered. Payments for imports are treated as transfers within the overall system and not net social costs. Where imports to one U.S. region displace exports that would have gone to another, any increased fossil generation in that second region can be counted as an additional indirect cost.

believed to be important in determining the time course of CH<sub>4</sub> emissions. Because of uncertainties in (1) how these variables combine to determine emissions and (2) the location and characteristics of a hypothetical future reservoir, we estimate CH<sub>4</sub> emissions from a new hydroelectric facility in Quebec by pooling the above range of values into a uniform distribution and scaling by the generation demanded in Scenario B3 (up to 126.2 TWh per year or 62% of demand). The Eastmain reservoir powers turbines at Eastmain-1 (480 MW), Eastmain-1-A (768 MW) and Sarcelle (150 MW), while Laforge-1 (878 MW) and Robert-Bourassa (878 MW) are each associated with one dam for a total of 7,892 MW at an estimated average capacity factor of 0.65 (Hydro-Québec, 2025). Thus, we consider CH<sub>4</sub>-C emissions using a uniform distribution of 0.16 to 1.22 kg CH<sub>4</sub>-C per MWh imported. Details of facility specific methane emissions from Canadian reservoirs are provided in SI Table S9.




Figure S2: Pay for performance rates and the value of lost load curve used by ISO-NE adapted from the “2023 Assessment Of The ISO New England Electricity Markets” report prepared by Potomac Economics for ISO-NE (Potomac Economics, 2024)




Figure S3: Modeled electricity generation by resource (top panels) and battery discharge (bottom panels) for the eight decarbonization pathways from 2025 to 2050 (simulation #1). Stacked areas in the upper charts indicate generation from hydropower, biomass, nuclear, imports, fossil fuels, natural gas, small modular reactors, onshore wind, offshore wind, and solar; the black dashed line shows the total demand. The greyed hashed region shows the total curtailments. The lower charts display annual battery discharge profiles (in GWh) under each pathway.

Scenario: High Electrification | Comparisons of Median Model Trajectory vs ISO-NE Target




Figure S4: Deterministic validation of generation trajectories (2025–2050). Comparison of the model’s median simulated trajectories (blue solid lines) against the ISO-NE "High Electrification" ISO-NE estimated (red dashed lines). a) Renewable Generation shows near-perfect alignment ( $R^2 = 0.97$ ) and b) Total Annual Load (sum of all generation and imports) shows strong trajectory alignment ( $R^2 = 0.89$ ), with the model projecting higher gross generation requirements due to the inclusion of probabilistic operational losses. Thus, validating the model’s representation of the clean energy transition. ISO-NE estimated data source: Massachusetts 2050 Decarbonization Roadmap (Commonwealth of Massachusetts, 2020).




Figure S5: Spearman correlation matrix showing pairwise relationships between uncertain model parameters and outputs. Positive correlations (green) indicate variables that increase together, while negative correlations (red) show inverse relationships. Hierarchical clustering highlights patterns of dependency across key uncertainty drivers such as GHG emissions, fuel costs, and investment parameters.




Figure S6: Normalized global importance of uncertainty sources for cost-related variables. Air emissions and GHG uncertainties dominate overall variability, while other factors such as fuel, capital, and operational costs contribute minimally. Error bars represent 95% confidence intervals across model evaluations.



Table S2: Yearly capacity schedule for eight decarbonization pathways (2025–2050). All units are in megawatts.

<b>Pathway A</b>												
Year	Large nuclear	Hydropower	Biomass	Solar	Onshore Wind	Offshore Wind	Small modular reactor	New natural gas	Imports from Hydro-Quebec	Imports from NBSO	Imports from NYISO	Storage
<b>2025-2050</b>	3350	900	400	9027	3233	974	0	0	2125	1050	3200	4199
<b>Pathway B1</b>												
Year	Large nuclear	Hydropower	Biomass	Solar	Onshore Wind	Offshore Wind	Small modular reactor	New natural gas	Imports from Hydro-Quebec	Imports from NBSO	Imports from NYISO	Storage
<b>2025</b>	3350	900	400	10315	3563	1471	0	0	2125	1050	3200	4551
<b>2026</b>	3350	900	400	11833	3903	2029	0	0	3325	1050	3200	4968
<b>2027</b>	3350	900	400	13563	4254	2648	0	0	3325	1050	3200	5445
<b>2028</b>	3350	900	400	15490	4615	3327	0	0	3325	1050	3200	5976
<b>2029</b>	3350	900	400	17596	4988	4067	0	0	3325	1050	3200	6556
<b>2030</b>	3350	900	400	19864	5371	4867	0	0	3325	1050	3200	7180
<b>2031</b>	3350	900	400	22277	5764	5728	0	0	4525	1050	4000	7841
<b>2032</b>	3350	900	400	24819	6169	6650	0	0	4525	1050	4000	8536
<b>2033</b>	3350	900	400	27473	6584	7633	0	0	4525	1050	4000	9258
<b>2034</b>	3350	900	400	30221	7010	8676	0	0	4525	1050	4000	10003
<b>2035</b>	3350	900	400	33047	7446	9780	0	0	4525	1050	4000	10764
<b>2036</b>	3350	900	400	35934	7893	10944	0	0	4525	1050	4000	11537
<b>2037</b>	3350	900	400	38866	8351	12169	0	0	4525	1050	4000	12316
<b>2038</b>	3350	900	400	41824	8820	13455	0	0	4525	1050	4000	13096
<b>2039</b>	3350	900	400	44793	9299	14801	0	0	4525	1050	4000	13871
<b>2040</b>	3350	900	400	47756	9789	16209	0	0	4525	1050	4000	14637
<b>2041</b>	3350	900	400	50695	10290	17676	0	0	6225	1050	4800	15387

<b>2042</b>	3350	900	400	53593	10801	19205	0	0	6225	1050	4800	16117
<b>2043</b>	3350	900	400	56435	11324	20794	0	0	6225	1050	4800	16821
<b>2044</b>	3350	900	400	59203	11856	22444	0	0	6225	1050	4800	17493
<b>2045</b>	3350	900	400	61879	12400	24154	0	0	6225	1050	4800	18129
<b>2046</b>	3350	900	400	64448	12954	25925	0	0	6225	1050	4800	18723
<b>2047</b>	3350	900	400	66892	13519	27757	0	0	6225	1050	4800	19270
<b>2048</b>	3350	900	400	69195	14095	29650	0	0	6225	1050	4800	19764
<b>2049</b>	3350	900	400	71339	14681	31603	0	0	6225	1050	4800	20200
<b>2050</b>	3350	900	400	73308	15278	33617	0	0	6225	1050	4800	20572

**Pathway B2**

Year	Large nuclear	Hydropower	Biomass	Solar	Onshore Wind	Offshore Wind	Small modular reactor	New natural gas	Imports from Hydro-Quebec	Imports from NBSO	Imports from NYISO	Storage
<b>2025</b>	3350	900	400	9027	3233	1185	0	0	2125	1050	3200	4199
<b>2026</b>	3350	900	400	10315	3563	1820	0	0	2125	1050	3200	4551
<b>2027</b>	3350	900	400	11833	3903	2533	0	0	2125	1050	3200	4968
<b>2028</b>	3350	900	400	13563	4254	3322	0	0	2125	1050	3200	5445
<b>2029</b>	3350	900	400	15490	4615	4189	0	0	2125	1050	3200	5976
<b>2030</b>	3350	900	400	17596	4988	5133	0	0	2125	1050	3200	6556
<b>2031</b>	3350	900	400	19864	5371	6155	0	0	2125	1050	3200	7180
<b>2032</b>	3350	900	400	22277	5764	7253	0	0	2125	1050	4000	7841
<b>2033</b>	3350	900	400	24819	6169	8428	0	0	2125	1050	4000	8536
<b>2034</b>	3350	900	400	27473	6584	9681	0	0	2125	1050	4000	9258
<b>2035</b>	3350	900	400	30221	7010	11011	0	0	2125	1050	4000	10003
<b>2036</b>	3350	900	400	33047	7446	12418	0	0	2125	1050	4000	10764
<b>2037</b>	3350	900	400	35934	7893	13902	0	0	2125	1050	4000	11537
<b>2038</b>	3350	900	400	38866	8351	15463	0	0	2125	1050	4000	12316
<b>2039</b>	3350	900	400	41824	8820	17101	0	0	2125	1050	4000	13096
<b>2040</b>	3350	900	400	44793	9299	18817	0	0	2125	1050	4000	13871

<b>2041</b>	3350	900	400	47756	9789	20609	0	0	2125	1050	4000	14637
<b>2042</b>	3350	900	400	50695	10290	22479	0	0	2125	1050	4800	15387
<b>2043</b>	3350	900	400	53593	10801	24426	0	0	2125	1050	4800	16117
<b>2044</b>	3350	900	400	56435	11324	26450	0	0	2125	1050	4800	16821
<b>2045</b>	3350	900	400	59203	11856	28551	0	0	2125	1050	4800	17493
<b>2046</b>	3350	900	400	61879	12400	30729	0	0	2125	1050	4800	18129
<b>2047</b>	3350	900	400	64448	12954	32985	0	0	2125	1050	4800	18723
<b>2048</b>	3350	900	400	66892	13519	35317	0	0	2125	1050	4800	19270
<b>2049</b>	3350	900	400	69195	14095	37727	0	0	2125	1050	4800	19764
<b>2050</b>	3350	900	400	71339	14681	40214	0	0	2125	1050	4800	20200

**Pathway B3**

Year	Large nuclear	Hydropower	Biomass	Solar	Onshore Wind	Offshore Wind	Small modular reactor	New natural gas	Imports from Hydro-Quebec	Imports from NBSO	Imports from NYISO	Storage
<b>2025</b>	3350	900	400	10315	3563	1311	0	0	2125	1050	3200	4551
<b>2026</b>	3350	900	400	11833	3903	1798	0	0	3325	1050	3200	4968
<b>2027</b>	3350	900	400	13563	4254	2337	0	0	3325	1050	3200	5445
<b>2028</b>	3350	900	400	15490	4615	2930	0	0	3325	1050	3200	5976
<b>2029</b>	3350	900	400	17596	4988	3576	0	0	3325	1050	3200	6556
<b>2030</b>	3350	900	400	19864	5371	4275	0	0	3325	1050	3200	7180
<b>2031</b>	3350	900	400	22277	5764	5027	0	0	4525	1050	4000	7841
<b>2032</b>	3350	900	400	24819	6169	5832	0	0	4525	1050	4000	8536
<b>2033</b>	3350	900	400	27473	6584	6690	0	0	4525	1050	4000	9258
<b>2034</b>	3350	900	400	30221	7010	7601	0	0	4525	1050	4000	10003
<b>2035</b>	3350	900	400	33047	7446	8566	0	0	4525	1050	4000	10764
<b>2036</b>	3350	900	400	35934	7893	9583	0	0	5725	1050	4000	11537
<b>2037</b>	3350	900	400	38866	8351	10654	0	0	5725	1050	4000	12316
<b>2038</b>	3350	900	400	41824	8820	11777	0	0	5725	1050	4000	13096
<b>2039</b>	3350	900	400	44793	9299	12954	0	0	5725	1050	4000	13871

<b>2040</b>	3350	900	400	47756	9789	14184	0	0	5725	1050	4000	14637
<b>2041</b>	3350	900	400	50695	10290	15467	0	0	6925	1050	4800	15387
<b>2042</b>	3350	900	400	53593	10801	16803	0	0	6925	1050	4800	16117
<b>2043</b>	3350	900	400	56435	11324	18192	0	0	6925	1050	4800	16821
<b>2044</b>	3350	900	400	59203	11856	19634	0	0	6925	1050	4800	17493
<b>2045</b>	3350	900	400	61879	12400	21129	0	0	6925	1050	4800	18129
<b>2046</b>	3350	900	400	64448	12954	22678	0	0	8125	1050	4800	18723
<b>2047</b>	3350	900	400	66892	13519	24279	0	0	8125	1050	4800	19270
<b>2048</b>	3350	900	400	69195	14095	25934	0	0	8125	1050	4800	19764
<b>2049</b>	3350	900	400	71339	14681	27641	0	0	8125	1050	4800	20200
<b>2050</b>	3350	900	400	73308	15278	29402	0	0	8125	1050	4800	20572

**Pathway C1**

Year	Large nuclear	Hydropower	Biomass	Solar	Onshore Wind	Offshore Wind	Small modular reactor	New natural gas	Imports from Hydro-Quebec	Imports from NBSO	Imports from NYISO	Storage
<b>2025</b>	3350	900	400	9027	3233	974	0	0	2125	1050	3200	4199
<b>2026</b>	3350	900	400	9027	3233	974	0	0	2125	1050	3200	4199
<b>2027</b>	3350	900	400	9027	3233	974	0	0	2125	1050	3200	4199
<b>2028</b>	3350	900	400	9027	3233	974	0	0	2125	1050	3200	4199
<b>2029</b>	3350	900	400	9027	3233	974	0	0	2125	1050	3200	4199
<b>2030</b>	3350	900	400	9027	3233	974	0	0	2125	1050	3200	4199
<b>2031</b>	3350	900	400	9027	3233	974	2100	0	2125	1050	3200	4199
<b>2032</b>	3350	900	400	9027	3233	974	4200	0	2125	1050	3200	4199
<b>2033</b>	3350	900	400	9027	3233	974	6300	0	2125	1050	3200	4199
<b>2034</b>	3350	900	400	9027	3233	974	8400	0	2125	1050	3200	4199
<b>2035</b>	3350	900	400	9027	3233	974	10500	0	2125	1050	3200	4199
<b>2036</b>	3350	900	400	9027	3233	974	12600	0	2125	1050	3200	4199
<b>2037</b>	3350	900	400	9027	3233	974	14700	0	2125	1050	3200	4199
<b>2038</b>	3350	900	400	9027	3233	974	16800	0	2125	1050	3200	4199

<b>2039</b>	3350	900	400	9027	3233	974	18900	0	2125	1050	3200	4199
<b>2040</b>	3350	900	400	9027	3233	974	21000	0	2125	1050	3200	4199
<b>2041</b>	3350	900	400	9027	3233	974	23100	0	2125	1050	3200	4199
<b>2042</b>	3350	900	400	9027	3233	974	25200	0	2125	1050	3200	4199
<b>2043</b>	3350	900	400	9027	3233	974	27300	0	2125	1050	3200	4199
<b>2044</b>	3350	900	400	9027	3233	974	29400	0	2125	1050	3200	4199
<b>2045</b>	3350	900	400	9027	3233	974	31500	0	2125	1050	3200	4199
<b>2046</b>	3350	900	400	9027	3233	974	33600	0	2125	1050	3200	4199
<b>2047</b>	3350	900	400	9027	3233	974	35700	0	2125	1050	3200	4199
<b>2048</b>	3350	900	400	9027	3233	974	37800	0	2125	1050	3200	4199
<b>2049</b>	3350	900	400	9027	3233	974	39900	0	2125	1050	3200	4199
<b>2050</b>	3350	900	400	9027	3233	974	42000	0	2125	1050	3200	4199

**Pathway C2**

Year	Large nuclear	Hydropower	Biomass	Solar	Onshore Wind	Offshore Wind	Small modular reactor	New natural gas	Imports from Hydro-Quebec	Imports from NBSO	Imports from NYISO	Storage
<b>2025</b>	3350	900	400	10315	3563	1471	0	0	2125	1050	3200	4551
<b>2026</b>	3350	900	400	11833	3903	2029	0	0	2125	1050	3200	4968
<b>2027</b>	3350	900	400	13563	4254	2648	0	0	2125	1050	3200	5445
<b>2028</b>	3350	900	400	15490	4615	3327	0	0	2125	1050	3200	5976
<b>2029</b>	3350	900	400	17596	4988	4067	0	0	2125	1050	3200	6556
<b>2030</b>	3350	900	400	19864	5371	4867	0	0	2125	1050	3200	7180
<b>2031</b>	3350	900	400	22277	5764	5728	300	0	2125	1050	4000	7841
<b>2032</b>	3350	900	400	24819	6169	6650	600	0	2125	1050	4000	8536
<b>2033</b>	3350	900	400	27473	6584	7633	900	0	2125	1050	4000	9258
<b>2034</b>	3350	900	400	30221	7010	8676	1200	0	2125	1050	4000	10003
<b>2035</b>	3350	900	400	33047	7446	9780	1500	0	2125	1050	4000	10764
<b>2036</b>	3350	900	400	35934	7893	10944	1800	0	2125	1050	4000	11537
<b>2037</b>	3350	900	400	38866	8351	12169	2100	0	2125	1050	4000	12316

<b>2038</b>	3350	900	400	41824	8820	13455	2400	0	2125	1050	4000	13096
<b>2039</b>	3350	900	400	44793	9299	14801	2700	0	2125	1050	4000	13871
<b>2040</b>	3350	900	400	47756	9789	16209	3000	0	2125	1050	4000	14637
<b>2041</b>	3350	900	400	50695	10290	17676	3300	0	2125	1050	4800	15387
<b>2042</b>	3350	900	400	53593	10801	19205	3600	0	2125	1050	4800	16117
<b>2043</b>	3350	900	400	56435	11324	20794	3900	0	2125	1050	4800	16821
<b>2044</b>	3350	900	400	59203	11856	22444	4200	0	2125	1050	4800	17493
<b>2045</b>	3350	900	400	61879	12400	24154	4200	0	2125	1050	4800	18129
<b>2046</b>	3350	900	400	64448	12954	25925	4200	0	2125	1050	4800	18723
<b>2047</b>	3350	900	400	66892	13519	27757	4200	0	2125	1050	4800	19270
<b>2048</b>	3350	900	400	69195	14095	29650	4200	0	2125	1050	4800	19764
<b>2049</b>	3350	900	400	71339	14681	31603	4200	0	2125	1050	4800	20200
<b>2050</b>	3350	900	400	73308	15278	33617	4200	0	2125	1050	4800	20572

**Pathway C3**

Year	Large nuclear	Hydropower	Biomass	Solar	Onshore Wind	Offshore Wind	Small modular reactor	New natural gas	Imports from Hydro-Quebec	Imports from NBSO	Imports from NYISO	Storage
<b>2025</b>	3350	900	400	10315	3563	1311	0	0	2125	1050	3200	4551
<b>2026</b>	3350	900	400	11833	3903	1798	0	0	3325	1050	3200	4968
<b>2027</b>	3350	900	400	13563	4254	2337	0	0	3325	1050	3200	5445
<b>2028</b>	3350	900	400	15490	4615	2930	0	0	3325	1050	3200	5976
<b>2029</b>	3350	900	400	17596	4988	3576	0	0	3325	1050	3200	6556
<b>2030</b>	3350	900	400	19864	5371	4275	0	0	3325	1050	3200	7180
<b>2031</b>	3350	900	400	22277	5764	5027	300	0	4525	1050	4000	7841
<b>2032</b>	3350	900	400	24819	6169	5832	600	0	4525	1050	4000	8536
<b>2033</b>	3350	900	400	27473	6584	6690	900	0	4525	1050	4000	9258
<b>2034</b>	3350	900	400	30221	7010	7601	1200	0	4525	1050	4000	10003
<b>2035</b>	3350	900	400	33047	7446	8566	1500	0	4525	1050	4000	10764
<b>2036</b>	3350	900	400	35934	7893	9583	1800	0	4525	1050	4000	11537

2037	3350	900	400	38866	8351	10654	2100	0	4525	1050	4000	12316
2038	3350	900	400	41824	8820	11777	2100	0	4525	1050	4000	13096
2039	3350	900	400	44793	9299	12954	2100	0	4525	1050	4000	13871
2040	3350	900	400	47756	9789	14184	2100	0	4525	1050	4000	14637
2041	3350	900	400	50695	10290	15467	2100	0	6225	1050	4800	15387
2042	3350	900	400	53593	10801	16803	2100	0	6225	1050	4800	16117
2043	3350	900	400	56435	11324	18192	2100	0	6225	1050	4800	16821
2044	3350	900	400	59203	11856	19634	2100	0	6225	1050	4800	17493
2045	3350	900	400	61879	12400	21129	2100	0	6225	1050	4800	18129
2046	3350	900	400	64448	12954	22678	2100	0	6225	1050	4800	18723
2047	3350	900	400	66892	13519	24279	2100	0	6225	1050	4800	19270
2048	3350	900	400	69195	14095	25934	2100	0	6225	1050	4800	19764
2049	3350	900	400	71339	14681	27641	2100	0	6225	1050	4800	20200
2050	3350	900	400	73308	15278	29402	2100	0	6225	1050	4800	20572

**Pathway D**

Year	Large nuclear	Hydropower	Biomass	Solar	Onshore Wind	Offshore Wind	Small modular reactor	New natural gas	Imports from Hydro-Quebec	Imports from NBSO	Imports from NYISO	Storage
2025	3350	900	400	9361	3353	1010	0	0	2125	1050	3200	4551
2026	3350	900	400	9707	3477	1047	0	0	3325	1050	3200	4968
2027	3350	900	400	10066	3606	1086	0	0	3325	1050	3200	5445
2028	3350	900	400	10438	3739	1126	0	0	3325	1050	3200	5976
2029	3350	900	400	10824	3877	1168	0	0	3325	1050	3200	6556
2030	3350	900	400	11224	4020	1211	0	0	3325	1050	3200	7180
2031	3350	900	400	11639	4169	1256	0	0	4525	1050	4000	7841
2032	3350	900	400	12070	4323	1302	0	0	4525	1050	4000	8536
2033	3350	900	400	12517	4483	1350	0	1131	4525	1050	4000	9258
2034	3350	900	400	12980	4649	1400	0	2262	4525	1050	4000	10003
2035	3350	900	400	13460	4821	1452	0	3393	4525	1050	4000	10764

<b>2036</b>	3350	900	400	13958	4999	1506	0	4524	4525	1050	4000	11537
<b>2037</b>	3350	900	400	14474	5184	1562	0	5655	4525	1050	4000	12316
<b>2038</b>	3350	900	400	15010	5376	1620	0	6786	4525	1050	4000	13096
<b>2039</b>	3350	900	400	15565	5575	1680	0	7917	4525	1050	4000	13871
<b>2040</b>	3350	900	400	16141	5781	1742	0	9048	4525	1050	4000	14637
<b>2041</b>	3350	900	400	16738	5995	1806	0	10179	6225	1050	4800	15387
<b>2042</b>	3350	900	400	17357	6217	1873	0	11310	6225	1050	4800	16117
<b>2043</b>	3350	900	400	17999	6447	1942	0	12441	6225	1050	4800	16821
<b>2044</b>	3350	900	400	18665	6686	2014	0	13572	6225	1050	4800	17493
<b>2045</b>	3350	900	400	19356	6933	2089	0	14703	6225	1050	4800	18129
<b>2046</b>	3350	900	400	20072	7190	2166	0	15834	6225	1050	4800	18723
<b>2047</b>	3350	900	400	20815	7456	2246	0	16965	6225	1050	4800	19270
<b>2048</b>	3350	900	400	21585	7732	2329	0	18096	6225	1050	4800	19764
<b>2049</b>	3350	900	400	22384	8018	2415	0	19227	6225	1050	4800	20200
<b>2050</b>	3350	900	400	23212	8315	2504	0	20358	6225	1050	4800	20572

---

Table S3: Average annual (2022–2050) electricity generation capacity changes under a no Inflation Reduction Act scenario (U.S. EIA AEO, 2023).

<b>Source</b>	<b>Average annual change in the U.S. (%)</b>
Coal	-2.7%
Oil and Natural Gas Steam	-1.1%
Combined Cycle (CC)	1.0%
Combustion Turbine/Diesel (CT)	3.1%
Nuclear Power	-0.2%
Pumped Storage	0.0%
Diurnal Storage	6.3%
Fuel Cells	0.7%
Renewable Sources	3.7%
Distributed Generation (Natural Gas)	--
<b>Total</b>	<b>1.8%</b>

Table S4: Facility and unit-level operational characteristics, ramp category, retirement timelines, and emissions factors for all fossil fuel power plant facilities in New England. This table includes each facility’s nameplate capacity (MW) and capacity factor (in brackets), ramp designation, projected retirement year, and average CO<sub>2</sub>, NO<sub>x</sub>, SO<sub>2</sub>, and heat input rates on a per-MW basis. Note this retirement schedule in this study applies to all pathways except A and D.

Facility name	Facility [unit] ID	Location	Nameplate capacity (MW) [capacity factor]	Ramp	Retirement year	CO <sub>2</sub> tons MW <sup>-1</sup>	NO <sub>x</sub> lbs. MW <sup>-1</sup>	SO <sub>2</sub> lbs. MW <sup>-1</sup>	Heat input MMBtu MW <sup>-1</sup>
<b>Alfred L Pierce Generating Station</b>	6635 [AP-1]	New Haven County, CT	84 [0.62]	1H	2062	0.63	0.56	0.01	6.29
<b>Bellingham</b>	10307 [1]	Norfolk County, MA	257.4 [0.37]	12H	2046	0.67	0.88	0.03	4.11
<b>Bellingham</b>	10307 [2]	Norfolk County, MA	257.4 [0.37]	12H	2046	0.68	0.92	0.03	4.24
<b>Bellingham Power Generation LLC</b>	55211 [2]	Norfolk County, MA	289 [0.45]	12H	2057	0.65	0.1	0.01	4.9
<b>Bellingham Power Generation LLC</b>	55211 [1]	Norfolk County, MA	289 [0.44]	12H	2057	0.66	0.1	0.01	4.93
<b>Berkshire Power</b>	55041 [1]	Hampden County, MA	289 [0.67]	12H	2054	0.43	0.11	0	4.85
<b>Berlin 5</b>	3734 [A]	Washington County, VT	41.8 [0.89]	10M	2027	0.79	0.12	0.01	13.22
<b>Berlin 5</b>	3734 [B]	Washington County, VT	41.8 [0.89]	10M	2027	0.79	0.12	0.01	13.22
<b>Blackstone Power</b>	55212 [1]	Worcester County, MA	289 [0.44]	12H	2056	0.64	0.1	0.01	4.78

Facility name	Facility [unit] ID	Location	Nameplate capacity (MW) [capacity factor]	Ramp	Retirement year	CO2 tons MW <sup>-1</sup>	NOx lbs. MW <sup>-1</sup>	SO2 lbs. MW <sup>-1</sup>	Heat input MMBtu MW <sup>-1</sup>
<b>Generation LLC</b>									
<b>Blackstone Power Generation LLC</b>	55212 [2]	Worcester County, MA	289 [0.45]	12H	2056	0.65	0.09	0.01	4.89
<b>Branford</b>	540 [10]	New Haven County, CT	21.8 [0.53]	10M	2024	0.78	14.91	0.01	7
<b>Bridgeport Energy</b>	55042 [BE1]	Fairfield County, CT	350 [0.62]	12H	2053	0.44	0.13	0	4.55
<b>Bridgeport Energy</b>	55042 [BE2]	Fairfield County, CT	350 [0.64]	12H	2053	0.43	0.13	0	4.57
<b>Bridgeport Harbor Station</b>	568 [BHB5]	Fairfield County, CT	575.6 [0.78]	1H	2074	0.38	0.04	0	5.03
<b>Bridgeport Harbor Station</b>	568 [BHB2]	Fairfield County, CT	179.5 [0.78]	1H	2016	1.02	1.39	3.35	9.95
<b>Burgess BioPower</b>	58054 [ST01]	Coos County, NH	75 [0.94]	OVER	2058	1.52	0.92	0.07	13.69
<b>Canal Station</b>	1599 [2]	Barnstable County, MA	580 [0.35]	12H	2030	0.76	1.49	2.2	3.77
<b>Canal Station</b>	1599 [3]	Barnstable County, MA	367.7 [0.69]	12H	2030	0.6	0.1	0.01	6.62
<b>Canal Station</b>	1599 [1]	Barnstable County, MA	585 [0.53]	12H	2023	0.78	0.98	3.51	5.07
<b>Cleary Flood</b>	1682 [8]	Bristol County, MA	28 [0.61]	10M	2021	1.19	3.87	10.45	9.01

Facility name	Facility [unit] ID	Location	Nameplate capacity (MW) [capacity factor]	Ramp	Retirement year	CO2 tons MW <sup>-1</sup>	NOx lbs. MW <sup>-1</sup>	SO2 lbs. MW <sup>-1</sup>	Heat input MMBtu MW <sup>-1</sup>
<b>Cleary Flood</b>	1682 [9]	Bristol County, MA	118 [0.49]	10M	2030	0.63	1.6	0.07	5.15
<b>Cos Cob</b>	542 [10]	Fairfield County, CT	25 [0.56]	10M	2024	0.78	13.5	0.01	6.27
<b>Cos Cob</b>	542 [11]	Fairfield County, CT	25 [0.58]	10M	2024	0.78	13.36	0.01	6.51
<b>Cos Cob</b>	542 [12]	Fairfield County, CT	25 [0.58]	10M	2024	0.78	13.7	0.01	6.58
<b>Cos Cob</b>	542 [14]	Fairfield County, CT	20 [0.72]	10M	2030	0.78	16.34	0.01	10.33
<b>Cos Cob</b>	542 [13]	Fairfield County, CT	20 [0.68]	10M	2030	0.78	18.2	0.01	10.38
<b>CPV Towantic Energy Center</b>	56047 [2]	New Haven County, CT	565.5 [0.62]	12H	2073	0.39	0.04	0	4.1
<b>CPV Towantic Energy Center</b>	56047 [1]	New Haven County, CT	565.5 [0.63]	12H	2073	0.38	0.04	0	4.1
<b>Dartmouth Power</b>	52026 [2]	Bristol County, MA	24.7 [0.7]	12H	2064	0.63	0.13	0.01	7.4
<b>Dartmouth Power</b>	52026 [1]	Bristol County, MA	77 [0.63]	12H	2047	0.48	0.26	0.01	5.06
<b>Devon</b>	544 [10]	New Haven County, CT	18.6 [0.67]	1H	2040	0.78	13.74	0.01	7.67
<b>Devon</b>	544 [14]	New Haven County, CT	43 [0.55]	1H	2051	0.79	8.21	0.18	5.98
<b>Devon</b>	544 [13]	New Haven County, CT	43 [0.56]	1H	2051	0.8	8.41	0.21	6.03
<b>Devon</b>	544 [12]	New Haven County, CT	43 [0.56]	1H	2051	0.78	8.27	0.19	6.07

Facility name	Facility [unit] ID	Location	Nameplate capacity (MW) [capacity factor]	Ramp	Retirement year	CO2 tons MW <sup>-1</sup>	NOx lbs. MW <sup>-1</sup>	SO2 lbs. MW <sup>-1</sup>	Heat input MMBtu MW <sup>-1</sup>
<b>Devon</b>	544 [11]	New Haven County, CT	43 [0.56]	1H	2051	0.79	8.66	0.2	6.1
<b>Devon</b>	544 [16]	New Haven County, CT	51 [0.72]	1H	2065	0.58	0.11	0.01	5.17
<b>Devon</b>	544 [15]	New Haven County, CT	51 [0.72]	1H	2065	0.58	0.12	0.01	5.22
<b>Devon</b>	544 [18]	New Haven County, CT	51 [0.74]	1H	2065	0.58	0.13	0.01	5.44
<b>Devon</b>	544 [17]	New Haven County, CT	51 [0.75]	1H	2065	0.59	0.11	0.01	5.53
<b>Dighton</b>	55026 [1]	Bristol County, MA	200 [0.74]	12H	2054	0.46	0.1	0	5.72
<b>Exelon West Medway II</b>	59882 [J5]	Norfolk County, MA	131.8 [0.39]	10M	2074	0.55	0.09	0.01	3.62
<b>Exelon West Medway II</b>	59882 [J4]	Norfolk County, MA	131.8 [0.4]	10M	2074	0.55	0.09	0.01	3.69
<b>Fore River Energy Center</b>	55317 [11]	Norfolk County, MA	593.6 [0.53]	OVER	2058	0.42	0.05	0	3.74
<b>Fore River Energy Center</b>	55317 [12]	Norfolk County, MA	593.6 [0.55]	OVER	2058	0.44	0.05	0	4.01
<b>Framingham Station</b>	1586 [FJ-3]	Middlesex County, MA	14.2 [0.41]	10M	2024	0.78	11.86	0.01	8.46
<b>Framingham Station</b>	1586 [FJ-2]	Middlesex County, MA	14.2 [0.4]	10M	2024	0.78	11.18	0.01	8.74
<b>Framingham Station</b>	1586 [FJ-1]	Middlesex County, MA	14.2 [0.43]	10M	2024	0.78	11.44	0.01	8.87
<b>Franklin Drive</b>	561 [10]	Litchfield County, CT	21.8 [0.47]	10M	2024	0.78	18.45	0.01	7.26

Facility name	Facility [unit] ID	Location	Nameplate capacity (MW) [capacity factor]	Ramp	Retirement year	CO2 tons MW <sup>-1</sup>	NOx lbs. MW <sup>-1</sup>	SO2 lbs. MW <sup>-1</sup>	Heat input MMBtu MW <sup>-1</sup>
<b>Granite Ridge Energy</b>	55170 [1]	Rockingham County, NH	530 [0.36]	12H	2058	0.64	0.1	0.01	3.9
<b>Granite Ridge Energy</b>	55170 [2]	Rockingham County, NH	530 [0.36]	12H	2058	0.64	0.1	0.01	3.91
<b>J C McNeil</b>	589 [1]	Chittenden County, VT	59.5 [0.82]	OVER	2029	1.48	0.98	0.01	11.55
<b>Kendall Green Energy LLC</b>	1595 [S6]	Middlesex County, MA	20 [0.44]	12H	2025	0.78	23.04	0.01	9.98
<b>Kendall Green Energy LLC</b>	1595 [4]	Middlesex County, MA	253.6 [1.03]	12H	2030	0.39	0.05	0	6.65
<b>Kendall Green Energy LLC</b>	1595 [3]	Middlesex County, MA	54.4 [0.82]	12H	2009	1.47	1.28	8.28	13.57
<b>Kendall Green Energy LLC</b>	1595 [2]	Middlesex County, MA	50.2 [0.87]	12H	2004	1.54	1	0.01	14.75
<b>Kleen Energy Systems Project</b>	56798 [U1]	Middlesex County, CT	494 [0.55]	12H	2066	0.41	0.05	0	3.79
<b>Kleen Energy Systems Project</b>	56798 [U2]	Middlesex County, CT	494 [0.55]	12H	2066	0.41	0.05	0	3.8
<b>Lake Road Generating Company</b>	55149 [LRG3]	Windham County, CT	280 [0.52]	12H	2056	0.66	0.07	0.01	5.75
<b>Lake Road Generating Company</b>	55149 [LRG1]	Windham County, CT	280 [0.51]	12H	2056	0.67	0.08	0.01	5.76

Facility name	Facility [unit] ID	Location	Nameplate capacity (MW) [capacity factor]	Ramp	Retirement year	CO2 tons MW <sup>-1</sup>	NOx lbs. MW <sup>-1</sup>	SO2 lbs. MW <sup>-1</sup>	Heat input MMBtu MW <sup>-1</sup>
<b>Lake Road Generating Company</b>	55149 [LRG2]	Windham County, CT	280 [0.52]	12H	2056	0.66	0.08	0.01	5.84
<b>Lost Nation</b>	2362 [CT1]	Coos County, NH	18 [0.42]	10M	2024	0.78	21.48	0.01	14.44
<b>Maine Independence Station</b>	55068 [2]	Penobscot County, ME	371.2 [0.28]	12H	2055	0.7	0.21	0.01	3.33
<b>Maine Independence Station</b>	55068 [1]	Penobscot County, ME	371.2 [0.29]	12H	2055	0.7	0.2	0.01	3.34
<b>Manchester Street Station</b>	3236 [9]	Providence County, RI	171 [0.5]	12H	2050	0.72	0.41	0.01	5.97
<b>Manchester Street Station</b>	3236 [10]	Providence County, RI	173 [0.51]	12H	2050	0.7	0.35	0.01	6.03
<b>Manchester Street Station</b>	3236 [11]	Providence County, RI	171 [0.52]	12H	2050	0.71	0.37	0.01	6.16
<b>MBTA South Boston Power Facility</b>	10176 [B]	Suffolk County, MA	69 [0.4]	10M	2030	0.72	1.41	0.01	3.61
<b>MBTA South Boston Power Facility</b>	10176 [A]	Suffolk County, MA	69 [0.41]	10M	2030	0.71	1.36	0.01	3.61
<b>Medway Station</b>	1592 [J1T1]	Norfolk County, MA	45 [0.24]	1H	2025	1.69	11.23	0.01	4.95
<b>Medway Station</b>	1592 [J1T2]	Norfolk County, MA	45 [0.26]	1H	2025	1.55	10.72	0.01	4.98

Facility name	Facility [unit] ID	Location	Nameplate capacity (MW) [capacity factor]	Ramp	Retirement year	CO2 tons MW <sup>-1</sup>	NOx lbs. MW <sup>-1</sup>	SO2 lbs. MW <sup>-1</sup>	Heat input MMBtu MW <sup>-1</sup>
Medway Station	1592 [J2T1]	Norfolk County, MA	45 [0.26]	1H	2025	1.6	9.44	0.01	5.04
Medway Station	1592 [J2T2]	Norfolk County, MA	45 [0.25]	1H	2025	1.63	10.37	0.01	5.04
Medway Station	1592 [J3T2]	Norfolk County, MA	45 [0.28]	1H	2025	1.54	9.75	0.01	5.37
Medway Station	1592 [J3T1]	Norfolk County, MA	45 [0.28]	1H	2025	1.57	10.55	0.01	5.42
Merrimack	2364 [CT2]	Merrimack County, NH	18.6 [0.42]	OVER	2024	0.78	24.04	0.01	12.81
Merrimack	2364 [CT1]	Merrimack County, NH	18.6 [0.43]	OVER	2024	0.78	23.18	0.01	12.88
Merrimack	2364 [1]	Merrimack County, NH	113.6 [0.87]	OVER	2030	1.02	2.77	1.32	8.67
Merrimack	2364 [2]	Merrimack County, NH	345.6 [0.77]	OVER	2030	1.01	2.57	1.53	7.62
Middletown	562 [10]	Middlesex County, CT	18.6 [0.49]	10M	2021	0.78	17.23	0.01	7.87
Middletown	562 [14]	Middlesex County, CT	60.5 [0.58]	10M	2030	0.58	0.05	0.01	4.23
Middletown	562 [15]	Middlesex County, CT	60.5 [0.58]	10M	2030	0.6	0.06	0.01	4.36
Middletown	562 [12]	Middlesex County, CT	60.5 [0.59]	10M	2030	0.59	0.07	0.01	4.43
Middletown	562 [13]	Middlesex County, CT	60.5 [0.59]	10M	2030	0.59	0.06	0.01	4.44
Middletown	562 [2]	Middlesex County, CT	113.6 [0.58]	10M	2013	0.68	1.21	0.54	6.36

Facility name	Facility [unit] ID	Location	Nameplate capacity (MW) [capacity factor]	Ramp	Retirement year	CO2 tons MW <sup>-1</sup>	NOx lbs. MW <sup>-1</sup>	SO2 lbs. MW <sup>-1</sup>	Heat input MMBtu MW <sup>-1</sup>
Middletown	562 [3]	Middlesex County, CT	239.4 [0.53]	10M	2019	0.62	2	0.3	5.36
Middletown	562 [4]	Middlesex County, CT	414.9 [0.39]	10M	2028	1.11	3.15	3.64	5.33
Milford Power Company LLC	55126 [CT02]	New Haven County, CT	289 [0.81]	12H	2057	0.42	0.05	0	5.7
Milford Power Company LLC	55126 [CT01]	New Haven County, CT	289 [0.83]	12H	2057	0.42	0.05	0	5.85
Milford Power, LLC	54805 [1]	Worcester County, MA	249.3 [0.45]	1H	2048	0.59	0.3	0.01	4.44
Millennium Power	55079 [1]	Worcester County, MA	360 [0.55]	12H	2055	0.64	0.14	0.01	5.87
Montville	546 [5]	New London County, CT	80.4 [0.59]	10M	2009	0.82	1.46	1.92	6.74
Montville	546 [6]	New London County, CT	414.9 [0.33]	10M	2026	1.05	2.57	3.53	4.24
Mystic	1588 [94]	Middlesex County, MA	593.6 [0.49]	12H	2024	0.43	0.05	0	3.51
Mystic	1588 [93]	Middlesex County, MA	593.6 [0.49]	12H	2024	0.43	0.06	0	3.53
Mystic	1588 [82]	Middlesex County, MA	593.6 [0.51]	12H	2024	0.42	0.06	0	3.62
Mystic	1588 [81]	Middlesex County, MA	593.6 [0.51]	12H	2024	0.42	0.05	0	3.65
New Haven Harbor	6156 [NHHS2]	New Haven County, CT	60.5 [0.59]	OVER	2030	0.58	0.19	0.01	4.36
New Haven Harbor	6156 [NHHS3]	New Haven County, CT	60.5 [0.6]	OVER	2030	0.58	0.15	0.01	4.39

Facility name	Facility [unit] ID	Location	Nameplate capacity (MW) [capacity factor]	Ramp	Retirement year	CO2 tons MW <sup>-1</sup>	NOx lbs. MW <sup>-1</sup>	SO2 lbs. MW <sup>-1</sup>	Heat input MMBtu MW <sup>-1</sup>
<b>New Haven Harbor</b>	6156 [NHHS4]	New Haven County, CT	60.5 [0.6]	OVER	2030	0.58	0.15	0.01	4.4
<b>New Haven Harbor</b>	6156 [NHB1]	New Haven County, CT	460 [0.35]	OVER	2030	0.78	1.19	1.89	3.7
<b>Newington</b>	8002 [1]	Rockingham County, NH	414 [0.35]	OVER	2029	0.95	2.33	4.08	4.54
<b>Newington Energy</b>	55661 [2]	Rockingham County, NH	419.9 [0.48]	12H	2057	0.44	0.1	0.01	3.48
<b>Newington Energy</b>	55661 [1]	Rockingham County, NH	419.9 [0.5]	12H	2057	0.45	0.1	0.01	3.62
<b>Ocean State Power</b>	51030 [2]	Providence County, RI	171.4 [0.41]	12H	2045	0.73	0.34	0.01	5.05
<b>Ocean State Power</b>	51030 [1]	Providence County, RI	171.4 [0.43]	12H	2045	0.71	0.31	0.01	5.06
<b>Ocean State Power II</b>	54324 [3]	Providence County, RI	171.4 [0.4]	12H	2046	0.76	0.35	0.01	5.14
<b>Ocean State Power II</b>	54324 [4]	Providence County, RI	171.4 [0.42]	12H	2046	0.75	0.37	0.01	5.23
<b>Penny Lane Gas Turbine</b>	3754 [CT1]	Chittenden County, VT	25.5 [0.92]	1H	2026	0.78	0.1	0.01	13.17
<b>Penny Lane Gas Turbine</b>	3754 [CT2]	Chittenden County, VT	25.5 [0.92]	1H	2026	0.78	0.1	0.01	13.17
<b>Pittsfield Generating</b>	50002 [1]	Berkshire County, MA	93.4 [0.34]	12H	2045	0.71	0.28	0	3.94
<b>Pittsfield Generating</b>	50002 [3]	Berkshire County, MA	93.4 [0.35]	12H	2045	0.71	0.25	0	4.07
<b>Pittsfield Generating</b>	50002 [2]	Berkshire County, MA	93.4 [0.35]	12H	2045	0.72	0.27	0	4.08

Facility name	Facility [unit] ID	Location	Nameplate capacity (MW) [capacity factor]	Ramp	Retirement year	CO2 tons MW <sup>-1</sup>	NOx lbs. MW <sup>-1</sup>	SO2 lbs. MW <sup>-1</sup>	Heat input MMBtu MW <sup>-1</sup>
<b>Potter</b>	1660 [4]	Norfolk County, MA	58 [0.67]	12H	2024	0.53	0.11	0.01	5.6
<b>Potter</b>	1660 [5]	Norfolk County, MA	58 [0.67]	12H	2024	0.53	0.14	0.01	5.62
<b>Potter</b>	1660 [3]	Norfolk County, MA	101 [0.44]	12H	2024	0.74	4.75	0	5.5
<b>Rhode Island State Energy Center</b>	55107 [RISEP2]	Providence County, RI	400 [0.62]	12H	2057	0.4	0.05	0	4.18
<b>Rhode Island State Energy Center</b>	55107 [RISEP1]	Providence County, RI	400 [0.62]	12H	2057	0.4	0.05	0	4.21
<b>Rumford Power</b>	55100 [1]	Oxford County, ME	272.9 [0.64]	12H	2055	0.43	0.16	0	4.7
<b>Ryegate Associates</b>	51026 [1]	Caledonia County, VT	20 [0.95]		2037	1.48	0.55	0.01	14.24
<b>Salem Harbor Station NGCC</b>	60903 [2]	Essex County, MA	399.1 [0.56]	12H	2073	0.41	0.07	0	3.93
<b>Salem Harbor Station NGCC</b>	60903 [1]	Essex County, MA	399.1 [0.56]	12H	2072	0.42	0.06	0	3.97
<b>Schiller</b>	2367 [CT1]	Rockingham County, NH	21.3 [0.4]	12H	2024	0.78	25.56	0.01	13.27
<b>Schiller</b>	2367 [6]	Rockingham County, NH	50 [0.55]	12H	2030	1.23	2.82	9.97	6.7
<b>Schiller</b>	2367 [4]	Rockingham County, NH	50 [0.54]	12H	2027	1.26	3.14	10.77	6.76
<b>Schiller</b>	2367 [5]	Rockingham County, NH	50 [0.87]	12H	2000	1.54	1	0.01	12.79

Facility name	Facility [unit] ID	Location	Nameplate capacity (MW) [capacity factor]	Ramp	Retirement year	CO2 tons MW <sup>-1</sup>	NOx lbs. MW <sup>-1</sup>	SO2 lbs. MW <sup>-1</sup>	Heat input MMBtu MW <sup>-1</sup>
<b>Stony Brook Energy Center</b>	6081 [4]	Hampden County, MA	85 [0.48]	10M	2030	1.07	15.82	0.01	6.39
<b>Stony Brook Energy Center</b>	6081 [5]	Hampden County, MA	85 [0.48]	10M	2030	1.1	16.24	0.01	6.55
<b>Stony Brook Energy Center</b>	6081 [2]	Hampden County, MA	190 [0.32]	10M	2030	0.85	1.89	0	3.69
<b>Stony Brook Energy Center</b>	6081 [3]	Hampden County, MA	190 [0.33]	10M	2030	0.77	1.9	0	3.92
<b>Stony Brook Energy Center</b>	6081 [1]	Hampden County, MA	190 [0.34]	10M	2030	0.77	2.02	0	3.97
<b>Tiverton Power, LLC</b>	55048 [1]	Newport County, RI	272.5 [0.83]	12H	2055	0.42	0.08	0	5.82
<b>Torrington Terminal</b>	565 [10]	Litchfield County, CT	21.8 [0.5]	10M	2024	0.78	17.23	0.01	7.23
<b>Wallingford Energy, LLC</b>	55517 [CT01]	New Haven County, CT	50 [0.74]	1H	2056	0.47	0.08	0	5.82
<b>Wallingford Energy, LLC</b>	55517 [CT07]	New Haven County, CT	50 [0.69]	1H	2072	0.5	0.1	0.01	5.83
<b>Wallingford Energy, LLC</b>	55517 [CT02]	New Haven County, CT	50 [0.73]	1H	2056	0.48	0.09	0	5.86
<b>Wallingford Energy, LLC</b>	55517 [CT03]	New Haven County, CT	50 [0.7]	1H	2056	0.5	0.09	0.01	5.86
<b>Wallingford Energy, LLC</b>	55517 [CT05]	New Haven County, CT	50 [0.73]	1H	2056	0.48	0.08	0	5.86
<b>Wallingford Energy, LLC</b>	55517 [CT06]	New Haven County, CT	50 [0.7]	1H	2072	0.51	0.1	0.01	5.97
<b>Wallingford Energy, LLC</b>	55517 [CT04]	New Haven County, CT	50 [0.74]	1H	2056	0.48	0.08	0.01	5.98

Facility name	Facility [unit] ID	Location	Nameplate capacity (MW) [capacity factor]	Ramp	Retirement year	CO2 tons MW <sup>-1</sup>	NOx lbs. MW <sup>-1</sup>	SO2 lbs. MW <sup>-1</sup>	Heat input MMBtu MW <sup>-1</sup>
<b>Waterbury Generation</b>	56629 [10]	New Haven County, CT	96 [0.69]	1H	2064	0.47	0.14	0.02	5.47
<b>Waters River</b>	1678 [1]	Essex County, MA	21.3 [0.68]	1H	2026	0.78	5.47	0.01	7.97
<b>Waters River</b>	1678 [2]	Essex County, MA	49.9 [0.49]	1H	2026	0.75	3.39	0.01	5.64
<b>Waterside Power, LLC</b>	56189 [4]	Fairfield County, CT	23.2 [0.92]	1H	2059	0.78	0.1	0.01	13.17
<b>Waterside Power, LLC</b>	56189 [5]	Fairfield County, CT	23.2 [0.92]	1H	2059	0.78	0.1	0.01	13.17
<b>Waterside Power, LLC</b>	56189 [7]	Fairfield County, CT	23.2 [0.92]	1H	2061	0.78	0.1	0.01	13.17
<b>Westbrook Energy Center</b>	55294 [2]	Cumberland County, ME	379.7 [0.59]	12H	2056	0.38	0.1	0	3.76
<b>Westbrook Energy Center</b>	55294 [1]	Cumberland County, ME	379.7 [0.59]	12H	2056	0.38	0.1	0	3.78
<b>White Lake</b>	2369 [CT1]	Carroll County, NH	18.6 [0.42]	10M	2024	0.78	23.01	0.01	12.95
<b>William F Wyman</b>	1507 [2]	Cumberland County, ME	50 [0.17]	OVER	2013	1.35	3.97	10.65	2.62
<b>William F Wyman</b>	1507 [1]	Cumberland County, ME	50 [0.24]	OVER	2012	1.22	3.45	9.63	3.34
<b>William F Wyman</b>	1507 [3]	Cumberland County, ME	213.6 [0.18]	OVER	2020	0.9	1.6	7.09	1.92
<b>William F Wyman</b>	1507 [4]	Cumberland County, ME	649.1 [0.35]	OVER	2030	0.87	1.75	6.52	3.54

Table S5: Externally derived parameters for the generation expansion model

Description	Probabilistic treatment	Calculation method or source
Hourly electricity demand through 2050	Deterministic	Data provided by ISO-NE (Commonwealth of Massachusetts, 2020).
Hourly nuclear, hydropower and biomass capacity factors	Deterministic	Data provided by ISO-NE (Commonwealth of Massachusetts, 2020).
Solar PV, onshore wind and offshore wind capacity factors	Modeled distributions (1 <sup>st</sup> to 99 <sup>th</sup> percentiles)	Non-parametric bootstrap sample year provided by ISO-NE (2024a).; linear regression employed to compute missing percentiles ranging from 1 to 99 .
Energy storage operating constrains	Deterministic	Data provided by ISO-NE (Commonwealth of Massachusetts, 2020).
Hourly electricity imports from other jurisdictions	Empirical distributions (1 <sup>st</sup> to 99 <sup>th</sup> percentiles)	Empirical distributions for percentiles ranging from 1 to 99 were simulated using historical data provided by ISO-NE (2024b).
Fossil fuel facility data (e.g., nameplate capacity, stack heights, age and planned retirements)	Deterministic	Data provided by U.S. EPA CAMPD API. eGrid and EIA Form 860 were consulted to cross reference CAMPD data. (U.S. EIA 860, 2023; U.S. EPA CAMPD, 2024; U.S. EPA eGrid, 2022).
Fossil fuel hourly generation data	Empirical distributions (1 <sup>st</sup> to 99 <sup>th</sup> percentiles)	Empirical distributions for percentiles ranging from 1 to 99 were simulated using historical data provided by U.S. EPA CAMPD (2024).
	Uniform distributions from available estimates	Where historical data were unavailable, data were pooled from comparable facility types within the U.S. EPA CAMPD.
Fossil fuel hourly emissions data (CO <sub>2</sub> , SO <sub>2</sub> and NO <sub>x</sub> )	Empirical distributions (1 <sup>st</sup> to 99 <sup>th</sup> percentiles)	Empirical distributions for percentiles ranging from 1 to 99 were simulated using historical data provided by U.S. EPA CAMPD (2024).
	Uniform distributions from available estimates	Where historical data were unavailable, data were pooled from comparable facility types within the U.S. EPA CAMPD.

Table S6: Externally derived parameters for cost calculations

<b>Description</b>	<b>Probabilistic treatment</b>	<b>Calculation method or source</b>	<b>Location in the manuscript</b>
CAPEX, FOM and VOM costs	Uniform distributions from available estimates	Data provided by NREL (2024).	SI section 2.8
Fossil generation fuel costs	Uniform distributions from available estimates	Data provided by NREL (2021).	SI section 2.8
Non-fossil generation fuel costs	Uniform distributions from available estimates	Data provided by NREL (2024).	SI section 2.8
Electricity import costs	Uniform distributions from available estimates	Imports from Canada provided by Calder et al., (2022) and imports from NYISO provided by DeSantis et al., (2021).	SI section 2.9
GHG (CO <sub>2</sub> , CH <sub>4</sub> and N <sub>2</sub> O) emissions economic valuation	Uniform distributions from available estimates	Data provided by Calder et al., (2022).	SI section 2.10
GHG (CH <sub>4</sub> and N <sub>2</sub> O) emission factors	Uniform distributions from available estimates	Data provided by U.S. EPA GHGRP (2024) to identify the CO <sub>2</sub> <sub>eq</sub> of CH <sub>4</sub> and N <sub>2</sub> O emissions for different fuel type.	SI section 2.10
Air emissions (SO <sub>2</sub> , NO <sub>x</sub> , VOC, PM <sub>2.5</sub> and PM <sub>10</sub> ) and economic valuation	Deterministic valuations based on stack height and county	Data provided by AP3 model (Muller, 2022).	SI section 2.11
CO emissions economic valuation	Uniform distributions from available estimates	Data provided by Calder et al., (2022).	SI section 2.11
Ambient air pollutant (CO, TPM and VOC) emission factors	Uniform distributions from available estimates	EIA 923 (2023) data was pooled to calculate TPM for each facility and U.S. EPA AP-42 (2024) guidelines were used to estimate VOC and CO emissions.	SI section 2.11
Unmet demand penalty	Deterministic	EVOLL model used by ISO-NE (Potomac Economics, 2024).	SI section 2.12
New hydroelectric dam in Canada emission factors and costs	Uniform distributions from available estimates	CAPEX was estimated using (Commonwealth of Massachusetts, 2020; Hollmann et al., 2014). FOM was estimate using IEA (2010). CH <sub>4</sub> emissions were estimated using Delwiche et al., (2022) and Canadian dams as a reference.	SI section 5
CPI factors	Deterministic	Data provided by U.S. Bureau of Labor Statistics (2024) API.	SI section 2.15

Table S7: Summary of fuel-specific emission factors, including non-biogenic CO<sub>2</sub>-eq for CH<sub>4</sub> and N<sub>2</sub>O emissions, PM rates and ratios, and estimated CO and VOC emissions. Details on sources for these estimates is provided in SI Table S6.

<b>Fuel category</b>	<b>non-biogenic CH<sub>4</sub>-to-CO<sub>2</sub> (ratio %)</b>	<b>non-biogenic N<sub>2</sub>O-to-CO<sub>2</sub> (ratio %)</b>	<b>PM (lbs MMBtu<sup>-1</sup>)</b>	<b>PM<sub>2.5</sub>-to-PM (ratio %)</b>	<b>PM<sub>10</sub>-to-PM (ratio %)</b>	<b>CO (tons MMBtu<sup>-1</sup>)</b>	<b>VOC (tons MMBtu<sup>-1</sup>)</b>
Oil	9.66E-04	2.62E-03	2.45E-02	69%	31%	1.67E-05	4.29E-06
Gas (combined cycle)	4.91E-04	6.55E-04	1.09E-02	100%	0%	1.50E-05	1.05E-06
Gas (combustion turbine)	5.26E-04	7.27E-04	1.71E-02	100%	0%	1.50E-05	1.05E-06
Coal	3.13E-03	5.48E-03	1.09E-02	32.5%	67.5%	9.62E-06	1.09E-06
Wood	n/a	n/a	2.94E-03	100%	0%	3.00E-04	8.50E-06

Table S8: Facility specific social costs of air emissions (2024-USD tonne<sup>-1</sup>). Details on sources for these estimates is provided in SI Table S7.

Facility name	Facility [unit] ID	Location	Primary fuel type	Stack height (ft)	Social cost (2024-USD tonne <sup>-1</sup> )					
					NO <sub>x</sub>	SO <sub>2</sub>	VOC	CO	PM <sub>2.5</sub>	PM <sub>10</sub>
<b>Alfred L Pierce Generating Station</b>	6635 [AP-1]	New Haven, CT	Pipeline Natural Gas	120	85.28	3095.76	1152.24	1406.75	10322.52	1378.32
<b>Bellingham</b>	10307 [1]	Norfolk, MA	Pipeline Natural Gas	120	97.18	3639.16	1503.26	1653.25	13582.89	2084.34
<b>Bellingham</b>	10307 [2]	Norfolk, MA	Pipeline Natural Gas	120	97.18	3639.16	1503.26	1653.25	13582.89	2084.34
<b>Bellingham Power Generation LLC</b>	55211 [1]	Norfolk, MA	Pipeline Natural Gas	120	97.18	3639.16	1503.26	1653.25	13582.89	2084.34
<b>Bellingham Power Generation LLC</b>	55211 [2]	Norfolk, MA	Pipeline Natural Gas	120	97.18	3639.16	1503.26	1653.25	13582.89	2084.34
<b>Berkshire Power</b>	55041 [1]	Hampden, MA	Pipeline Natural Gas	120	77.34	2306.45	765.51	1048.7	6613.95	1070.92
<b>Blackstone Power Generation LLC</b>	55212 [1]	Worcester, MA	Pipeline Natural Gas	120	45.61	4620.84	1455.66	2098.57	12803.49	2135.9

Facility name	Facility [unit] ID	Location	Primary fuel type	Stack height (ft)	Social cost (2024-USD tonne <sup>-1</sup> )					
					NO <sub>x</sub>	SO <sub>2</sub>	VOC	CO	PM <sub>2.5</sub>	PM <sub>10</sub>
<b>Blackstone Power Generation LLC</b>	55212 [2]	Worcester, MA	Pipeline Natural Gas	120	45.61	4620.84	1455.66	2098.57	12803.49	2135.9
<b>Bridgeport Energy</b>	55042 [BE1]	Fairfield, CT	Pipeline Natural Gas	120	255.83	4616.87	1786.86	2096.77	15996.44	2298.52
<b>Bridgeport Energy</b>	55042 [BE2]	Fairfield, CT	Pipeline Natural Gas	120	255.83	4616.87	1786.86	2096.77	15996.44	2298.52
<b>Bridgeport Harbor Station</b>	568 [BHB5]	Fairfield, CT	Pipeline Natural Gas	298	27.76	2389.75	840.87	1086.48	6970.92	1003.5
<b>Burgess BioPower</b>	58054 [ST01]	Coos, NH	Wood	120	65.45	938.05	160.64	427.95	1245.45	202.29
<b>Canal Station</b>	1599 [2]	Barnstable, MA	Residual Oil	498	277.65	1021.34	243.93	465.73	1572.67	212.2
<b>Canal Station</b>	1599 [3]	Barnstable, MA	Pipeline Natural Gas	498	277.65	1021.34	243.93	465.73	1572.67	212.2
<b>Cleary Flood</b>	1682 [9]	Bristol, MA	Pipeline Natural Gas	187	93.21	2980.74	1021.34	1354.57	9057.24	1346.59
<b>Cos Cob</b>	542 [13]	Litchfield, CT	Other Oil	120	144.77	4273.78	1437.82	1941.13	12839.19	1733.31
<b>Cos Cob</b>	542 [14]	Litchfield, CT	Other Oil	120	144.77	4273.78	1437.82	1941.13	12839.19	1733.31

Facility name	Facility [unit] ID	Location	Primary fuel type	Stack height (ft)	Social cost (2024-USD tonne <sup>-1</sup> )					
					NO <sub>x</sub>	SO <sub>2</sub>	VOC	CO	PM <sub>2.5</sub>	PM <sub>10</sub>
<b>CPV Towantic Energy Center</b>	56047 [1]	New Haven, CT	Pipeline Natural Gas	150	85.28	3095.76	1152.24	1406.75	10322.52	1378.32
<b>CPV Towantic Energy Center</b>	56047 [2]	New Haven, CT	Pipeline Natural Gas	150	85.28	3095.76	1152.24	1406.75	10322.52	1378.32
<b>Dartmouth Power</b>	52026 [1]	Bristol, MA	Pipeline Natural Gas	120	93.21	2980.74	1021.34	1354.57	9057.24	1346.59
<b>Dartmouth Power</b>	52026 [2]	Bristol, MA	Pipeline Natural Gas	120	93.21	2980.74	1021.34	1354.57	9057.24	1346.59
<b>Devon</b>	544 [10]	Fairfield, CT	Other Oil	340	27.76	2389.75	840.87	1086.48	6970.92	1003.5
<b>Devon</b>	544 [11]	Fairfield, CT	Pipeline Natural Gas	340	27.76	2389.75	840.87	1086.48	6970.92	1003.5
<b>Devon</b>	544 [12]	Fairfield, CT	Pipeline Natural Gas	340	27.76	2389.75	840.87	1086.48	6970.92	1003.5
<b>Devon</b>	544 [13]	Fairfield, CT	Pipeline Natural Gas	340	27.76	2389.75	840.87	1086.48	6970.92	1003.5
<b>Devon</b>	544 [14]	Fairfield, CT	Pipeline Natural Gas	340	27.76	2389.75	840.87	1086.48	6970.92	1003.5

Facility name	Facility [unit] ID	Location	Primary fuel type	Stack height (ft)	Social cost (2024-USD tonne <sup>-1</sup> )					
					NO <sub>x</sub>	SO <sub>2</sub>	VOC	CO	PM <sub>2.5</sub>	PM <sub>10</sub>
<b>Devon</b>	544 [15]	Fairfield, CT	Diesel Oil	340	27.76	2389.75	840.87	1086.48	6970.92	1003.5
<b>Devon</b>	544 [16]	Fairfield, CT	Diesel Oil	340	27.76	2389.75	840.87	1086.48	6970.92	1003.5
<b>Devon</b>	544 [17]	Fairfield, CT	Diesel Oil	340	27.76	2389.75	840.87	1086.48	6970.92	1003.5
<b>Devon</b>	544 [18]	Fairfield, CT	Diesel Oil	340	27.76	2389.75	840.87	1086.48	6970.92	1003.5
<b>Dighton</b>	55026 [1]	Bristol, MA	Pipeline Natural Gas	120	93.21	2980.74	1021.34	1354.57	9057.24	1346.59
<b>Exelon West Medway II</b>	59882 [J4]	Norfolk, MA	Pipeline Natural Gas	120	97.18	3639.16	1503.26	1653.25	13582.89	2084.34
<b>Exelon West Medway II</b>	59882 [J5]	Norfolk, MA	Pipeline Natural Gas	120	97.18	3639.16	1503.26	1653.25	13582.89	2084.34
<b>Fore River Energy Center</b>	55317 [11]	Norfolk, MA	Pipeline Natural Gas	255	49.58	2010.96	654.45	914.65	5310.99	811.13
<b>Fore River Energy Center</b>	55317 [12]	Norfolk, MA	Pipeline Natural Gas	255	49.58	2010.96	654.45	914.65	5310.99	811.13
<b>Granite Ridge Energy</b>	55170 [1]	Hillsborough, NH	Pipeline Natural Gas	120	77.34	3058.08	795.26	1389.66	6828.13	1189.92
<b>Granite Ridge Energy</b>	55170 [2]	Hillsborough, NH	Pipeline Natural Gas	120	77.34	3058.08	795.26	1389.66	6828.13	1189.92

Facility name	Facility [unit] ID	Location	Primary fuel type	Stack height (ft)	Social cost (2024-USD tonne <sup>-1</sup> )					
					NO <sub>x</sub>	SO <sub>2</sub>	VOC	CO	PM <sub>2.5</sub>	PM <sub>10</sub>
<b>J C McNeil</b>	589 [1]	Chittenden, VT	Wood	120	63.46	997.55	226.08	454.94	1743.23	311.36
<b>Kendall Green Energy LLC</b>	1595 [4]	Middlesex, MA	Pipeline Natural Gas	120	107.09	5289.18	1889.98	2401.74	16980.1	2718.96
<b>Kendall Green Energy LLC</b>	1595 [S6]	Middlesex, MA	Diesel Oil	120	107.09	5289.18	1889.98	2401.74	16980.1	2718.96
<b>Kleen Energy Systems Project</b>	56798 [U1]	Middlesex, CT	Pipeline Natural Gas	215	69.41	1897.92	592.97	863.37	5154.32	763.53
<b>Kleen Energy Systems Project</b>	56798 [U2]	Middlesex, CT	Pipeline Natural Gas	215	69.41	1897.92	592.97	863.37	5154.32	763.53
<b>Lake Road Generating Company</b>	55149 [LRG1]	Windham, CT	Pipeline Natural Gas	120	148.74	2901.41	767.5	1318.59	6689.31	1068.94
<b>Lake Road Generating Company</b>	55149 [LRG2]	Windham, CT	Pipeline Natural Gas	120	148.74	2901.41	767.5	1318.59	6689.31	1068.94
<b>Lake Road Generating Company</b>	55149 [LRG3]	Windham, CT	Pipeline Natural Gas	120	148.74	2901.41	767.5	1318.59	6689.31	1068.94
<b>Maine Independence Station</b>	55068 [1]	Penobscot, ME	Pipeline Natural Gas	120	29.75	374.82	57.51	172.45	412.5	71.39
<b>Maine Independence Station</b>	55068 [2]	Penobscot, ME	Pipeline Natural Gas	120	29.75	374.82	57.51	172.45	412.5	71.39

Facility name	Facility [unit] ID	Location	Primary fuel type	Stack height (ft)	Social cost (2024-USD tonne <sup>-1</sup> )					
					NO <sub>x</sub>	SO <sub>2</sub>	VOC	CO	PM <sub>2.5</sub>	PM <sub>10</sub>
<b>Manchester Street Station</b>	3236 [10]	Providence, RI	Pipeline Natural Gas	120	113.04	3143.36	1118.52	1428.34	9824.74	1642.08
<b>Manchester Street Station</b>	3236 [11]	Providence, RI	Pipeline Natural Gas	120	113.04	3143.36	1118.52	1428.34	9824.74	1642.08
<b>Manchester Street Station</b>	3236 [9]	Providence, RI	Pipeline Natural Gas	120	113.04	3143.36	1118.52	1428.34	9824.74	1642.08
<b>MBTA South Boston Power Facility</b>	10176 [A]	Suffolk, MA	Other Oil	120	93.21	3716.5	1753.14	1688.33	15883.39	2427.43
<b>MBTA South Boston Power Facility</b>	10176 [B]	Suffolk, MA	Other Oil	120	93.21	3716.5	1753.14	1688.33	15883.39	2427.43
<b>Medway Station</b>	1592 [J1T1]	Norfolk, MA	Diesel Oil	120	97.18	3639.16	1503.26	1653.25	13582.89	2084.34
<b>Medway Station</b>	1592 [J1T2]	Norfolk, MA	Diesel Oil	120	97.18	3639.16	1503.26	1653.25	13582.89	2084.34
<b>Medway Station</b>	1592 [J2T1]	Norfolk, MA	Diesel Oil	120	97.18	3639.16	1503.26	1653.25	13582.89	2084.34
<b>Medway Station</b>	1592 [J2T2]	Norfolk, MA	Diesel Oil	120	97.18	3639.16	1503.26	1653.25	13582.89	2084.34
<b>Medway Station</b>	1592 [J3T1]	Norfolk, MA	Diesel Oil	120	97.18	3639.16	1503.26	1653.25	13582.89	2084.34
<b>Medway Station</b>	1592 [J3T2]	Norfolk, MA	Diesel Oil	120	97.18	3639.16	1503.26	1653.25	13582.89	2084.34
<b>Merrimack</b>	2364 [1]	Merrimack, NH	Coal	445	243.93	1483.43	362.92	675.35	2572.2	414.49

Facility name	Facility [unit] ID	Location	Primary fuel type	Stack height (ft)	Social cost (2024-USD tonne <sup>-1</sup> )					
					NO <sub>x</sub>	SO <sub>2</sub>	VOC	CO	PM <sub>2.5</sub>	PM <sub>10</sub>
<b>Merrimack</b>	2364 [2]	Merrimack, NH	Coal	445	243.93	1483.43	362.92	675.35	2572.2	414.49
<b>Middletown</b>	562 [12]	Middlesex, CT	Diesel Oil	266	251.87	1223.63	351.03	557.5	2500.81	374.82
<b>Middletown</b>	562 [13]	Middlesex, CT	Diesel Oil	266	251.87	1223.63	351.03	557.5	2500.81	374.82
<b>Middletown</b>	562 [14]	Middlesex, CT	Diesel Oil	266	251.87	1223.63	351.03	557.5	2500.81	374.82
<b>Middletown</b>	562 [15]	Middlesex, CT	Diesel Oil	266	251.87	1223.63	351.03	557.5	2500.81	374.82
<b>Middletown</b>	562 [4]	Middlesex, CT	Residual Oil	266	251.87	1223.63	351.03	557.5	2500.81	374.82
<b>Milford Power Company LLC</b>	55126 [CT01]	New Haven, CT	Pipeline Natural Gas	120	85.28	3095.76	1152.24	1406.75	10322.52	1378.32
<b>Milford Power Company LLC</b>	55126 [CT02]	New Haven, CT	Pipeline Natural Gas	120	85.28	3095.76	1152.24	1406.75	10322.52	1378.32
<b>Milford Power, LLC</b>	54805 [1]	Worcester, MA	Pipeline Natural Gas	120	45.61	4620.84	1455.66	2098.57	12803.49	2135.9
<b>Millennium Power</b>	55079 [1]	Worcester, MA	Pipeline Natural Gas	120	45.61	4620.84	1455.66	2098.57	12803.49	2135.9
<b>Montville</b>	546 [6]	New London, CT	Residual Oil	249	148.74	3270.29	928.13	1485.92	8053.75	1253.38

Facility name	Facility [unit] ID	Location	Primary fuel type	Stack height (ft)	Social cost (2024-USD tonne <sup>-1</sup> )					
					NO <sub>x</sub>	SO <sub>2</sub>	VOC	CO	PM <sub>2.5</sub>	PM <sub>10</sub>
<b>New Haven Harbor</b>	6156 [NHB1]	New Haven, CT	Residual Oil	389	339.13	1659.93	521.58	755.42	4077.45	563.23
<b>New Haven Harbor</b>	6156 [NHHS2]	New Haven, CT	Diesel Oil	389	339.13	1659.93	521.58	755.42	4077.45	563.23
<b>New Haven Harbor</b>	6156 [NHHS3]	New Haven, CT	Diesel Oil	389	339.13	1659.93	521.58	755.42	4077.45	563.23
<b>New Haven Harbor</b>	6156 [NHHS4]	New Haven, CT	Diesel Oil	389	339.13	1659.93	521.58	755.42	4077.45	563.23
<b>Newington</b>	8002 [1]	Rockingham, NH	Residual Oil	410	160.64	1495.33	442.25	680.75	3323.83	517.61
<b>Newington Energy</b>	55661 [1]	Rockingham, NH	Pipeline Natural Gas	150	69.41	2812.17	872.6	1278.1	7674.96	1209.75
<b>Newington Energy</b>	55661 [2]	Rockingham, NH	Pipeline Natural Gas	150	69.41	2812.17	872.6	1278.1	7674.96	1209.75
<b>Ocean State Power</b>	51030 [1]	Providence, RI	Pipeline Natural Gas	120	113.04	3143.36	1118.52	1428.34	9824.74	1642.08
<b>Ocean State Power</b>	51030 [2]	Providence, RI	Pipeline Natural Gas	120	113.04	3143.36	1118.52	1428.34	9824.74	1642.08
<b>Ocean State Power II</b>	54324 [3]	Providence, RI	Pipeline Natural Gas	120	113.04	3143.36	1118.52	1428.34	9824.74	1642.08
<b>Ocean State Power II</b>	54324 [4]	Providence, RI	Pipeline Natural Gas	120	113.04	3143.36	1118.52	1428.34	9824.74	1642.08

Facility name	Facility [unit] ID	Location	Primary fuel type	Stack height (ft)	Social cost (2024-USD tonne <sup>-1</sup> )					
					NO <sub>x</sub>	SO <sub>2</sub>	VOC	CO	PM <sub>2.5</sub>	PM <sub>10</sub>
<b>Pittsfield Generating</b>	50002 [1]	Berkshire, MA	Pipeline Natural Gas	120	105.11	2193.41	624.71	997.42	5269.34	777.41
<b>Pittsfield Generating</b>	50002 [2]	Berkshire, MA	Pipeline Natural Gas	120	105.11	2193.41	624.71	997.42	5269.34	777.41
<b>Pittsfield Generating</b>	50002 [3]	Berkshire, MA	Pipeline Natural Gas	120	105.11	2193.41	624.71	997.42	5269.34	777.41
<b>Rhode Island State Energy Center</b>	55107 [RISEP1]	Providence, RI	Pipeline Natural Gas	185	113.04	3143.36	1118.52	1428.34	9824.74	1642.08
<b>Rhode Island State Energy Center</b>	55107 [RISEP2]	Providence, RI	Pipeline Natural Gas	185	113.04	3143.36	1118.52	1428.34	9824.74	1642.08
<b>Rumford Power</b>	55100 [1]	Oxford, ME	Pipeline Natural Gas	120	77.34	967.8	164.61	441.44	1336.67	210.22
<b>Salem Harbor Station NGCC</b>	60903 [1]	Essex, MA	Pipeline Natural Gas	230	69.41	2322.32	874.59	1055.89	7760.23	1183.97
<b>Salem Harbor Station NGCC</b>	60903 [2]	Essex, MA	Pipeline Natural Gas	230	69.41	2322.32	874.59	1055.89	7760.23	1183.97
<b>Schiller</b>	2367 [4]	Rockingham, NH	Coal	226	69.41	2812.17	872.6	1278.1	7674.96	1209.75

Facility name	Facility [unit] ID	Location	Primary fuel type	Stack height (ft)	Social cost (2024-USD tonne <sup>-1</sup> )					
					NO <sub>x</sub>	SO <sub>2</sub>	VOC	CO	PM <sub>2.5</sub>	PM <sub>10</sub>
<b>Schiller</b>	2367 [6]	Rockingham, NH	Coal	226	69.41	2812.17	872.6	1278.1	7674.96	1209.75
<b>Stony Brook Energy Center</b>	6081 [1]	Hampden, MA	Pipeline Natural Gas	120	77.34	2306.45	765.51	1048.7	6613.95	1070.92
<b>Stony Brook Energy Center</b>	6081 [2]	Hampden, MA	Pipeline Natural Gas	120	77.34	2306.45	765.51	1048.7	6613.95	1070.92
<b>Stony Brook Energy Center</b>	6081 [3]	Hampden, MA	Pipeline Natural Gas	120	77.34	2306.45	765.51	1048.7	6613.95	1070.92
<b>Stony Brook Energy Center</b>	6081 [4]	Hampden, MA	Diesel Oil	120	77.34	2306.45	765.51	1048.7	6613.95	1070.92
<b>Stony Brook Energy Center</b>	6081 [5]	Hampden, MA	Diesel Oil	120	77.34	2306.45	765.51	1048.7	6613.95	1070.92
<b>Tiverton Power, LLC</b>	55048 [1]	Newport, RI	Pipeline Natural Gas	120	97.18	2231.09	763.53	1014.51	6578.25	981.68
<b>Wallingford Energy, LLC</b>	55517 [CT01]	New Haven, CT	Pipeline Natural Gas	120	85.28	3095.76	1152.24	1406.75	10322.52	1378.32
<b>Wallingford Energy, LLC</b>	55517 [CT02]	New Haven, CT	Pipeline Natural Gas	120	85.28	3095.76	1152.24	1406.75	10322.52	1378.32
<b>Wallingford Energy, LLC</b>	55517 [CT03]	New Haven, CT	Pipeline Natural Gas	120	85.28	3095.76	1152.24	1406.75	10322.52	1378.32

Facility name	Facility [unit] ID	Location	Primary fuel type	Stack height (ft)	Social cost (2024-USD tonne <sup>-1</sup> )					
					NO <sub>x</sub>	SO <sub>2</sub>	VOC	CO	PM <sub>2.5</sub>	PM <sub>10</sub>
<b>Wallingford Energy, LLC</b>	55517 [CT04]	New Haven, CT	Pipeline Natural Gas	120	85.28	3095.76	1152.24	1406.75	10322.52	1378.32
<b>Wallingford Energy, LLC</b>	55517 [CT05]	New Haven, CT	Pipeline Natural Gas	120	85.28	3095.76	1152.24	1406.75	10322.52	1378.32
<b>Wallingford Energy, LLC</b>	55517 [CT06]	New Haven, CT	Pipeline Natural Gas	120	85.28	3095.76	1152.24	1406.75	10322.52	1378.32
<b>Wallingford Energy, LLC</b>	55517 [CT07]	New Haven, CT	Pipeline Natural Gas	120	85.28	3095.76	1152.24	1406.75	10322.52	1378.32
<b>Waterbury Generation</b>	56629 [10]	New Haven, CT	Pipeline Natural Gas	120	85.28	3095.76	1152.24	1406.75	10322.52	1378.32
<b>Waters River</b>	1678 [1]	Essex, MA	Pipeline Natural Gas	120	69.41	2322.32	874.59	1055.89	7760.23	1183.97
<b>Waters River</b>	1678 [2]	Essex, MA	Pipeline Natural Gas	120	69.41	2322.32	874.59	1055.89	7760.23	1183.97
<b>Westbrook Energy Center</b>	55294 [1]	Cumberland, ME	Pipeline Natural Gas	120	101.14	1447.73	329.21	659.16	2784.4	444.24
<b>Westbrook Energy Center</b>	55294 [2]	Cumberland, ME	Pipeline Natural Gas	120	101.14	1447.73	329.21	659.16	2784.4	444.24
<b>William F Wyman</b>	1507 [4]	Cumberland, ME	Residual Oil	320	243.93	926.15	220.13	422.55	1330.72	210.22

Table S9: Methane emissions from Canadian reservoirs and relevant facilities. Total reservoir capacity 7,892 MW and hydroelectric capacity factor of 65%. Details on sources for these estimates is provided in SI Table S5.

Reservoir	Facility	Emissions [mg CH <sub>4</sub> - C (m <sup>2</sup> day) <sup>-1</sup> ]	Area (km <sup>2</sup> )	Emissions [mg CH <sub>4</sub> - C (day) <sup>-1</sup> ]	Capacity (MW)	Emissions [mg CH <sub>4</sub> - C (MW day) <sup>-1</sup> ]	Emissions [mg CH <sub>4</sub> - C (MW year) <sup>-1</sup> ]	Emissions [kg CH <sub>4</sub> -C (MWh) <sup>-1</sup> ]
Eastmain Reservoir	Eastmain-1				480			
	Eastmain-1-A	9.43	602.9	5.69E9	768	4.07E6	714.22	<b>0.26</b>
	Sarcelle				150			
Laforge-1 Reservoir	Laforge-1	13	1,288	1.67E10	878	1.91E7	3349.24	<b>1.22</b>
Robert- Bourassa Reservoir	Robert- Bourassa	5	2,835	1.42E10	5,616	2.52E6	443.28	<b>0.16</b>

Table S10: Net present value of costs (in billions of 2024 USD, discounted at 1.5%) across eight decarbonization pathways (A, B1, B2, B3(1), B3(2), C1, C2, C3, D). Costs are disaggregated into capital expenditures (CAPEX), fixed and variable operations and maintenance (O&M), fuel, imports, greenhouse gas (GHG) and air emissions, and unmet demand penalties; values in parentheses indicate uncertainty ranges, and the “Sum” row shows total costs. Pathway B3 compares two cost-accounting methods for new hydroelectric development in Canada: B3(1) assumes U.S.-only costs (infrastructure plus imported power), while B3(2) captures total social costs by also accounting for generation-side impacts (e.g., reservoir methane emissions). Upper and lower bounds in brackets show the 90% CI considering NREL cost various scenarios.

	<b>A</b>	<b>B1</b>	<b>B2</b>	<b>B3(1)</b>	<b>B3(2)</b>	<b>C1</b>	<b>C2</b>	<b>C3</b>	<b>D</b>
<b>CAPEX</b>	0 (0-0)	200.89 (159.72- 248.41)	225.98 (179.33- 279.84)	189.21 (150.58- 233.78)	238.76 (179.99- 303.47)	226.19 (114.01- 342.26)	223.33 (170.27- 283.01)	202.96 (157.74- 254.17)	79.95 (67.23- 94.83)
<b>Fixed O&amp;M</b>	46.38 (40.76-51.44)	79.56 (67.56-91.97)	85.24 (72.66- 98.35)	76.94 (65.21-89.03)	131.65 (87.31- 176.36)	90.88 (72.59- 115.43)	86.21 (72.57- 101.15)	81.22 (68.43- 94.94)	63.84 (54.9-72.77)
<b>Variable O&amp;M</b>	7.71 (7.27-8.11)	3.59 (3.21-3.93)	3.93 (3.55-4.27)	3.59 (3.21-3.93)	3.59 (3.21-3.93)	10.23 (8.98-11.25)	4.65 (4.16-5.08)	4.01 (3.56-4.4)	9.2 (8.73-9.63)
<b>Fuel</b>	53.73 (53.73-53.73)	21.79 (21.79-21.79)	25.56 (25.56- 25.56)	21.72 (21.72-21.72)	21.72 (21.72- 21.72)	50.02 (47.31- 52.81)	27.55 (27.2-27.91)	22.61 (22.38- 22.84)	74.58 (74.58- 74.58)
<b>Imports</b>	21.88 (10.97-32.8)	74.49 (37.4-111.59)	28.26 (14.15- 42.37)	94.7 (47.56- 141.84)	17.84 (8.91-26.76)	21.88 (10.97-32.8)	28.26 (14.15- 42.37)	74.49 (37.4- 111.59)	74.49 (37.4- 111.59)
<b>GHG emissions</b>	629.96 (629.96- 629.96)	197.62 (197.62- 197.62)	237.72 (237.72- 237.72)	196.72 (196.72- 196.72)	204.07 (198.37- 209.76)	192.35 (192.35- 192.35)	218.75 (218.75- 218.75)	181.3 (181.3- 181.3)	780.83 (780.83- 780.83)
<b>Air emissions</b>	1.45 (1.45-1.45)	0.68 (0.68-0.68)	0.78 (0.78-0.78)	0.67 (0.67-0.67)	0.67 (0.67-0.67)	0.62 (0.62-0.62)	0.73 (0.73-0.73)	0.63 (0.63-0.63)	1.35 (1.35-1.35)
<b>Unmet demand penalty</b>	488.85 (488.85- 488.85)	5.39 (5.39-5.39)	11.97 (11.97- 11.97)	4.56 (4.56-4.56)	4.56 (4.56-4.56)	5.52 (5.52-5.52)	6.81 (6.81-6.81)	3.23 (3.23-3.23)	2.34 (2.34-2.34)
<b>Sum</b>	1249.95 (1232.98- 1266.33)	584.01 (493.37- 681.37)	619.44 (545.73- 700.85)	588.11 (490.23- 692.25)	622.86 (504.75- 747.23)	597.68 (452.36- 753.03)	596.28 (514.64- 685.8)	570.46 (474.68- 673.11)	1086.59 (1027.37- 1147.93)

Table S11: Net present value of costs (in billions of 2024 USD, discounted at 2%) across eight decarbonization pathways

	<b>A</b>	<b>B1</b>	<b>B2</b>	<b>B3(1)</b>	<b>B3(2)</b>	<b>C1</b>	<b>C2</b>	<b>C3</b>	<b>D</b>
<b>CAPEX</b>	0 (0-0)	188.41 (149.78- 232.99)	211.75 (167.98- 262.31)	177.49 (141.26- 219.29)	226.35 (170.26- 288.03)	210.25 (106.23- 317.81)	209.44 (159.68- 265.42)	190.63 (148.12- 238.77)	74.75 (62.84- 88.67)
<b>Fixed O&amp;M</b>	43.57 (38.34-48.29)	73.9 (62.84-85.34)	79.11 (67.52- 91.18)	71.5 (60.68-82.64)	122.33 (81.22- 163.77)	83.89 (67.14- 106.33)	79.97 (67.4-93.71)	75.43 (63.64- 88.07)	59.56 (51.3-67.82)
<b>Variable O&amp;M</b>	7.23 (6.82-7.6)	3.41 (3.06-3.72)	3.73 (3.38-4.05)	3.41 (3.06-3.72)	3.41 (3.06-3.72)	9.47 (8.34-10.41)	4.39 (3.94-4.78)	3.79 (3.38-4.16)	8.56 (8.12-8.95)
<b>Fuel</b>	50.33 (50.33-50.33)	20.8 (20.8-20.8)	24.33 (24.33- 24.33)	20.76 (20.76-20.76)	20.76 (20.76- 20.76)	46.72 (44.25- 49.25)	26.18 (25.86- 26.51)	21.54 (21.34- 21.76)	69.01 (69.01- 69.01)
<b>Imports</b>	20.58 (10.31-30.84)	69 (34.64- 103.36)	26.42 (13.23-39.6)	87.3 (43.84- 130.75)	16.62 (8.3-24.93)	20.58 (10.31- 30.84)	26.42 (13.23-39.6)	69 (34.64- 103.36)	69 (34.64- 103.36)
<b>GHG emissions</b>	369.28 (369.28- 369.28)	116.5 (116.5-116.5)	139.91 (139.91- 139.91)	116.03 (116.03- 116.03)	121.34 (117.22- 125.46)	114.03 (114.03- 114.03)	129.01 (129.01- 129.01)	107.04 (107.04- 107.04)	455.51 (455.51- 455.51)
<b>Air emissions</b>	1.35 (1.35-1.35)	0.65 (0.65-0.65)	0.74 (0.74-0.74)	0.64 (0.64-0.64)	0.64 (0.64-0.64)	0.6 (0.6-0.6)	0.7 (0.7-0.7)	0.61 (0.61-0.61)	1.27 (1.27-1.27)
<b>Unmet demand penalty</b>	443.32 (443.32- 443.32)	4.98 (4.98-4.98)	11.04 (11.04- 11.04)	4.22 (4.22-4.22)	4.22 (4.22-4.22)	5.3 (5.3-5.3)	6.32 (6.32-6.32)	2.99 (2.99-2.99)	2.2 (2.2-2.2)
<b>Sum</b>	935.67 (919.77- 951.02)	477.64 (393.24- 568.33)	497.04 (428.14- 573.17)	481.34 (390.49- 578.06)	515.68 (405.69- 631.53)	490.84 (356.19- 634.58)	482.42 (406.13- 566.05)	471.03 (381.75- 566.74)	739.86 (684.9- 796.79)

Table S12: Net present value of costs (in billions of 2024 USD, discounted at 2.5%) across eight decarbonization pathways

	<b>A</b>	<b>B1</b>	<b>B2</b>	<b>B3(1)</b>	<b>B3(2)</b>	<b>C1</b>	<b>C2</b>	<b>C3</b>	<b>D</b>
<b>CAPEX</b>	0 (0-0)	176.98 (140.69- 218.89)	198.74 (157.61- 246.27)	166.75 (132.73- 206.03)	214.95 (161.33- 273.83)	195.66 (99.08- 295.45)	196.71 (149.98- 249.29)	179.32 (139.31- 224.63)	69.99 (58.83- 83.03)
<b>Fixed O&amp;M</b>	41 (36.12-45.4)	68.76 (58.54-79.31)	73.54 (62.84- 84.67)	66.55 (56.56-76.84)	113.85 (75.67- 152.32)	77.56 (62.19-98.1)	74.3 (62.71- 86.95)	70.17 (59.28- 81.82)	55.67 (48.02-63.3)
<b>Variable O&amp;M</b>	6.79 (6.41-7.13)	3.24 (2.92-3.53)	3.55 (3.22-3.84)	3.25 (2.92-3.54)	3.25 (2.92-3.54)	8.79 (7.75-9.65)	4.15 (3.73-4.52)	3.6 (3.21-3.93)	7.97 (7.57-8.34)
<b>Fuel</b>	47.23 (47.23-47.23)	19.87 (19.87-19.87)	23.2 (23.2-23.2)	19.85 (19.85-19.85)	19.85 (19.85- 19.85)	43.71 (41.47- 46.02)	24.91 (24.61- 25.21)	20.56 (20.37- 20.75)	63.96 (63.96- 63.96)
<b>Imports</b>	19.38 (9.72-29.05)	64.02 (32.14-95.9)	24.74 (12.39- 37.09)	80.6 (40.48- 120.73)	15.51 (7.75-23.27)	19.38 (9.72-29.05)	24.74 (12.39- 37.09)	64.02 (32.14-95.9)	64.02 (32.14-95.9)
<b>GHG emissions</b>	226.1 (226.1-226.1)	71.74 (71.74-71.74)	86.01 (86.01- 86.01)	71.48 (71.48-71.48)	75.52 (72.39- 78.64)	70.62 (70.62- 70.62)	79.47 (79.47- 79.47)	66.01 (66.01- 66.01)	277.48 (277.48- 277.48)
<b>Air emissions</b>	1.27 (1.27-1.27)	0.62 (0.62-0.62)	0.71 (0.71-0.71)	0.62 (0.62-0.62)	0.62 (0.62-0.62)	0.58 (0.58-0.58)	0.67 (0.67-0.67)	0.58 (0.58-0.58)	1.2 (1.2-1.2)
<b>Unmet demand penalty</b>	402.36 (402.36- 402.36)	4.6 (4.6-4.6)	10.2 (10.2-10.2)	3.91 (3.91-3.91)	3.91 (3.91-3.91)	5.09 (5.09-5.09)	5.88 (5.88-5.88)	2.77 (2.77-2.77)	2.06 (2.06-2.06)
<b>Sum</b>	744.13 (729.21- 758.54)	409.84 (331.12- 494.46)	420.69 (356.17-492)	413.03 (328.56-503)	447.47 (344.45- 555.99)	421.39 (296.49- 554.56)	410.82 (339.44- 489.08)	407.02 (323.66- 496.39)	542.35 (491.26- 595.27)

Table S13: Net present value of costs (billions of 2024 USD, discounted at 2%) for All-Options Pathway, as estimated by ISO-NE's Massachusetts Decarbonization Roadmap study (Commonwealth of Massachusetts, 2020). We excluded behind the meter, demand side and distribution cost items from the total cost estimate presented by ISO-NE, since we do not consider these costs in our study.

<b>Cost group</b>	<b>All-Options</b>	
Demand-side costs	\$	-
Electricity storage	\$	0.31
Electricity distribution	\$	-
Electricity transmission	\$	4.22
Gas pipelines	\$	1.89
Gas power plants	\$	0.21
In-state fuels production	\$	0.67
Biomass power plants	\$	0.09
Ground-mounted solar	\$	1.46
Rooftop solar	\$	-
Offshore wind	\$	3.04
Hydro purchases	\$	0.91
Zero carbon liquid imports	\$	1.53
Zero carbon gas imports	\$	0.14
Natural gas	\$	0.23
Oil products	\$	1.34
Other	\$	1.05
<b>Total (mean annualized costs 2024-bUSD for 2025-2050)</b>	<b>\$</b>	<b>17.08</b>
<b>NPV 2024-bUSD (2% discount rate)</b>	<b>\$</b>	<b>343.57</b>

Table S14: Net present value of air emission costs (in millions of 2024 USD, discounted at 1.5%) across eight decarbonization pathways. Each cell reports the mean cost estimate along with its corresponding uncertainty bounds (in parentheses, 90% CI and NREL cost scenarios), facilitating a comparative assessment of financial implications by pathway and location in the region.

	A	B1	B2	B3	C1	C2	C3	D
<b>Barnstable, MA</b>	22.31 (21.82-23.18)	4.67 (4.44-5.17)	4.82 (4.57-5.31)	4.71 (4.48-5.06)	5.32 (5.12-5.67)	4.9 (4.68-5.41)	4.71 (4.48-5.06)	19.97 (19.35-21.06)
<b>Berkshire, MA</b>	2.95 (1.58-3.13)	0.38 (0.27-0.49)	0.6 (0.44-0.76)	0.38 (0.28-0.5)	0.58 (0.43-0.72)	0.52 (0.37-0.67)	0.31 (0.22-0.41)	1.42 (1.15-1.68)
<b>Bristol, MA</b>	25.05 (5.91-25.96)	18.44 (6.23-19.1)	20.3 (19.55-20.98)	18.24 (17.47-19.07)	13.5 (1.17-14.13)	19.02 (18.3-19.65)	17.09 (16.29-17.8)	24.08 (3.67-26.07)
<b>Chittenden, VT</b>	16.87 (16.13-17.67)	3.76 (3.58-4.27)	3.8 (3.6-4.33)	3.76 (3.58-4.35)	3.86 (3.69-4.25)	3.81 (3.65-4.37)	3.76 (3.58-4.35)	17.11 (16.42-17.88)
<b>Coos, NH</b>	23.43 (22.71-24.26)	30.16 (29.29-30.84)	31.38 (30.6-32.29)	29.66 (28.85-30.37)	19.37 (18.17-20.16)	30.26 (29.42-30.87)	28.72 (27.72-29.62)	23.46 (22.74-24.29)
<b>Cumberland, ME</b>	94.13 (29.89-96.68)	37.76 (18.04-39.58)	40.56 (18.12-42.32)	37.68 (36.06-39.37)	34.74 (20.18-36.64)	39.16 (37.79-40.87)	36.45 (17.8-38.07)	96.77 (72.41-103.08)
<b>Essex, MA</b>	24.28 (1.16-28.26)	21.38 (0.07-22.55)	23.96 (0.08-25.23)	21.12 (19.98-22.14)	15.91 (0.09-17.23)	22.33 (0.08-23.52)	19.67 (0.07-20.67)	28.93 (0.8-31.88)
<b>Fairfield, CT</b>	100.72 (0.04-105.52)	57.47 (0.11-60.03)	67.37 (1.25-69.83)	57.1 (53.34-59.54)	49.93 (48.63-50.95)	61.85 (50.9-64.12)	52.28 (20.91-54.69)	176.41 (80.9-178.3)
<b>Hampden, MA</b>	16.97 (12.58-18.5)	12.89 (12.04-13.5)	14.46 (9.81-15.11)	12.72 (11.89-13.39)	9.65 (9.14-10.15)	13.34 (12.59-13.94)	11.83 (11.09-12.51)	16.88 (14.44-19.17)
<b>Hillsborough, NH</b>	43.36 (40.81-45.51)	7.35 (5.39-9.27)	12.16 (9.26-14.69)	7.27 (5.42-9.25)	9.67 (7.7-11.81)	10.05 (7.63-12.4)	6.11 (4.46-7.87)	23.29 (2.66-27.28)
<b>Litchfield, CT</b>	0.26 (0.25-0.26)	0.05 (0.04-0.05)	0.05 (0.05-0.05)	0.05 (0.05-0.05)	0.06 (0.06-0.07)	0.05 (0.05-0.05)	0.05 (0.05-0.05)	0.2 (0.11-0.21)
<b>Merrimack, NH</b>	70.62 (61.88-71.75)	18.09 (17.89-18.41)	18.28 (18.05-18.73)	18.15 (17.93-18.53)	18.75 (16.42-19.24)	18.37 (18.15-18.81)	18.15 (17.93-18.53)	69.51 (68.74-70.68)
<b>Middlesex, CT</b>	41.77 (0.01-44.73)	15.84 (13.68-17.64)	20.67 (18.39-22.36)	15.69 (13.67-17.46)	15.27 (14.33-16.03)	18.41 (16.28-19.87)	14.07 (12.17-15.74)	40.83 (38.7-42.46)
<b>Middlesex, MA</b>	39.75 (38.71-40.74)	10.45 (10.08-11.11)	10.36 (10.02-10.96)	10.36 (10.04-10.83)	10.22 (9.95-10.49)	10.28 (9.99-10.59)	10.36 (10.04-10.83)	39.44 (38.38-40.41)

	<b>A</b>	<b>B1</b>	<b>B2</b>	<b>B3</b>	<b>C1</b>	<b>C2</b>	<b>C3</b>	<b>D</b>
<b>New Haven, CT</b>	188.75 (36.73-195.24)	147.91 (143.55- 151.06)	158.86 (154.82- 161.83)	146.45 (142.53- 149.18)	123.34 (122.31- 124.62)	150.62 (75.49- 153.11)	140.37 (40.52- 143.22)	250.92 (60.09-254.62)
<b>New London, CT</b>	24.08 (23.53-25.03)	1.09 (0.98-1.18)	1.16 (1.06-1.25)	1.11 (1.01-1.2)	1.33 (1.23-1.46)	1.19 (1.09-1.29)	1.11 (1.01-1.2)	17.74 (16.83-18.79)
<b>Newport, RI</b>	14.17 (13.68-14.74)	13.75 (13.35-14.15)	14.75 (14.39-15.1)	13.54 (13.14-13.9)	9.38 (9.17-9.63)	13.86 (13.55-14.28)	12.89 (12.5-13.28)	22.44 (21.95-24.29)
<b>Norfolk, MA</b>	139.72 (30.38-146.15)	73.54 (29.6-78.51)	87.34 (28.42-92.66)	73.06 (66.86-78.09)	72.05 (28.81-74.73)	80.7 (74.71-85.37)	68.44 (29.97-73.01)	124.91 (30.41-130.22)
<b>Oxford, ME</b>	2.77 (2.65-3.18)	2.62 (2.48-2.76)	2.92 (2.79-3.08)	2.59 (2.45-2.72)	1.92 (1.82-2.04)	2.72 (2.59-2.86)	2.42 (2.28-2.52)	3.36 (3.07-3.67)
<b>Penobscot, ME</b>	1.69 (1.58-1.8)	0.22 (0.16-0.27)	0.36 (0.16-0.45)	0.21 (0.16-0.27)	0.3 (0.23-0.37)	0.3 (0.22-0.37)	0.18 (0.13-0.23)	0.74 (0.61-0.88)
<b>Providence, RI</b>	155.66 (54.62-161.63)	85.08 (51.56-90.5)	100.14 (58.36- 106.62)	84.71 (78.94-89.84)	82.23 (78.76-85.37)	92.86 (86.42-98.6)	79.45 (48.35-84.13)	241.53 (92.83-248.91)
<b>Rockingham, NH</b>	215.91 (118.4-221.38)	47.93 (19.91-50.4)	53.96 (20.84-56.58)	48.08 (45.5-50.54)	51.99 (50.55-53.39)	52.21 (40.66-54.41)	46.22 (20.1-48.73)	240.21 (66.34-244.53)
<b>Suffolk, MA</b>	9.71 (9.28-10.18)	3.9 (3.85-3.94)	3.85 (3.78-3.91)	3.89 (3.84-3.94)	3.59 (3.44-3.71)	3.83 (3.74-3.89)	3.89 (3.84-3.94)	13.2 (12.87-13.52)
<b>Windham, CT</b>	57.98 (54.7-60.91)	23.34 (18.67-26.79)	31.95 (26.68-35.24)	23.13 (18.61-26.45)	23.6 (21.41-25.14)	28.04 (23.34-31.1)	20.5 (16.41-23.62)	81.04 (51.57-84.08)
<b>Worcester, MA</b>	109.49 (47.81-114.19)	38.35 (30.78-43.62)	53.09 (1.14-59.23)	38.01 (30.87-43.23)	40.14 (35.61-43.69)	46.47 (38.87-51.85)	33.5 (0.74-38.51)	88.71 (43.48-95.3)

Table S15: Net present value of air emission costs (in millions of 2024 USD, discounted at 2%) across eight decarbonization pathways

	A	B1	B2	B3	C1	C2	C3	D
<b>Barnstable, MA</b>	20.92 (20.46-21.73)	4.6 (4.37-5.08)	4.74 (4.5-5.23)	4.63 (4.41-4.98)	5.23 (5.03-5.57)	4.81 (4.6-5.32)	4.63 (4.41-4.98)	18.75 (18.17-19.78)
<b>Berkshire, MA</b>	2.73 (1.48-2.91)	0.36 (0.26-0.46)	0.57 (0.41-0.73)	0.36 (0.26-0.47)	0.56 (0.41-0.7)	0.5 (0.36-0.64)	0.3 (0.21-0.4)	1.32 (1.06-1.56)
<b>Bristol, MA</b>	23.52 (5.52-24.37)	17.6 (5.97-18.21)	19.31 (18.62-19.95)	17.42 (16.7-18.21)	13.09 (1.15-13.7)	18.16 (17.49-18.75)	16.36 (15.6-17.03)	22.65 (3.46-24.52)
<b>Chittenden, VT</b>	15.86 (15.16-16.62)	3.7 (3.53-4.21)	3.74 (3.54-4.27)	3.7 (3.53-4.29)	3.8 (3.64-4.19)	3.75 (3.6-4.3)	3.7 (3.53-4.29)	16.09 (15.44-16.82)
<b>Coos, NH</b>	22.03 (21.35-22.81)	28.55 (27.76-29.17)	29.65 (28.93-30.48)	28.11 (27.36-28.75)	18.7 (17.54-19.44)	28.65 (27.88-29.2)	27.23 (26.32-28.06)	22.07 (21.38-22.84)
<b>Cumberland, ME</b>	88.43 (29.19-90.81)	36.53 (17.74-38.29)	39.16 (17.82-40.85)	36.48 (34.91-38.11)	33.85 (19.84-35.7)	37.9 (36.6-39.58)	35.33 (17.5-36.9)	90.98 (68.07-96.91)
<b>Essex, MA</b>	22.81 (1.09-26.55)	20.39 (0.07-21.5)	22.79 (0.08-23.99)	20.17 (19.1-21.14)	15.42 (0.09-16.7)	21.32 (0.08-22.44)	18.82 (0.07-19.77)	27.2 (0.75-29.98)
<b>Fairfield, CT</b>	94.6 (0.03-99.1)	54.94 (0.11-57.36)	64.18 (1.2-66.48)	54.66 (51.09-56.97)	48.47 (47.23-49.44)	59.21 (48.64-61.34)	50.17 (20.06-52.45)	163.24 (76.09-165.01)
<b>Hampden, MA</b>	15.9 (11.83-17.34)	12.29 (11.49-12.86)	13.74 (9.49-14.34)	12.14 (11.36-12.77)	9.36 (8.86-9.83)	12.73 (12.03-13.29)	11.32 (10.62-11.94)	15.86 (13.58-18.01)
<b>Hillsborough, NH</b>	40.3 (37.84-42.38)	6.96 (5.09-8.8)	11.5 (8.75-13.92)	6.9 (5.13-8.8)	9.4 (7.48-11.49)	9.58 (7.26-11.85)	5.81 (4.23-7.51)	21.65 (2.59-25.42)
<b>Litchfield, CT</b>	0.24 (0.24-0.24)	0.05 (0.04-0.05)	0.05 (0.05-0.05)	0.05 (0.04-0.05)	0.06 (0.06-0.06)	0.05 (0.05-0.05)	0.05 (0.04-0.05)	0.19 (0.1-0.2)
<b>Merrimack, NH</b>	66.39 (58.62-67.46)	17.79 (17.59-18.1)	17.98 (17.75-18.42)	17.84 (17.64-18.22)	18.44 (16.17-18.91)	18.06 (17.85-18.49)	17.84 (17.64-18.22)	65.37 (64.65-66.47)
<b>Middlesex, CT</b>	39.14 (0.01-41.92)	15.18 (13.12-16.9)	19.72 (17.56-21.33)	15.06 (13.13-16.75)	14.88 (13.97-15.61)	17.69 (15.66-19.09)	13.54 (11.73-15.15)	38.33 (36.3-39.87)
<b>Middlesex, MA</b>	37.38 (36.39-38.3)	10.28 (9.91-10.93)	10.19 (9.85-10.78)	10.19 (9.88-10.65)	10.05 (9.78-10.32)	10.11 (9.82-10.41)	10.19 (9.88-10.65)	37.09 (36.1-38.01)
<b>New Haven, CT</b>	177.27 (34.84-183.33)	140.71 (136.63-143.64)	150.84 (147.09-153.6)	139.45 (135.77-142.01)	118.61 (117.62-119.85)	143.44 (71.54-145.75)	133.79 (38.59-136.48)	234.34 (56.35-237.83)
<b>New London, CT</b>	22.49 (21.96-23.37)	1.09 (0.98-1.17)	1.15 (1.05-1.24)	1.1 (1-1.19)	1.33 (1.22-1.45)	1.19 (1.08-1.28)	1.1 (1-1.19)	16.61 (15.75-17.58)

	A	B1	B2	B3	C1	C2	C3	D
<b>Newport, RI</b>	13.32 (12.87-13.86)	13.05 (12.68-13.42)	13.97 (13.64-14.29)	12.87 (12.49-13.2)	9.07 (8.87-9.3)	13.16 (12.88-13.55)	12.26 (11.9-12.62)	21.05 (20.59-22.79)
<b>Norfolk, MA</b>	130.66 (28.31-136.65)	70 (28.08-74.76)	82.97 (26.97-88.03)	69.62 (63.69-74.44)	69.42 (27.38-72.06)	77.03 (71.29-81.49)	65.31 (28.43-69.7)	117.09 (28.53-122.14)
<b>Oxford, ME</b>	2.61 (2.49-2.99)	2.5 (2.37-2.63)	2.77 (2.65-2.92)	2.47 (2.34-2.59)	1.86 (1.76-1.98)	2.59 (2.48-2.73)	2.31 (2.18-2.41)	3.16 (2.89-3.45)
<b>Penobscot, ME</b>	1.56 (1.46-1.67)	0.2 (0.15-0.26)	0.34 (0.16-0.43)	0.2 (0.15-0.26)	0.29 (0.23-0.36)	0.28 (0.21-0.35)	0.17 (0.12-0.21)	0.69 (0.57-0.82)
<b>Providence, RI</b>	145.74 (51.3-151.33)	80.91 (48.93-86.1)	95.11 (55.36-101.28)	80.64 (75.1-85.57)	79.12 (75.71-82.19)	88.55 (82.37-94.05)	75.72 (45.92-80.23)	223.01 (87.16-229.99)
<b>Rockingham, NH</b>	202.71 (111.23-207.79)	46.75 (19.64-49.12)	52.46 (20.54-54.96)	46.92 (44.45-49.3)	51.02 (49.61-52.38)	50.93 (39.59-53.04)	45.18 (19.82-47.6)	223.91 (61.35-227.98)
<b>Suffolk, MA</b>	9.12 (8.72-9.56)	3.83 (3.78-3.87)	3.79 (3.72-3.84)	3.83 (3.78-3.87)	3.52 (3.38-3.65)	3.77 (3.68-3.83)	3.83 (3.78-3.87)	12.41 (12.1-12.71)
<b>Windham, CT</b>	54.32 (51.29-57.08)	22.3 (17.84-25.6)	30.42 (25.4-33.53)	22.14 (17.81-25.33)	22.97 (20.84-24.46)	26.89 (22.4-29.82)	19.68 (15.75-22.68)	75.21 (48.24-78.11)
<b>Worcester, MA</b>	102.34 (44.76-106.73)	36.61 (29.38-41.65)	50.51 (1.09-56.35)	36.36 (29.53-41.36)	39.05 (34.65-42.51)	44.53 (37.27-49.68)	32.14 (0.72-36.95)	83.07 (40.82-89.32)

Table S16: Net present value of air emission costs (in millions of 2024 USD, discounted at 2.5%) across eight decarbonization pathways

	A	B1	B2	B3	C1	C2	C3	D
<b>Barnstable, MA</b>	19.64 (19.21-20.4)	4.52 (4.3-5)	4.66 (4.42-5.14)	4.55 (4.34-4.9)	5.14 (4.95-5.47)	4.73 (4.53-5.23)	4.55 (4.34-4.9)	17.64 (17.09-18.61)
<b>Berkshire, MA</b>	2.53 (1.38-2.71)	0.34 (0.24-0.44)	0.54 (0.39-0.69)	0.34 (0.25-0.45)	0.54 (0.4-0.68)	0.48 (0.34-0.61)	0.28 (0.2-0.38)	1.22 (0.98-1.46)
<b>Bristol, MA</b>	22.12 (5.17-22.92)	16.81 (5.74-17.38)	18.4 (17.75-18.99)	16.66 (15.99-17.41)	12.7 (1.13-13.3)	17.36 (16.74-17.92)	15.67 (14.96-16.31)	21.34 (3.25-23.1)
<b>Chittenden, VT</b>	14.94 (14.28-15.65)	3.65 (3.48-4.15)	3.69 (3.49-4.21)	3.65 (3.48-4.22)	3.75 (3.58-4.13)	3.7 (3.55-4.24)	3.65 (3.48-4.22)	15.15 (14.55-15.84)
<b>Coos, NH</b>	20.75 (20.11-21.48)	27.06 (26.34-27.64)	28.06 (27.38-28.82)	26.67 (25.99-27.26)	18.07 (16.94-18.77)	27.16 (26.47-27.67)	25.87 (25.03-26.62)	20.79 (20.14-21.52)
<b>Cumberland, ME</b>	83.21 (28.51-85.44)	35.38 (17.45-37.08)	37.84 (17.53-39.47)	35.35 (33.84-36.92)	33 (19.51-34.81)	36.73 (35.49-38.36)	34.28 (17.21-35.8)	85.67 (64.1-91.25)
<b>Essex, MA</b>	21.47 (1.02-24.98)	19.48 (0.07-20.52)	21.7 (0.07-22.83)	19.29 (18.29-20.21)	14.95 (0.09-16.18)	20.38 (0.08-21.45)	18.03 (0.07-18.93)	25.62 (0.71-28.23)
<b>Fairfield, CT</b>	89 (0.03-93.23)	52.59 (0.1-54.87)	61.23 (1.15-63.38)	52.39 (49-54.58)	47.08 (45.89-48)	56.76 (46.53-58.75)	48.19 (19.27-50.36)	151.3 (71.67-152.97)
<b>Hampden, MA</b>	14.92 (11.14-16.28)	11.73 (10.98-12.26)	13.07 (9.19-13.63)	11.6 (10.87-12.19)	9.08 (8.6-9.54)	12.17 (11.51-12.68)	10.84 (10.18-11.42)	14.92 (12.79-16.95)
<b>Hillsborough, NH</b>	37.51 (35.14-39.53)	6.6 (4.81-8.37)	10.89 (8.27-13.22)	6.56 (4.86-8.39)	9.14 (7.27-11.18)	9.15 (6.93-11.34)	5.54 (4.02-7.18)	20.16 (2.53-23.72)
<b>Litchfield, CT</b>	0.23 (0.22-0.23)	0.05 (0.04-0.05)	0.05 (0.05-0.05)	0.05 (0.04-0.05)	0.06 (0.06-0.06)	0.05 (0.05-0.05)	0.05 (0.04-0.05)	0.18 (0.1-0.19)
<b>Merrimack, NH</b>	62.52 (55.61-63.53)	17.5 (17.3-17.8)	17.68 (17.46-18.12)	17.55 (17.34-17.92)	18.13 (15.93-18.6)	17.76 (17.55-18.19)	17.55 (17.34-17.92)	61.57 (60.9-62.61)
<b>Middlesex, CT</b>	36.74 (0.01-39.35)	14.56 (12.6-16.2)	18.84 (16.78-20.37)	14.48 (12.63-16.1)	14.51 (13.62-15.22)	17.01 (15.07-18.35)	13.06 (11.32-14.59)	36.03 (34.1-37.5)
<b>Middlesex, MA</b>	35.2 (34.27-36.07)	10.11 (9.75-10.75)	10.02 (9.69-10.6)	10.02 (9.71-10.48)	9.88 (9.62-10.15)	9.94 (9.66-10.24)	10.02 (9.71-10.48)	34.94 (34.01-35.81)
<b>New Haven, CT</b>	166.75 (33.11-172.42)	134.05 (130.22-136.78)	143.43 (139.95-146.01)	132.97 (129.51-135.37)	114.18 (113.22-115.37)	136.78 (67.89-138.93)	127.7 (36.8-130.23)	219.21 (52.92-222.5)
<b>New London, CT</b>	21.03 (20.53-21.86)	1.08 (0.97-1.16)	1.14 (1.05-1.23)	1.1 (0.99-1.18)	1.32 (1.22-1.44)	1.18 (1.07-1.27)	1.1 (0.99-1.18)	15.57 (14.76-16.48)

	A	B1	B2	B3	C1	C2	C3	D
<b>Newport, RI</b>	12.54 (12.12-13.05)	12.41 (12.07-12.74)	13.24 (12.94-13.53)	12.24 (11.9-12.54)	8.77 (8.58-8.99)	12.51 (12.25-12.86)	11.68 (11.35-12.01)	19.77 (19.33-21.4)
<b>Norfolk, MA</b>	122.37 (26.43-127.97)	66.72 (26.68-71.27)	78.92 (25.61-83.74)	66.43 (60.74-71.05)	66.96 (26.05-69.54)	73.6 (68.11-77.88)	62.4 (27.01-66.63)	109.93 (26.81-114.75)
<b>Oxford, ME</b>	2.45 (2.34-2.81)	2.38 (2.26-2.51)	2.64 (2.52-2.78)	2.36 (2.24-2.47)	1.8 (1.71-1.92)	2.48 (2.37-2.6)	2.21 (2.09-2.31)	2.98 (2.72-3.25)
<b>Penobscot, ME</b>	1.45 (1.35-1.55)	0.19 (0.14-0.24)	0.33 (0.15-0.4)	0.19 (0.14-0.24)	0.29 (0.22-0.35)	0.27 (0.2-0.34)	0.16 (0.11-0.2)	0.64 (0.53-0.76)
<b>Providence, RI</b>	136.68 (48.27-141.92)	77.04 (46.5-82.03)	90.45 (52.59-96.34)	76.86 (71.53-81.61)	76.21 (72.85-79.22)	84.55 (78.6-89.83)	72.25 (43.68-76.61)	206.27 (81.94-212.89)
<b>Rockingham, NH</b>	190.63 (104.66-195.36)	45.62 (19.37-47.91)	51.05 (20.26-53.43)	45.82 (43.45-48.12)	50.08 (48.71-51.41)	49.71 (38.57-51.75)	44.19 (19.55-46.53)	209.09 (56.87-212.93)
<b>Suffolk, MA</b>	8.59 (8.21-9)	3.77 (3.72-3.81)	3.72 (3.66-3.78)	3.76 (3.71-3.81)	3.47 (3.32-3.58)	3.7 (3.62-3.77)	3.76 (3.71-3.81)	11.69 (11.39-11.97)
<b>Windham, CT</b>	50.97 (48.17-53.58)	21.33 (17.06-24.5)	29 (24.21-31.95)	21.22 (17.07-24.28)	22.36 (20.29-23.8)	25.81 (21.51-28.62)	18.91 (15.14-21.8)	69.9 (45.19-72.66)
<b>Worcester, MA</b>	95.8 (41.98-99.93)	35 (28.09-39.83)	48.12 (1.05-53.68)	34.82 (28.27-39.61)	38.02 (33.73-41.37)	42.72 (35.77-47.65)	30.86 (0.69-35.5)	77.91 (38.38-83.86)

Table S17: Environmental impact metrics of energy technologies across scenarios B1–B3, C1–C3 and D. Values reported are the means, with 90% CI shown in brackets.

Technology	Unit	Pathway						
		B1	B2	B3	C1	C2	C3	D
<b><i>Bird mortality</i></b>								
On-shore wind	million bird deaths	0.01 (0.00-0.02)	0.01 (0.00-0.02)	0.01 (0.00-0.02)	0.00 (0.00-0.00)	0.01 (0.00-0.02)	0.01 (0.00-0.02)	0.00 (0.00-0.01)
	million bat deaths	0.08 (0.02-0.16)	0.08 (0.02-0.16)	0.08 (0.02-0.16)	0.00 (0.00-0.00)	0.08 (0.02-0.16)	0.08 (0.02-0.16)	0.03 (0.01-0.07)
Solar	million bird deaths	0.21 (0.01-0.43)	0.21 (0.01-0.43)	0.21 (0.01-0.43)	0.00 (0.00-0.00)	0.21 (0.01-0.43)	0.21 (0.01-0.43)	0.05 (0.00-0.10)
Sum	million avian deaths	0.29 (0.05-0.78)	0.29 (0.05-0.78)	0.29 (0.05-0.78)	0.00 (0.00-0.00)	0.29 (0.05-0.78)	0.29 (0.05-0.78)	0.08 (0.02-0.20)
<b><i>Land use</i></b>								
Hydropower reservoirs	million hectares	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.35 (0.20-0.50)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)
Natural gas	million hectares	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)
On-shore wind	million hectares	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)
Small modular nuclear	million hectares	0.41 (0.17-0.69)	0.42 (0.17-0.73)	0.41 (0.18-0.70)	0.00 (0.00-0.00)	0.41 (0.18-0.71)	0.41 (0.17-0.69)	0.18 (0.08-0.29)
Solar	million hectares	0.23 (0.10-0.37)	0.23 (0.11-0.38)	0.22 (0.10-0.36)	0.00 (0.00-0.00)	0.22 (0.11-0.36)	0.23 (0.10-0.38)	0.05 (0.02-0.08)
Sum	million hectares	0.63 (0.31-1.03)	0.65 (0.31-1.10)	0.99 (0.59-1.47)	0.00 (0.00-0.00)	0.64 (0.31-1.10)	0.63 (0.30-1.07)	0.23 (0.10-0.40)
<b><i>View shed</i></b>								
High-voltage transmission to/from Hydro-Québec	million people within viewshed	0.20 (0.07-0.39)	0.00 (0.00-0.00)	0.19 (0.10-0.33)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.23 (0.11-0.38)	0.27 (0.07-0.80)
High-voltage transmission to/from NYISO	million people within viewshed	0.90 (0.18-2.38)	0.29 (0.08-0.61)	0.79 (0.08-2.61)	0.00 (0.00-0.00)	0.76 (0.21-2.63)	0.68 (0.08-1.33)	0.64 (0.05-2.17)
Off-shore wind	million people within viewshed	6.52 (3.47-8.58)	6.16 (3.58-9.82)	3.84 (1.96-6.26)	0.00 (0.00-0.00)	6.48 (3.52-10.61)	3.60 (1.71-5.91)	0.63 (0.00-2.06)

Technology	Unit	Pathway						
		B1	B2	B3	C1	C2	C3	D
Solar	million people within viewshed	3.88 (3.46-4.49)	4.31 (3.35-4.99)	4.20 (3.34-5.52)	0.00 (0.00-0.00)	4.01 (3.43-4.35)	4.32 (3.43-5.49)	0.80 (0.58-1.11)
Sum	million people within viewshed	11.51 (7.19-15.85)	10.77 (7.01-15.42)	9.01 (5.49-14.71)	0.00 (0.00-0.00)	11.24 (7.17-17.59)	8.83 (5.33-13.11)	2.34 (0.71-6.14)
<b><i>Water withdrawals for thermal generation</i></b>								
Natural gas – dry-cooled	trillion gallons	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	2.57 (2.57-2.57)	0.33 (0.33-0.33)	0.21 (0.21-0.21)	0.00 (0.00-0.00)
Small modular nuclear – water-cooled	trillion gallons	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.05 (0.05-0.05)
Sum	trillion gallons	0.00 (0.00-0.00)	0.00 (0.00-0.00)	0.00 (0.00-0.00)	2.57 (2.57-2.57)	0.33 (0.33-0.33)	0.21 (0.21-0.21)	0.05 (0.05-0.05)

## Literature cited

Bowman, J. (2024, November 16). *Will Nuclear Stocks Soar in the New Trump Administration?*

*Here's What Investors Need To Know.* | *Nasdaq*. <https://www.nasdaq.com/articles/will-nuclear-stocks-soar-new-trump-administration-heres-what-investors-need-know>

Calder, R. S. D., Borsuk, M. E., & Robinson, C. (2020). *Analysis of environmental and economic impacts of hydropower imports for New York City through 2050.*

Calder, R. S. D., Robinson, C. S., & Borsuk, M. E. (2022). Total Social Costs and Benefits of Long-Distance Hydropower Transmission. *Environmental Science & Technology*, 56(24), 17510–17522. <https://doi.org/10.1021/acs.est.2c06221>

Castelvecchi, D. (2024). Will AI's huge energy demands spur a nuclear renaissance? *Nature*, 635(8037), 19–20. <https://doi.org/10.1038/d41586-024-03490-3>

Central Maine Power Company. (2019, February 21). *NECEC Stipulation (2017-00232) (W6918333-13)*. State of Maine, Public Utilities Commission.

<https://climate.law.columbia.edu/sites/default/files/content/CBAs/NECEC%20Stipulation.pdf>

CHPExpress. (2021, November 30). Champlain Hudson Power Express Finalizes Contract to Deliver Clean Energy to New York City. *TDI CHPExpress*.

<https://chpexpress.com/news/champlain-hudson-power-express-finalizes-contract-to-deliver-clean-energy-to-new-york-city/>

Commonwealth of Massachusetts. (2020, December). *MA Decarbonization Roadmap* | *Mass.gov* [Government]. An Official Website of the Commonwealth of Massachusetts.

<https://www.mass.gov/info-details/ma-decarbonization-roadmap>

- Curran, M. A., Mann, M., & Norris, G. (2005). The international workshop on electricity data for life cycle inventories. *Journal of Cleaner Production*, *13*(8), 853–862.  
<https://doi.org/10.1016/j.jclepro.2002.03.001>
- Dagoumas, A. S., & Koltsaklis, N. E. (2019). Review of models for integrating renewable energy in the generation expansion planning. *Applied Energy*, *242*, 1573–1587.  
<https://doi.org/10.1016/j.apenergy.2019.03.194>
- Delwiche, K. B., Harrison, J. A., Maasackers, J. D., Sulprizio, M. P., Worden, J., Jacob, D. J., & Sunderland, E. M. (2022). Estimating Drivers and Pathways for Hydroelectric Reservoir Methane Emissions Using a New Mechanistic Model. *Journal of Geophysical Research: Biogeosciences*, *127*(8), e2022JG006908. <https://doi.org/10.1029/2022JG006908>
- DeSantis, D., James, B. D., Houchins, C., Saur, G., & Lyubovsky, M. (2021). Cost of long-distance energy transmission by different carriers. *iScience*, *24*(12).  
<https://doi.org/10.1016/j.isci.2021.103495>
- Dysert, L. R. (2016). *AACE International Recommended Practice No. 18R-97*.  
<https://services.austintexas.gov/edims/document.cfm?id=280770>
- Earles, J. M., & Halog, A. (2011). Consequential life cycle assessment: A review. *The International Journal of Life Cycle Assessment*, *16*(5), 445–453.  
<https://doi.org/10.1007/s11367-011-0275-9>
- Ekvall, T. (2019). Attributional and Consequential Life Cycle Assessment. In *Sustainability Assessment at the 21st century*. IntechOpen. <https://doi.org/10.5772/intechopen.89202>
- Frew, B., Sergi, B., Denholm, P., Cole, W., Gates, N., Levie, D., & Margolis, R. (2021). The curtailment paradox in the transition to high solar power systems. *Joule*, *5*(5), 1143–1167. <https://doi.org/10.1016/j.joule.2021.03.021>

- Gazar, A. M. (2023). *Emerging nuclear energy technologies: An alternative path to Australia's energy security*. <https://vtechworks.lib.vt.edu/bitstreams/0a23ed6c-6dc7-4af7-8e57-e4dfdf98d72/download>
- Gazar, A. M., Borsuk, M. E., & Calder, R. (2024). Causal inference to scope environmental impact assessment of renewable energy projects and test competing mental models of decarbonization. *Environmental Research: Infrastructure and Sustainability*. <https://doi.org/10.1088/2634-4505/ad8fce>
- Gerrard, M. (2024). *Trump 2.0: This Time the Stakes for Climate Are Even Higher*. Yale. <https://e360.yale.edu/features/trump-second-term-climate>
- Hamlen, C., & Lenzen, J. (2024, December 19). *New England Clean Energy Connect (NECEC) Operating Agreements* [Powerpoint Presentation]. Transmission Operating Agreement and Interconnection Operators Agreement. [https://www.iso-ne.com/static-assets/documents/100018/a04\\_2024\\_12\\_19\\_tc\\_necec\\_implementation.pdf](https://www.iso-ne.com/static-assets/documents/100018/a04_2024_12_19_tc_necec_implementation.pdf)
- Hollmann, J. K., Bali, R. S., Boots, J. M., Germain, C., Guevremont, M., & Ng, K. K. (2014). *Variability in Accuracy Ranges: A Case Study in the Canadian Hydropower Industry | AACE*. [https://www.pathlms.com/aace/courses/3172/video\\_presentations/34503](https://www.pathlms.com/aace/courses/3172/video_presentations/34503)
- Hydro-Québec. (2025). *Combining Wind and Water | Basic Concepts | Hydro-Québec*. <https://www.hydroquebec.com/learning/eolienne/reperes-comprendre-complementarite.html>
- IEA, E. (2010). *Hydropower*. [https://www.iea-etsap.org/E-TechDS/HIGHLIGHTS%20PDF/E06-hydropower-GS-gct\\_ADfina\\_gs%201.pdf](https://www.iea-etsap.org/E-TechDS/HIGHLIGHTS%20PDF/E06-hydropower-GS-gct_ADfina_gs%201.pdf)
- ISO-NE. (2024a, November 4). *Variable Energy Resource (VER) Data*. <https://www.iso-ne.com/system-planning/planning-models-and-data/variable-energy-resource-data>

- ISO-NE. (2024b, November 14). *Operations Reports*. <https://www.iso-ne.com/isoexpress/web/reports/operations/-/tree/daily-capacity-status>
- L’Her, G. F., Kemp, R. S., Bazilian, M. D., & Deinert, M. R. (2024). Potential for small and micro modular reactors to electrify developing regions. *Nature Energy*, 9(6), 725–734. <https://doi.org/10.1038/s41560-024-01512-y>
- Muller, N. (2022). *APModel*. <https://nickmuller.tepper.cmu.edu/APModel.aspx>
- Naldal, L. W. (2022, June 1). *NKT signs turnkey contract for the Champlain Hudson Power Express project in the United States*. <https://www.nkt.com/news-press-releases/nkt-signs-turnkey-contract-for-the-champlain-hudson-power-express-project-in-the-united-states>
- NREL. (2021). *About | Electricity | 2021 | ATB | NREL*. <https://atb.nrel.gov/electricity/2021/about>
- NREL. (2024). *About | Electricity | 2024 | ATB | NREL*. <https://atb.nrel.gov/electricity/2024/about>
- Office of Management and Budget. (2023). *Circular No. A-4: Regulatory Analysis* (No. A-4). Executive Office of the President. <https://bidenwhitehouse.archives.gov/wp-content/uploads/2023/11/CircularA-4.pdf>
- Osaka, S. (2024, November 13). How to save money with the Inflation Reduction Act before Trump is in charge. *Washington Post*. <https://www.washingtonpost.com/climate-solutions/2024/11/13/ev-tax-credits-solar-clean-energy-trump-repeal/>
- Potomac Economics. (2024). *2023 ASSESSMENT OF THE ISO NEW ENGLAND*. External market monitor for ISO-NE. <https://www.iso-ne.com/static-assets/documents/100012/iso-ne-2023-emm-report-final.pdf>

U.S. Bureau of Labor Statistics. (2024). *CPI Home*. Bureau of Labor Statistics.

<https://www.bls.gov/cpi/>

U.S. EIA 860. (2023). *Annual Electric Power Industry Report, Form EIA-860 detailed data with previous form data (EIA-860A/860B)—U.S. Energy Information Administration (EIA)*.

<https://www.eia.gov/electricity/data/eia860/index.php>

U.S. EIA 923. (2023). *Form EIA-923 detailed data with previous form data (EIA-906/920)—U.S. Energy Information Administration (EIA)*.

<https://www.eia.gov/electricity/data/eia923/index.php>

U.S. EIA AEO. (2023). *Annual Energy Outlook 2023—U.S. Energy Information Administration (EIA)*. U.S. Energy Information Administration.

<https://www.eia.gov/outlooks/aeo/index.php>

U.S. EPA. (2023). *Supplementary Material for the Regulatory Impact Analysis for the Final Rulemaking, “Standards of Performance for New, Reconstructed, and Modified Sources and Emissions Guidelines for Existing Sources: Oil and Natural Gas Sector Climate Review”* (United States; Supplementary Materials No. Docket ID No. EPA-HQ-OAR-2021-0317; EPA Report on the Social Cost of Greenhouse Gases: Estimates Incorporating Recent Scientific Advances, p. Appendix 5). United States Government.

[https://www.epa.gov/system/files/documents/2023-12/epa\\_scghg\\_2023\\_report\\_final.pdf](https://www.epa.gov/system/files/documents/2023-12/epa_scghg_2023_report_final.pdf)

U.S. EPA AP-42, O. (2024). *AP-42: Compilation of Air Emissions Factors from Stationary Sources* [Other Policies and Guidance]. <https://www.epa.gov/air-emissions-factors-and-quantification/ap-42-compilation-air-emissions-factors-stationary-sources>

U.S. EPA CAMPD, O. (2024). *Clean Air Markets API Portal* [Data and Tools].

<https://www.epa.gov/power-sector/cam-api-portal>

U.S. EPA eGrid, O. (2022, May 17). *Download Data* [Data and Tools].

<https://www.epa.gov/egrid/download-data>

U.S. EPA GHGRP. (2024). *Greenhouse Gas Reporting Program (GHGRP) | US EPA*.

<https://www.epa.gov/ghgreporting>

Vanatta, M., Stewart, W. R., & Craig, M. T. (2024). The role of policy and module

manufacturing learning in industrial decarbonization by small modular reactors. *Nature*

*Energy*, 1–13. <https://doi.org/10.1038/s41560-024-01665-w>